


HENDRINA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Jun-2025
	Coal	Tons	820 000	301 881.0
	Fuel Oil	Tons	3 200	1741.99
Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Jun-2025
	Energy	GWh	1440	441.32
	Ash	Tons	290 000	66 595
	RE PM	kg/MWh	not specified	0.240

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.68
Ash Content	%	20 to < 35	22.06

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	50	3200	1100
South	50	3200	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jun-2025
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	100%
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	100%
Unit 6	Fabric Filter Plant (FFP)	100%
Unit 7	Fabric Filter Plant (FFP)	100%
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	100%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North					
South					

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

-Monitors were removed on 13 June 2025 for Continuous Emissions Monitoring Systems (CEMS) replacement project to improve long-term reliability and meet the Minimum Emission Standards requirements.

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of June-2025

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
North	56.2	2 813.4	1 059.8
South	49.9	1 855.7	553.1
SUM	106.1	4 669.2	1 612.9

Note: Average values from the 13th May to 12 June 2025 were used for the period of (13-30 June) where monitors were removed.

Table 6.2: Operating days in compliance to PM AEL Limit - June 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	29	1	0	0	1	42.4
South	2	8	0	20	28	61.2
SUM	31	9	0	20	29	

Note: Out of the 20 days of contravention 18 fall within the period when monitors were removed and average values used.

Table 6.3: Operating days in compliance to SO₂ AEL Limit - June 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
North	30	0	0	0	0	2 039.0
South	30	0	0	0	0	2 036.5
SUM	60	0	0	0	0	


Table 6.4: Operating days in compliance to NO_x AEL Limit - June 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
North	30	0	0	0	0	759.4
South	30	0	0	0	0	609.8
SUM	60	0	0	0	0	

Table 6.5: Legend Description


Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Hendrina North Stack PM Emissions - June 2025



Half loads were arranged as a mitigation measure during the period where monitors were unavailable, visual inspections of the FFP were conducted and 87 damaged bags were replaced at unit 05.

Figure 2: Hendrina South Stack PM Emissions - June 2025



Load losses were taken as a mitigation measure during the period where monitors were unavailable, visual inspections of the FFP were conducted and 96 damaged bags were replaced at unit 10. The station tried to arrange for spot checks but were unsuccessful.



Figure 3: Hendrina North Stack SO₂ Emissions - June 2025Figure 4: Hendrina South Stack SO₂ Emissions - June 2025

Figure 5: Hendrina North Stack NOx Emissions - June 2025





Figure 6: Hendrina South Stack NOx Emissions - June 2025



Gaseous Emission (NOx and SOx) for the North Stack: Surrogate values from QAL2 (RSL 411) have been used for reporting due to erroneous data from the Continuous Emission Monitoring System (CEMS).

Spot Check measurements have been performed internally and they confirmed the error. The station has installed new CEMS monitors. Services of an accredited service provider have been sourced for conducting both correlation and parallel tests on the recently replaced CEMS for both stacks.

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7 1 PM Start-up information for the month of June-2025

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 4		Unit 5		Unit 5		no event	
Breaker Open (BO)	8 55 pm	2025/06/21	11 45 am	2025/06/06	10 45 am	2025/06/21		
Draught Group (DG) Shut Down (SD)	DG did not tnp or SD	DG did not tnp or SD	11 05 am	2025/06/07	12 45 am	2025/06/22		
BO to DG SD (duration)	n/a	DD HH MM	00 23 20	DD HH MM	00 14 00	DD HH MM		DD HH MM
Fires in time			2025/06/14	2025/06/14	29 07 15	2025/06/29		
Synch to Grid (or BC)			12 10 pm	2025/06/15	6 00 pm	2025/06/29		
Fires in to BC (duration)		DD HH MM	00 15 15	DD HH MM	00 10 45	DD HH MM		DD HH MM
Emissions below limit from BC (end date)			not > limit	not > limit	not > limit	not > limit		
Emissions below limit from BC (duration)		DD HH MM	n/a	DD HH MM	n/a	DD HH MM		DD HH MM


South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 6		Unit 6		no event		Unit 10	
Breaker Open (BO)	2 05 am	2025/06/07	12 45 pm	2025/06/17			6 15 pm	2025/06/07
Draught Group (DG) Shut Down (SD)	2 25 am	2025/06/08	DG did not trnp or SD	DG did not trnp or SD			9 05 pm	2025/06/07
BO to DG SD (duration)	01 00 20	DD HH MM	n/a	DD HH MM		DD HH MM	00 02 50	DD HH MM
Fires in time	10 05 pm	2025/06/08					2025/06/08	2025/06/08
Synch to Grid (or BC)	4 20 pm	2025/06/09					3 10 pm	2025/06/08
Fires in to BC (duration)	00 18 15	DD HH MM		DD HH MM		DD HH MM	00 12 15	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit					not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM		DD HH MM		DD HH MM	n/a	DD HH MM


08 Complaints register


Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
The Station did not receive complaints related to air quality during the month of June 2025					


09 General


The station has installed new CEMS monitors. Services of an accredited service provider have been sourced for conducting both correlation and parallel tests on the recently replaced CEMS for both stacks to improve reliability and meet MES requirements
Reporting as per AEL Condition 7.2.8 South Stack Hours exceeded between 11-13 June 2025 43 Hours (exceedance on the average (averaged from 13 May to 12 June 2025) surrogate values used after the monitors were removed for replacement 18 days)


06/08/2025
 Compiled Environmental Officer Date
 A Boja


07/08/2025
 Checked by System Engineer Boiler/ FFP Date
 Moyahabo Cellyff Muto


07/08/2025
 Validated by Manager Boiler Engineering Manager Date
 G Kgwallhe


07/08/2025
 Authorised by GM Date
 T Lekatakala


07/08/2025
 Supported by Environmental Manager Date
 L Ntula

Compiled by Boiler Engineering Department

For Nkangala District Municipality

Copies Eskom Environmental Management

Group Technology Engineering

Hendrina Power Station

FFP SE/ Environmental Officer

Air Quality Officer

D Herbst
B Mccourt

R Rampiar
E Patel

Engineering Manager
 Operating Manager
 Maintenance Manager
 Unit Production Manager
 Boiler Engineering Manager
 System Engineer Boiler Engineering
 Environmental Officer
 C & I Engineering Manager
 Production Manager
 Environmental Manager
 PSM