	<b>Technical and Generic Report</b>	<b>Matimba Power Station</b>
---	-------------------------------------	------------------------------

Title: **Matimba Power Station March 2025 emissions report** Document Identifier: **RP/247/058**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **30**

Report Date: **March 2025**

Disclosure Classification: **Controlled**

**Compiled by**



**Kamogelo Kwata**  
**Environmental Officer**  
**(GIT)**

Date: 2025-05-05


**Reviewed by**



**Helry Ramahlare**  
**Senior Advisor**  
**Environment**

Date: 2025-05-05

**Functional Responsibility**



**MC Mamabolo**  
**Environmental**  
**Manager**

Date: 06.05.2025

**Authorized by**



**Obakeng Mabotja**  
**General Manager**

Date: 2025/06/06

## Content

	Page
1. Report Summary .....	5
2. Emission information .....	6
2.1 Raw materials and products.....	6
2.2 Abatement technology.....	6
2.3 Emissions reporting.....	7
2.3.1 Particulate Matter Emissions.....	7
2.3.2 Gaseous Emissions .....	10
2.3.2.a SOx Emissions .....	10
2.3.2.b NOx Emissions.....	13
2.3.3 Total Volatile Organic Compounds .....	16
2.3.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	17
2.4 Daily power generated. ....	17
2.5 Pollutant Tonnages .....	21
2.6 Operating days in compliance to PM AEL Limit .....	21
2.7 Operating days in compliance to SOx AEL Limit .....	21
2.8 Operating days in compliance to NOx AEL Limit .....	22
2.9 Reference values .....	22
2.10 Continuous Emission Monitors.....	22
2.10.1 Reliability.....	22
2.10.2 Changes, downtime, and repairs .....	24
2.10.3 Sampling dates and times.....	25
2.11 Units Start-up information .....	26
2.12 Emergency generation .....	28
2.13 Complaints register. ....	28
2.14 Air quality improvements and social responsibility conducted. ....	28
Air quality improvements.....	28
Social responsibility conducted. ....	28
2.15 Ambient air quality monitoring.....	29
2.16 Electrostatic precipitator and Sulphur plant status.....	29
2.17 General.....	30
3. Attachments.....	30
4. Report Conclusion .....	30
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	6
Table 2: Abatement Equipment Control Technology Utilised.....	6
Table 3: Energy Source Material Characteristics. ....	7
Table 4: Total volatile compound estimates .....	16

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 5: Daily power generated per unit in MWh for the month of March 2025 .....	17
Table 6: Pollutant tonnages for the month of March 2025 .....	21
Table 7: Operating days in compliance with PM AEL limit of March 2025 .....	21
Table 8: Operating days in compliance with SO <sub>x</sub> AEL limit of March 2025 .....	21
Table 9: Operating days in compliance with NO <sub>x</sub> AEL limit of March 2025 .....	22
Table 10: Reference values for data provided, March 2025 .....	22
Table 11: Monitor reliability percentage (%) .....	22
Table 12: Average percentage (%) availability of monitors for the month of March 2025. ....	23
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 6. ....	25
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO <sub>2</sub> and NO <sub>x</sub> for unit 1, 5 and 6) ...	25
Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only.....	25
Table 16: Start-up information .....	26
Table 17: Emergency generation .....	28
Table 18: Complaints.....	28

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of March 2025 .....	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2025 .....	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2025 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2025 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of March 2025 .....	9
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of March 2025.....	10
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of March 2025.....	11
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of March 2025.....	11
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of March 2025.....	12
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of March 2025.....	12
Figure 11: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of March 2025.....	13
Figure 12: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of March 2025.....	14
Figure 13: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of March 2025.....	14
Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of March 2025.....	15
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of March 2025.....	15
Figure 16: Unit 1 daily generated power in MWh for the month of March 2025.....	18

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 17: Unit 3 daily generated power in MWh for the month of March 2025.....18

Figure 18: Unit 4 daily generated power in MWh for the month of March 2025.....19

Figure 19: Unit 5 daily generated power in MWh for the month of March 2025.....19

Figure 20: Unit 6 daily generated power in MWh for the month of March 2025.....20

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for March 2025. The information recorded in the report is obtained from Matimba Emission Reporting tool V10.2024.



During the period under review, Matimba experienced ninety-two (92) exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ), eighty-one (81) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and eleven (11) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ). There were no exceedances of the daily  $\text{NO}_x$  emission limit ( $750\text{mg}/\text{Nm}^3$ ).

Flue gas conditioning plant availability was below 90% for unit 1, 2, 3, 4 and 5. Unit 1 was returned from outage on the 25<sup>th</sup> March 2025 and had faulty burner issues. Unit 2 was offload for the whole of March 2025. Unit 3  $\text{SO}_3$  plant's availability was 60% due to the faulty sulphur burner inlet valve that had no actuator spare. Unit 4  $\text{SO}_3$  plant's availability was 87% due to the sulphur control valve that had to be repaired. Unit 5  $\text{SO}_3$  plant's availability 80% due to low precipitators inlet temperature. Unit 6  $\text{SO}_3$  plant's availability was 95% due to blower failing to start.

The consumption rates for fuel oil for the month of March 2025 exceeded the limit of 1200 tons by 2871.492 tons due to multiple units light up trips and unit 1 and unit 2 cold start up.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1: Quantity of Raw Materials and Products used/produced for the month.**

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	693 494
	Fuel Oil	Tons/month	1 200	2871.492
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1708.344
	Ash	Tons/month	547500	251 573.914

The consumption rates for fuel oil for the month of March 2025 exceeded the permitted maximum limits due to multiple units light up trips and combustion support.

### 2.2 Abatement technology

**Table 2: Abatement Equipment Control Technology Utilised**

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.933%
Unit 2	Electrostatic Precipitator	100%	Off
Unit 3	Electrostatic Precipitator	100%	99.988%
Unit 4	Electrostatic Precipitator	100%	99.988%
Unit 5	Electrostatic Precipitator	100%	99.984%
Unit 6	Electrostatic Precipitator	100%	99.986%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	0%
Unit 2	SO <sub>3</sub> Plant	100%	0%
Unit 3	SO <sub>3</sub> Plant	100%	60%
Unit 4	SO <sub>3</sub> Plant	100%	87%
Unit 5	SO <sub>3</sub> Plant	100%	80%
Unit 6	SO <sub>3</sub> Plant	100%	95%

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 1,2,3 ,4 and 5. Unit 1 was returned from outage on the 25<sup>th</sup> March 2025 and had faulty burner issues. Unit 2 was offload for the whole of March 2025. Unit 3 SO<sub>3</sub> plant was on hold due to faulty sulphur burner inlet valve that had no actuator spare. Unit 4 SO<sub>3</sub> plant was on permit to work(off) for sulphur control valve repair. Unit 5 SO<sub>3</sub> on hold mode due to low precipitators inlet temperature. Unit 6 SO<sub>3</sub> plant was off due to blower failing to start.

**Table 3: Energy Source Material Characteristics.**

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.142%
	Ash Content	40%	36.276%

Energy source characteristics remained within the ranges stipulated in the license.


## 2.3 Emissions reporting

### 2.3.1 Particulate Matter Emissions

The emission monitors correlation and parallel tests were performed on unit 2,3 and 4 in June 2024 and the curves were applied on emissions calculations for March 2025. Unit 1,5 and 6 emission calculations were done using the correlation/parallel tests curves from the spot test performed in August 2023. Unit 2 PM correlation curve applied is linear curve, Unit 3 and 4 PM correlation curve applied is polynomial curve.

#### Unit 1 Particulate Emissions

Unit 1 is on outage



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of March 2025**

**Interpretation:** Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 26 to 31 of March 2025. The exceedances from 26 to 31 March 2025 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency. Unit 1 monitor was not calibrated when other PM(dust) unit monitors were calibrated because the unit was on outage. Unit 1 was returned from outage on the 26<sup>th</sup> of March 2025 not calibrated resulting in the poor monitor reliability, data was removed and the emissions reporting tool used averages from the 26<sup>th</sup> to the 30<sup>th</sup> March 2025.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions

Unit 2 offload.

## Unit 3 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2025

**Interpretation:** Unit 3 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1 to 31 March 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## Unit 4 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2025

**Interpretation:** Unit 4 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1 to 13 and 21 to 31 March 2025. Exceedances from 1 to 13 and 23 to 31 March 2025 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency. Unit 4 dust monitor was reading almost one value on the 1<sup>st</sup> to 4<sup>th</sup> of March 2025 due to the continuous blockages that were caused by the high amount of ash passing through the flue gas stack.


## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




## Unit 5 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2025**

**Interpretation:** Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1 to 31 March 2025. Exceedances from the 11 to 31 March 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## Unit 6 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of March 2025**

**Interpretation:** Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1 to 5 March 2025. The exceedances from 3 to 5 March 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


### 2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in March 2025 as per the Eskom emission standard requirement.

The quality assurance tests (QAL2) used for March 2025 emission calculations were performed in June 2024 for Unit 2,3 and 4. Unit 1,5 and 6 quality assurance curves utilized are spot tests performed in August 2023

#### 2.3.2.a SO<sub>x</sub> Emissions

##### Unit 1 SO<sub>2</sub> Emissions



**Figure 6: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of March 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable from January 2025 due to water ingress issue that passed to north stack from south stack. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 1.


##### Unit 2 SO<sub>2</sub> Emissions

##### Unit 2 offload

#### CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 3 SO<sub>2</sub> Emissions**

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of March 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable in January 2025 till 19<sup>th</sup> March 2025 due to water ingress issue that passed to north stack from south stack. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 3 from the 1<sup>st</sup> to 19<sup>th</sup> March 2025.

**Unit 4 SO<sub>2</sub> Emissions**


**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of March 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 4.

**CONTROLLED DISCLOSURE**


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of March 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 5.

Unit 6 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of March 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 6.


## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.3.2.b NO<sub>x</sub> Emissions

#### Unit 1 NO<sub>x</sub> Emissions



**Figure 11: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of March 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable from January 2025 due to water ingress issue that passed to north stack from south stack. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 1.


#### Unit 2 NO<sub>x</sub> Emissions

Unit offload.

#### CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 3 NO<sub>x</sub> Emissions**

**Figure 12: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of March 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable in January 2025 till 19<sup>th</sup> March 2025 due to water ingress issue that passed to north stack from south stack. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 3 from the 1<sup>st</sup> to 19<sup>th</sup> March 2025.

**Unit 4 NO<sub>x</sub> Emissions**


**Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of March 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 4.

**CONTROLLED DISCLOSURE**


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 5 NO<sub>x</sub> Emissions**

**Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of March 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 5.

**Unit 6 NO<sub>x</sub> Emissions**

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of March 2025**


**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. The monitor was reported to be unavailable on the 18<sup>th</sup> of December 2025 due to water ingress. Moisture in the control air affected the efficiency of the monitor. SRM (Standard Reference Material) values from the parallel test were used to calculate the gaseous emissions for unit 6.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**2.3.3 Total Volatile Organic Compounds****Table 4:** Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
<b>Date:</b>	Tuesday, 29 April 2025	
<b>Station:</b>	Matimba Power Station	
<b>Province:</b>	Limpopo Province	
<b>Tank no.</b>	1-4	
<b>Description:</b>	Outdoor fuel oil storage tank	
<b>Tank Type:</b>	Vertical fixed roof (vented to atmosphere)	
<b>Material stored:</b>	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
<b>MONTH:</b>	<b>March</b>	
<b>GENERAL INFORMATION:</b>	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	<b>2871.492</b>	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	23.67	°C
Daily maximum ambient temperature	30.21	°C
Daily minimum ambient temperature	17.89	°C
Daily ambient temperature range	12.31	°C
Daily total insolation factor	5.08	kWh/m²/day
Tank paint colour	<b>Grey/medium</b>	NA
Tank paint solar absorbance	0.68	NA
<b>FINAL OUTPUT:</b>	<b>Result</b>	<b>Unit</b>
Breathing losses:	<b>0.55 kg/month</b>	
Working losses:	<b>0.08 kg/month</b>	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0.63 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### 2.3.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.4 Daily power generated.


**Table 5:** Daily power generated per unit in MWh for the month of March 2025

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2025/03/01	Unit off	Unit off	12129.5	11202.1	Unit off	10605.5
2025/03/02	Unit off	Unit off	11341.8	10607.8	Unit off	9920.24
2025/03/03	Unit off	Unit off	12185	11330.7	Unit off	10163
2025/03/04	Unit off	Unit off	10083.5	11053.2	Unit off	10181.8
2025/03/05	Unit off	Unit off	12044	11390.4	Unit off	9991.81
2025/03/06	Unit off	Unit off	11499.8	11332	Unit off	10166.2
2025/03/07	Unit off	Unit off	11709.2	11657.3	Unit off	10022.2
2025/03/08	Unit off	Unit off	11192.4	11588.9	4366.24	10198.9
2025/03/09	Unit off	Unit off	11026.2	10437.1	10779.9	10160.4
2025/03/10	Unit off	Unit off	10228.6	10417.9	10101.4	10546.6
2025/03/11	Unit off	Unit off	10232.2	10409.9	10106.7	11010.7
2025/03/12	Unit off	Unit off	10245.2	10415.9	10110.2	11336.7
2025/03/13	Unit off	Unit off	10255.9	10205.2	10122.6	11353.5
2025/03/14	Unit off	Unit off	10247.8	10148.9	10121	11498.1
2025/03/15	Unit off	Unit off	10239.6	10320.8	10128.8	11494.8
2025/03/16	Unit off	Unit off	10240.9	9803.79	10121.5	10678.4
2025/03/17	Unit off	Unit off	10249.1	11613.5	10117.4	10738.9
2025/03/18	Unit off	Unit off	10246.1	12550.1	8570.06	10902.3
2025/03/19	Unit off	Unit off	10253	12295.4	10110.7	11075
2025/03/20	Unit off	Unit off	10256.2	12349.1	10191.6	10995.3
2025/03/21	Unit off	Unit off	10246.1	12522.3	10192.7	10415.2
2025/03/22	Unit off	Unit off	10198.1	12426.8	10189.3	10328.7
2025/03/23	Unit off	Unit off	10233.8	12506.3	10113.4	11072.9
2025/03/24	Unit off	Unit off	11396.5	11155.5	10179.8	10905
2025/03/25	4596.56	Unit off	11329.1	10345.6	10169.7	10801.8
2025/03/26	9046.51	Unit off	11381	9986.87	10008.4	11293.1
2025/03/27	6097.29	Unit off	10707	10072.9	10143.6	10504.1
2025/03/28	9792.05	Unit off	11222.6	10109	10121.7	59.3114
2025/03/29	9305.4	Unit off	11221.6	10391.4	10039.2	Unit off
2025/03/30	9977.87	Unit off	11157.7	10106.6	9954.17	Unit off
2025/03/31	10078.5	3874.47	11027.3	9993.46	10149.4	Unit off


### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 16: Unit 1 daily generated power in MWh for the month of March 2025**




**Figure 17: Unit 3 daily generated power in MWh for the month of March 2025**


### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 18: Unit 4 daily generated power in MWh for the month of March 2025**




**Figure 19: Unit 5 daily generated power in MWh for the month of March 2025**

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 20: Unit 6 daily generated power in MWh for the month of March 2025**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.5 Pollutant Tonnages

The emitted pollutant tonnages for March 2025 are provided in table 6.

**Table 6:** Pollutant tonnages for the month of March 2025

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	54.9	922.4	186.6
Unit 2	Exempt	0.0	0.0
Unit 3	2 170.9	4 549.9	795.8
Unit 4	80.0	497.1	86.3
Unit 5	480.6	3 961.3	828.3
Unit 6	90.5	4 429.2	1 026.9
<b>SUM</b>	<b>2 876.9</b>	<b>14 359.9</b>	<b>2 923.8</b>

## 2.6 Operating days in compliance to PM AEL Limit

**Table 7:** Operating days in compliance with PM AEL limit of March 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	0	2	0	4	6	239.5
Unit 2	Exempt	Exempt	Exempt	Exempt	Exempt	Exempt
Unit 3	0	0	0	31	31	1 283.7
Unit 4	7	2	0	22	24	494.6
Unit 5	0	2	0	21	23	334.1
Unit 6	20	5	0	3	8	53.5
<b>SUM</b>	<b>27</b>	<b>11</b>	<b>0</b>	<b>81</b>	<b>92</b>	

## 2.7 Operating days in compliance to SO<sub>x</sub> AEL Limit

**Table 8:** Operating days in compliance with SO<sub>x</sub> AEL limit of March 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
Unit 1	8	0	0	0	0	2 601.5
Unit 2	0	0	0	0	0	
Unit 3	31	0	0	0	0	2 720.9
Unit 4	31	0	0	0	0	3 072.7
Unit 5	24	0	0	0	0	2 670.7
Unit 6	28	0	0	0	0	2 470.5
<b>SUM</b>	<b>122</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.8 Operating days in compliance to NOx AEL Limit

**Table 9: Operating days in compliance with NOx AEL limit of March 2025**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
Unit 1	8	0	0	0	0	526.2
Unit 2	0	0	0	0	0	
Unit 3	31	0	0	0	0	475.6
Unit 4	31	0	0	0	0	533.4
Unit 5	24	0	0	0	0	558.4
Unit 6	28	0	0	0	0	572.8
<b>SUM</b>	<b>122</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

## 2.9 Reference values

**Table 10: Reference values for data provided, March 2025**

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	9.48		9.22	7.98	7.34	9.84
Moisture	%	4.54		4.83	5.92	5.12	3.66
Velocity	m/s	24.0	10.2	23.5	2.1	23.7	29.1
Temperature	°C	110.3		133.4	136.4	122.5	110.0
Pressure	mBar	898.9	923.9	917.5	904.4	902.3	902.1

## 2.10 Continuous Emission Monitors

### 2.10.1 Reliability

**Table 11: Monitor reliability percentage (%)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
Unit 1	0.0	100.0	100.0
Unit 2	Exempt	Exempt	Exempt
Unit 3	82.8	99.9	99.9
Unit 4	69.2	100.0	100.0
Unit 5	57.1	100.0	100.0
Unit 6	96.6	100.0	100.0

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Note: NO<sub>x</sub> emissions are measured as NO in PPM. Final NO<sub>x</sub> value is expressed as total NO<sub>2</sub>.

Continuous emission monitors were reliable for less than 80% of the reporting period for unit 1, 3, 4 and 5 PM. Unit 1 PM monitor reliability was low zero because the dust monitor was not calibrated and the monitor kept maxing out of the monitor's range since the unit was synchronized. Unit 3 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 4 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1, 3, 4, 5 and 6 gaseous monitor reliability was above 99% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1, 3, 4, 5 and 6.

**Table 12:** Average percentage (%) availability of monitors for the month of March 2025.

Unit	SO <sub>2</sub>	NO <sub>x</sub>	PM	CO <sub>2</sub>
1	100.0	100.0	0.0	100.0
2	Exempt	Exempt	Exempt	Exempt
3	99.9	99.9	82.8	100.0
4	100.0	100.0	69.2	100.0
5	100.0	100.0	57.1	100.0
6	100.0	100.0	96.6	100.0

Continuous emission monitors were available for less than 80% of the reporting period for unit 1, 3, 4 and 5 PM. Unit 1 PM monitor availability was low zero because the dust monitor was not calibrated and the monitor kept maxing out of the monitor's range since the unit was synchronized. Unit 3 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 4 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1, 3, 4, 5 and 6 gaseous monitor availability was above 99% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1, 3, 4, 5 and 6.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.10.2 Changes, downtime, and repairs**

### **Unit 1**

- No adjustments done on the CEMs.
- Correlation test to be done.

### **Unit 2**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

### **Unit 3**

- No adjustments done on the CEMs.
- Correlation test to be done.

### **Unit 4**

- No adjustments done on the CEMs.
- Correlation test to be done.

### **Unit 5**

- No adjustments done on the CEMs.
- Correlation test to be done.

### **Unit 6**

- No adjustments done on the CEMs.
- Correlation test to be done.

## **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**2.10.3 Sampling dates and times****Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 6.

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
6	2020/09/09 06h41	New sampling tests in table 14	New sampling tests in table 14	New sampling tests in table 14

**Table 14:** Dates of last conducted CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> for unit 1, 5 and 6)

<b>Name of service provider:</b>		Levego Environmental services		
<b>Address of service provider:</b>		Building R6 Pineland site Ardeer Road Modderfontein 1645		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 13 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

Note: The CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> were performed in August 2023. PM spot verification test results for unit 6 failed and old curves are still in use.

**Table 15:** Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

<b>Name of service provider:</b>		Levego Environmental services		
<b>Address of service provider:</b>		Building R6 Pineland site Ardeer Road Modderfontein 1645		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
2	2024/07/02 08h50	2024/07/02 12h35	2024/07/02 12h35	2024/07/02 12h35
3	2024/06/23 16h34	2024/06/23 14h00	2024/06/23 14h00	2024/06/23 14h00
4	2024/06/29 16h05	2024/06/29 11h00	2024/06/29 11h00	2024/06/29 11h00

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.11 Units Start-up information

**Table 16:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2025/03/23	09h45
<b>Synchronization with Grid</b>	2025/03/25	09h35
<b>Emissions below limit</b>	N/A	The unit did not go below the limit after it was returned from outage March 2025.
<b>Fires in, to synchronization</b>	47.50	HOURS
<b>Synchronization to &lt; Emission limit</b>	N/A	HOURS

<b>Unit</b>	2	
<b>Fires in</b>	2025/03/30	22h09
<b>Synchronization with Grid</b>	2025/03/31	09h56
<b>Emissions below limit</b>	N/A	The unit did not go below the limit after it was returned from outage March 2025.
<b>Fires in, to synchronization</b>	11.47	HOURS
<b>Synchronization to &lt; Emission limit</b>	N/A	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	5	
<b>Fires in</b>	2025/03/07	19h49
<b>Synchronization with Grid</b>	2025/03/08	11h10
<b>Emissions below limit</b>	N/A	The unit did not go below the limit after it was returned from outage March 2025.
<b>Fires in, to synchronization</b>	15.21	HOURS
<b>Synchronization to Emission limit &lt;</b>	N/A	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.12 Emergency generation

**Table 17:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	744	744	744	744	744	744
<b>Emergency Hours declared including hours after standing down</b>	160.340	24.000	744.000	744.000	570.750	650.050
<b>Days over the Limit during Emergency Generation</b>	6	Off	31	24	23	8

During the period under review all Units were on emergency generation in force from 01 March 2025 until 31 March 2025.

## 2.13 Complaints register.

**Table 18:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.14 Air quality improvements and social responsibility conducted.

### Air quality improvements

None

### Social responsibility conducted.

None

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The March 2025 ambient air quality monitoring report is attached to this report as an addendum.

## 2.16 Electrostatic precipitator and Sulphur plant status

### Unit 1

- Unit on outage.
- RTS on 25 March 2025.

### Unit 2

- Unit on outage.

### Unit 3

- 4 fields defective.
- Unit 3 SO<sub>3</sub> plant running at low SO<sub>3</sub> injection rate due to defective process air flow transmitters.

### Unit 4

- 5 fields defective.
- No abnormalities on the SO<sub>3</sub> plant.

### Unit 5

- 4 fields defective.
- No abnormalities on the SO<sub>3</sub> plant.

### Unit 6

- 4 fields defective.
- No abnormalities on the SO<sub>3</sub> plant.

### SO<sub>3</sub> common plant

- Sulphur supply pump number 2 not available.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.17 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

- Fugitive dustfall out monitoring report and Ambient air quality report.
- Marapong ambient air quality report

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.