


| | | |
|---|-------------------------------------|------------------------------|
|  | Technical and Generic Report | Matimba Power Station |
|---|-------------------------------------|------------------------------|

Title: **Matimba Power Station June 2025 emissions report**

Document Identifier: **RP/247/062**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **29**

Report Date: **June 2025**

Disclosure Classification: **Controlled**


Compiled by



Kamogelo Kwata
Environmental Officer
(GIT)

Date: 2025-07-31

Reviewed by



Helry Ramahlare
Senior Advisor
Environment

Date: 2025-07-31


Functional Responsibility

p.p.  MF

MC Mamabolo
Environmental
Manager

Date: 2025/07/31

Authorized by



Obakeng Mabotja
General Manager

Date: 2025-07-31

Content

| | Page |
|--|------|
| 1. Report Summary | 5 |
| 2. Emission information | 6 |
| 2.1 Raw materials and products..... | 6 |
| 2.2 Abatement technology..... | 6 |
| 2.3 Emissions reporting..... | 7 |
| 2.3.1 Particulate Matter Emissions..... | 7 |
| 2.3.2 Gaseous Emissions | 10 |
| 2.3.2.a SOx Emissions | 10 |
| 2.3.2.b NOx Emissions..... | 13 |
| 2.3.3 Total Volatile Organic Compounds | 16 |
| 2.3.4 Greenhouse gas (CO ₂) emissions | 17 |
| 2.4 Daily power generated. | 17 |
| 2.5 Pollutant Tonnages | 21 |
| 2.6 Operating days in compliance to PM AEL Limit | 21 |
| 2.7 Operating days in compliance to SOx AEL Limit | 21 |
| 2.8 Operating days in compliance to NOx AEL Limit | 22 |
| 2.9 Reference values | 22 |
| 2.10 Continuous Emission Monitors..... | 22 |
| 2.10.1 Reliability..... | 22 |
| 2.10.2 Changes, downtime, and repairs | 24 |
| 2.10.3 Sampling dates and times..... | 25 |
| 2.11 Units Start-up information | 26 |
| 2.12 Emergency generation | 27 |
| 2.13 Complaints register. | 27 |
| 2.14 Air quality improvements and social responsibility conducted. | 28 |
| Air quality improvements..... | 28 |
| Social responsibility conducted. | 28 |
| 2.15 Ambient air quality monitoring..... | 28 |
| 2.16 Electrostatic precipitator and Sulphur plant status..... | 28 |
| 2.17 General..... | 29 |
| 3. Attachments..... | 29 |
| 4. Report Conclusion | 29 |
| Table 1: Quantity of Raw Materials and Products used/produced for the month..... | 6 |
| Table 2: Abatement Equipment Control Technology Utilised..... | 6 |
| Table 3: Energy Source Material Characteristics. | 7 |
| Table 4: Total volatile compound estimates | 16 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

| | |
|---|----|
| Table 5: Daily power generated per unit in MWh for the month of June 2025 | 17 |
| Table 6: Pollutant tonnages for the month of June 2025..... | 21 |
| Table 7: Operating days in compliance with PM AEL limit of June 2025 | 21 |
| Table 8: Operating days in compliance with SOx AEL limit of June 2025 | 21 |
| Table 9: Operating days in compliance with NOx AEL limit of June 2025 | 22 |
| Table 10: Reference values for data provided, June 2025..... | 22 |
| Table 11: Monitor reliability percentage (%) | 22 |
| Table 12: Average percentage (%) availability of monitors for the month of June 2025..... | 23 |
| Table 13: Dates of last full conducted CEMS verification tests for PM for unit 6. | 25 |
| Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO ₂ and NOx for unit 1, 5 and 6) ... | 25 |
| Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only..... | 25 |
| Table 16: Start-up information | 26 |
| Table 17: Emergency generation | 27 |
| Table 18: Complaints..... | 27 |

Figures

| | |
|--|----|
| Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of June 2025..... | 7 |
| Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of June 2025..... | 8 |
| Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of June 2025..... | 9 |
| Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of June 2025..... | 9 |
| Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of June 2025..... | 10 |
| Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of June 2025 | 11 |
| Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of June 2025 | 11 |
| Figure 8: SO ₂ daily average emissions against emission limit for unit 4 for the month of June 2025 | 12 |
| Figure 9: SO ₂ daily average emissions against emission limit for unit 5 for the month of June 2025 | 12 |
| Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of June 2025 | 13 |
| Figure 11: NOx daily average emissions against emission limit for unit 1 for the month of June 2025 | 13 |
| Figure 12: NOx daily average emissions against emission limit for unit 2 for the month of June 2025 | 14 |
| Figure 13: NOx daily average emissions against emission limit for unit 4 for the month of June 2025 | 14 |
| Figure 14: NOx daily average emissions against emission limit for unit 5 for the month of June 2025 | 15 |
| Figure 15: NOx daily average emissions against emission limit for unit 6 for the month of June 2025 | 15 |
| Figure 16: Unit 1 daily generated power in MWh for the month of June 2025 | 18 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 17: Unit 2 daily generated power in MWh for the month of June 202518

Figure 18: Unit 4 daily generated power in MWh for the month of June 202519

Figure 19: Unit 5 daily generated power in MWh for the month of June 202519

Figure 20: Unit 6 daily generated power in MWh for the month of June 202520

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for June 2025. The information recorded in the report is obtained from Matimba Emission Reporting tool V10.2024.



During the period under review, Matimba experienced one hundred and eight (108) exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$), one hundred and three (103) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and five (5) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$). There were no exceedances of the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$).

Flue gas conditioning plant availability was below 90% for unit 1, unit 2, unit 4, unit 5 and unit 6. Unit 1 SO_3 plant's availability was 83%. Unit 2 SO_3 plant's availability was 23%. Unit 4 SO_3 plant's SO_3 availability was 38%. Unit 5 SO_3 plant's availability was 64% and unit 6 SO_3 plant's availability was 17%.

The consumption rates for fuel oil for the month of June 2025 exceeded the limit of 1200 tons by 1409.486 tons due to unit 6 light up and combustion support.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

| Raw Materials and Products used | Raw Material Type | Unit | Maximum Permitted Consumption Rate (Quantity) | Consumption Rate |
|---------------------------------|--------------------------|------------|--|------------------|
| | Coal | Tons/month | 1 500 000 | 652 439 |
| | Fuel Oil | Tons/month | 1 200 | 1409.486 |
| | | | | |
| Production Rates | Product/ By-Product Name | Unit | Maximum Production Capacity Permitted (Quantity) | Production Rate |
| | Energy | MW | 4000 | 1644.357 |
| | Ash | Tons/month | 547500 | 235 500.883 |

The consumption rates for fuel oil for the month of June 2025 exceeded the permitted maximum limits due to multiple units light up trips and combustion support.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

| Associated Unit | Technology Type | Minimum utilisation (%) | Efficiency (%) |
|-----------------|----------------------------|-------------------------|------------------------|
| Unit 1 | Electrostatic Precipitator | 100% | 99.992% |
| Unit 2 | Electrostatic Precipitator | 100% | 99.997% |
| Unit 3 | Electrostatic Precipitator | 100% | Off |
| Unit 4 | Electrostatic Precipitator | 100% | 99.998% |
| Unit 5 | Electrostatic Precipitator | 100% | 99.996% |
| Unit 6 | Electrostatic Precipitator | 100% | 99.998% |
| Associated Unit | Technology Type | Minimum utilisation (%) | Actual Utilisation (%) |
| Unit 1 | SO ₃ Plant | 100% | 83% |
| Unit 2 | SO ₃ Plant | 100% | 23% |
| Unit 3 | SO ₃ Plant | 100% | Off |
| Unit 4 | SO ₃ Plant | 100% | 38% |
| Unit 5 | SO ₃ Plant | 100% | 64% |
| Unit 6 | SO ₃ Plant | 100% | 17% |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 1, unit 2, unit 4, unit 5 and unit 6. All units SO₃ plants were on hold mode from the 8th to 25th of June 2025 due to no steam supply since unit 1, unit 3 and unit 5 were offload. Additionally unit 2 was on hold mode from the 26th of June 2025 due to Sulphur flow transmitters faulty. Unit 4 was on hold due to service air to valves isolated. Unit 6 was on hold due to average duct temperature low.

Table 3: Energy Source Material Characteristics.

| | Characteristic | Stipulated Range (Unit) | Monthly Average Content |
|-------------|-----------------|-------------------------|-------------------------|
| Coal burned | Sulphur Content | 1.6% | 1.498% |
| | Ash Content | 40% | 36.325% |

Energy source characteristics remained within the ranges stipulated in the license.

2.3 Emissions reporting

2.3.1 Particulate Matter Emissions

The emission monitors correlation and parallel tests were performed on unit 2,3 and 4 in June 2024 and the curves were applied on emissions calculations for June 2025. Unit 1,5 and 6 emission calculations were done using the correlation/parallel tests curves from the spot test performed in August 2023. Unit 2 PM correlation curve applied is linear curve, Unit 3 and 4 PM correlation curve applied is polynomial curve.

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of June 2025

Interpretation: Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 1,2 and 25 to 30 of June 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of June 2025

Interpretation: Unit 2 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 30 June 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 3 Particulate Emissions

Unit 3 is on outage

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of June 2025

Interpretation: Unit 4 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 26 June 2025. Exceedances from 1 to 26 June 2025 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 5 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of June 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Interpretation: Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 1 to 8 and 21 to 30 June 2025. Exceedances from 1 to 8 and 23 to 30 June 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 6 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of June 2025

Interpretation: Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 3 and 5 to 29 June 2025. The exceedances from 5 to 29 June 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in June 2025 as per the Eskom emission standard requirement.


The quality assurance tests (QAL2) used for June 2025 emission calculations were performed in June 2024 for Unit 2,3 and 4. Unit 1,5 and 6 quality assurance curves utilized are spot tests performed in August 2023

2.3.2.a SOx Emissions


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 SO₂ Emissions**Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of June 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³. SRM (Standard Reference Measurements) were used to calculate the SO₂ gaseous emissions for unit 1 in June 2025.

Unit 2 SO₂ Emissions**Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of June 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 3 SO₂ Emissions

Unit 3 is on outage


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ Emissions**Figure 8: SO₂ daily average emissions against emission limit for unit 4 for the month of June 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³. SRM (Standard Reference Measurements) were used to calculate the SO₂ gaseous emissions for unit 4 in June 2025.


Unit 5 SO₂ Emissions**Figure 9: SO₂ daily average emissions against emission limit for unit 5 for the month of June 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 SO₂ EmissionsFigure 10: SO₂ daily average emissions against emission limit for unit 6 for the month of June 2025

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


2.3.2.b NO_x EmissionsUnit 1 NO_x EmissionsFigure 11: NO_x daily average emissions against emission limit for unit 1 for the month of June 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³. SRM (Standard Reference Measurements) were used to calculate the SO₂ gaseous emissions for unit 1 in June 2025.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO_x Emissions**Figure 12: NO_x daily average emissions against emission limit for unit 2 for the month of June 2025**

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 3 NO_x Emissions

Unit 3 is on outage


Unit 4 NO_x Emissions**Figure 13: NO_x daily average emissions against emission limit for unit 4 for the month of June 2025**

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³. SRM (Standard Reference Measurements) were used to calculate the SO₂ gaseous emissions for unit 4 in June 2025.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO_x EmissionsFigure 14: NO_x daily average emissions against emission limit for unit 5 for the month of June 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 6 NO_x EmissionsFigure 15: NO_x daily average emissions against emission limit for unit 6 for the month of June 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

|  | | |
|--|--|-------------|
| CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS* | | |
| Date: | Wednesday, 23 July 2025 | |
| Station: | Matimba Power Station | |
| Province: | Limpopo Province | |
| Tank no. | 1-4 | |
| Description: | Outdoor fuel oil storage tank | |
| Tank Type: | Vertical fixed roof (vented to atmosphere) | |
| Material stored: | Fuel Oil 150 | |
| <p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p> | | |
| MONTH: | June | |
| GENERAL INFORMATION: | Data | Unit |
| Total number of fuel oil tanks: | 4 | NA |
| Height of tank: | 13.34 | m |
| Diameter of tank: | 9.53 | m |
| Net fuel oil throughput for the month: | 1409.486 | |
| Molecular weight of the fuel oil: | 166.00 | Lb/lb-mole |
| METEROLOGICAL DATA FOR THE MONTH | Data | Unit |
| Daily average ambient temperature | 16.61 | °C |
| Daily maximum ambient temperature | 25.19 | °C |
| Daily minimum ambient temperature | 9.38 | °C |
| Daily ambient temperature range | 15.81 | °C |
| Daily total insolation factor | 3.45 | kWh/m²/day |
| Tank paint colour | Grey/medium | NA |
| Tank paint solar absorbance | 0.68 | NA |
| FINAL OUTPUT: | Result | Unit |
| Breathing losses: | 0.54 kg/month | |
| Working losses: | 0.04 kg/month | |
| TOTAL LOSSES (Total TVOC Emissions for the month): | 0.58 kg/month | |
| <p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p> | | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.4 Daily power generated.

Table 5: Daily power generated per unit in MWh for the month of June 2025

| Date | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|------------|----------|---------|----------|---------|----------|----------|
| 2025/06/01 | 10905.1 | 8939.91 | Unit off | 11292.3 | 11973.2 | Unit off |
| 2025/06/02 | 8525.78 | 8924.3 | Unit off | 11246.1 | 13004.2 | 7659.8 |
| 2025/06/03 | Unit off | 8976.1 | Unit off | 10685.6 | 11493.3 | 8760.22 |
| 2025/06/04 | Unit off | 8932.38 | Unit off | 10357.9 | 12140.3 | 7464.43 |
| 2025/06/05 | Unit off | 9070.67 | Unit off | 11779.7 | 11866.2 | 10955 |
| 2025/06/06 | Unit off | 9087.83 | Unit off | 10710.8 | 10689.9 | 11144.8 |
| 2025/06/07 | Unit off | 9067.87 | Unit off | 10130.2 | 10063.7 | 10172.1 |
| 2025/06/08 | Unit off | 9137.94 | Unit off | 10131.5 | 5033.58 | 10695.5 |
| 2025/06/09 | Unit off | 9084.21 | Unit off | 10125.4 | Unit off | 10133.9 |
| 2025/06/10 | Unit off | 9104.12 | Unit off | 10808.6 | Unit off | 10120.2 |
| 2025/06/11 | Unit off | 9060.95 | Unit off | 10659.4 | Unit off | 10687.7 |
| 2025/06/12 | Unit off | 9169.86 | Unit off | 10685.6 | Unit off | 10660.2 |
| 2025/06/13 | Unit off | 9081.65 | Unit off | 10487.4 | Unit off | 10631.9 |
| 2025/06/14 | Unit off | 9090.85 | Unit off | 10687.9 | Unit off | 10525.9 |
| 2025/06/15 | Unit off | 9080.34 | Unit off | 10655.5 | Unit off | 10729.9 |
| 2025/06/16 | Unit off | 9091.19 | Unit off | 10112.8 | Unit off | 9720.48 |
| 2025/06/17 | Unit off | 9086.34 | Unit off | 10728.3 | Unit off | 10713.5 |
| 2025/06/18 | Unit off | 9085.98 | Unit off | 10538.7 | Unit off | 10584.5 |
| 2025/06/19 | Unit off | 9073.29 | Unit off | 10725.8 | Unit off | 10596.4 |
| 2025/06/20 | Unit off | 9031.93 | Unit off | 10251.7 | 3544.96 | 11617.7 |
| 2025/06/21 | Unit off | 9058.4 | Unit off | 11075.2 | 10987 | 11045 |
| 2025/06/22 | Unit off | 9071.38 | Unit off | 10903.3 | 10462.2 | 10523.2 |
| 2025/06/23 | Unit off | 8790.37 | Unit off | 11754.1 | 10437.6 | 11274.2 |
| 2025/06/24 | 8495.33 | 9020.6 | Unit off | 11792.6 | 10117.5 | 11420 |
| 2025/06/25 | 11160 | 9021.32 | Unit off | 10168.2 | 10893.2 | 11830.2 |
| 2025/06/26 | 11214.1 | 9006.99 | Unit off | 12043.1 | 10393.7 | 11305.6 |
| 2025/06/27 | 11863.7 | 8927.4 | Unit off | 12150.6 | 10265 | 11400.2 |
| 2025/06/28 | 11161.2 | 9058.74 | Unit off | 11603.2 | 10779.9 | 11379.6 |
| 2025/06/29 | 10097 | 9063.57 | Unit off | 10273.5 | 10586 | 10396.1 |
| 2025/06/30 | 9209.39 | 9073.65 | Unit off | 8013.05 | 10137.2 | 7917.24 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of June 2025




Figure 17: Unit 2 daily generated power in MWh for the month of June 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 4 daily generated power in MWh for the month of June 2025




Figure 19: Unit 5 daily generated power in MWh for the month of June 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 6 daily generated power in MWh for the month of June 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.5 Pollutant Tonnages

The emitted pollutant tonnages for June 2025 are provided in table 6.

Table 6: Pollutant tonnages for the month of June 2025

| Associated Unit/Stack | PM (tons) | SO ₂ (tons) | NO _x (tons) |
|-----------------------|----------------|------------------------|------------------------|
| Unit 1 | 139.2 | 1 460.7 | 295.4 |
| Unit 2 | 3 138.5 | 7 460.2 | 1 196.0 |
| Unit 3 | Off | Off | Off |
| Unit 4 | 1 011.4 | 6 028.6 | 1 046.5 |
| Unit 5 | 724.1 | 1 742.4 | 269.6 |
| Unit 6 | 129.2 | 3 089.6 | 538.9 |
| SUM | 5 142.6 | 19 781.4 | 3 346.3 |

2.6 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of June 2025

| Associated Unit/Stack | Normal | Grace | Section 30 | Contravention | Total Exceedance | Average PM (mg/Nm ³) |
|-----------------------|----------|----------|------------|---------------|------------------|----------------------------------|
| Unit 1 | 0 | 2 | 0 | 6 | 8 | 277.2 |
| Unit 2 | 0 | 0 | 0 | 30 | 30 | 1 228.2 |
| Unit 3 | Off | Off | Off | Off | Off | Off |
| Unit 4 | 4 | 0 | 0 | 26 | 26 | 506.5 |
| Unit 5 | 0 | 2 | 0 | 16 | 18 | 824.7 |
| Unit 6 | 1 | 1 | 0 | 25 | 26 | 130.9 |
| SUM | 5 | 5 | 0 | 103 | 108 | |

2.7 Operating days in compliance to SO_x AEL Limit

Table 8: Operating days in compliance with SO_x AEL limit of June 2025

| Associated Unit/Stack | Normal | Grace | Section 30 | Contravention | Total Exceedance | Average SO ₂ (mg/Nm ³) |
|-----------------------|------------|----------|------------|---------------|------------------|---|
| Unit 1 | 9 | 0 | 0 | 0 | 0 | 2 557.3 |
| Unit 2 | 30 | 0 | 0 | 0 | 0 | 2 906.1 |
| Unit 3 | Off | Off | Off | Off | Off | Off |
| Unit 4 | 30 | 0 | 0 | 0 | 0 | 3 021.1 |
| Unit 5 | 19 | 0 | 0 | 0 | 0 | 1 702.3 |
| Unit 6 | 29 | 0 | 0 | 0 | 0 | 2 898.2 |
| SUM | 117 | 0 | 0 | 0 | 0 | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Operating days in compliance to NOx AEL Limit

Table 9: Operating days in compliance with NOx AEL limit of June 2025

| Associated Unit/Stack | Normal | Grace | Section 30 | Contravention | Total Exceedance | Average NOx (mg/Nm³) |
|-----------------------|------------|----------|------------|---------------|------------------|----------------------|
| Unit 1 | 9 | 0 | 0 | 0 | 0 | 517.2 |
| Unit 2 | 30 | 0 | 0 | 0 | 0 | 465.7 |
| Unit 3 | Off | Off | Off | Off | Off | Off |
| Unit 4 | 30 | 0 | 0 | 0 | 0 | 524.4 |
| Unit 5 | 19 | 0 | 0 | 0 | 0 | 265.5 |
| Unit 6 | 29 | 0 | 0 | 0 | 0 | 503.6 |
| SUM | 117 | 0 | 0 | 0 | 0 | |

2.9 Reference values

Table 10: Reference values for data provided, June 2025

| Compound / Parameter | Units of Measure | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|----------------------|------------------|--------|--------|--------|--------|--------|--------|
| Oxygen | % | 9.39 | 7.44 | Off | 7.90 | 8.82 | 9.78 |
| Moisture | % | 3.64 | 5.64 | Off | 4.92 | 4.12 | 3.07 |
| Velocity | m/s | 27.3 | 32.4 | Off | 26.8 | 23.6 | 21.5 |
| Temperature | °C | 141.2 | 132.8 | Off | 146.1 | 122.7 | 235.5 |
| Pressure | mBar | 965.1 | 923.2 | Off | 927.6 | 901.7 | 914.3 |

2.10 Continuous Emission Monitors

2.10.1 Reliability

Table 11: Monitor reliability percentage (%)

| Associated Unit/Stack | PM | SO ₂ | NO |
|-----------------------|------|-----------------|-------|
| Unit 1 | 67.2 | 100.0 | 100.0 |
| Unit 2 | 10.1 | 100.0 | 99.3 |
| Unit 3 | Off | Off | Off |
| Unit 4 | 80.7 | 100.0 | 100.0 |
| Unit 5 | 21.5 | 100.0 | 87.4 |
| Unit 6 | 77.9 | 99.4 | 99.4 |

Note: NOx emissions are measured as NO in PPM. Final NOx value is expressed as total NO₂.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Continuous emission monitors were reliable for less than 80% of the reporting period for unit 1,2,5 and 6 PM. Unit 1 PM monitor reliability was low zero because the dust monitor was not calibrated, and the monitor kept maxing out of the monitor's range. Unit 2 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 6 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1,2 and 4 gaseous monitor reliability was above 80% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1,2 and 4.

Table 12: Average percentage (%) availability of monitors for the month of June 2025.

| Unit | SO ₂ | NO _x | PM | CO ₂ |
|------|-----------------|-----------------|------|-----------------|
| 1 | 100.0 | 100.0 | 67.2 | 100.0 |
| 2 | 100.0 | 99.3 | 10.1 | 100.0 |
| 3 | Off | Off | Off | Off |
| 4 | 100.0 | 100.0 | 80.7 | 0.0 |
| 5 | 100.0 | 87.4 | 21.5 | 100.0 |
| 6 | 99.4 | 99.4 | 77.9 | 99.3 |

Continuous emission monitors were available for less than 80% of the reporting period for unit 1,2,5 and 6 PM. Unit 1 PM monitor availability was low zero because the dust monitor was not calibrated, and the monitor kept maxing out of the monitor's range since. Unit 2 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 6 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1,2 and 4 gaseous monitor availability was above 80% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1,2 and 4.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 3

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 4

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 5

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 6

- No adjustments done on the CEMs.
- Correlation test to be done.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.3 Sampling dates and times**Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 6.

| | | | | |
|-------------------------------------|------------------|---|-----------------------------------|-----------------------------------|
| Name of service provider: | | Stacklabs Environmental Services CC | | |
| Address of service provider: | | 10 Chisel Street Boltonia Krugersdorp 1739 | | |
| Stack/ Unit | PM | SO₂ | NO_x | CO₂ |
| 6 | 2020/09/09 06h41 | New sampling tests in table 14 | New sampling tests in table 14 | New sampling tests in table 14 |

Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x for unit 1, 5 and 6)

| | | | | |
|-------------------------------------|----------------------------|--|-----------------------|-----------------------|
| Name of service provider: | | Levego Environmental services | | |
| Address of service provider: | | Building R6 Pineland site Ardeer Road Modderfontein 1645 | | |
| Stack/ Unit | PM | SO₂ | NO_x | CO₂ |
| 1 | 2023/08/01 19h33 | 2023/08/01 19:33 | 2023/08/01 19:33 | 2023/08/01 19:33 |
| 5 | 2023/08/05 07:30 | 2023/08/05 07:30 | 2023/08/05 07:30 | 2023/08/05 07:30 |
| 6 | Dates in table 13 above | 2023/08/05 15:52 | 2023/08/05 15:52 | 2023/08/05 15:52 |

Note: The CEMS Spot verification tests for PM, SO₂ and NO_x were performed in August 2023. PM spot verification test results for unit 6 failed and old curves are still in use.

Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

| | | | | |
|-------------------------------------|------------------|--|-----------------------|-----------------------|
| Name of service provider: | | Levego Environmental services | | |
| Address of service provider: | | Building R6 Pineland site Ardeer Road Modderfontein 1645 | | |
| Stack/ Unit | PM | SO₂ | NO_x | CO₂ |
| 2 | 2024/07/02 08h50 | 2024/07/02 12h35 | 2024/07/02 12h35 | 2024/07/02 12h35 |
| 3 | 2024/06/23 16h34 | 2024/06/23 14h00 | 2024/06/23 14h00 | 2024/06/23 14h00 |
| 4 | 2024/06/29 16h05 | 2024/06/29 11h00 | 2024/06/29 11h00 | 2024/06/29 11h00 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.11 Units Start-up information

Table 16: Start-up information

| | | |
|---|------------|-------|
| Unit | 1 | |
| Fires in | 2025/06/23 | 21h04 |
| Synchronization with Grid | 2025/06/24 | 03h01 |
| Emissions below limit | 2025/06/25 | 16h00 |
| Fires in, to synchronization | 5.57 | HOURS |
| Synchronization to < Emission limit | 36.59 | HOURS |

| | | |
|---|------------|-------------------------------------|
| Unit | 5 | |
| Fires in | 2025/06/20 | 03h22 |
| Synchronization with Grid | 2025/06/20 | 12h59 |
| Emissions below limit | N/A | The unit did not go below the limit |
| Fires in, to synchronization | 9.37 | HOURS |
| Synchronization to < Emission limit | N/A | HOURS |

| | | |
|---|------------|-------|
| Unit | 6 | |
| Fires in | 2025/06/02 | 00h07 |
| Synchronization with Grid | 2025/06/02 | 05h56 |
| Emissions below limit | 2025/06/03 | 08h00 |
| Fires in, to synchronization | 5.49 | HOURS |
| Synchronization to < Emission limit | 26.4 | HOURS |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

| | | |
|---|------------|-------|
| Unit | 6 | |
| Fires in | 2025/06/04 | 03h35 |
| Synchronization with Grid | 2025/06/04 | 06h55 |
| Emissions below limit | 2025/06/04 | 12h00 |
| Fires in, to synchronization | 3.20 | HOURS |
| Synchronization to < Emission limit | 5.5 | HOURS |

2.12 Emergency generation

Table 17: Emergency generation

| | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|---|--------|--------|----------|--------|--------|--------|
| Emergency Generation hours declared by national Control | 744 | 744 | 744 | 744 | 744 | 744 |
| Emergency Hours declared including hours after standing down | 215.05 | 720 | Unit off | 720 | 438.56 | 682.83 |
| Days over the Limit during Emergency Generation | 8 | 30 | Unit off | 26 | 18 | 26 |

During the period under review all Units were on emergency generation in force from 01 June 2025 until 30 June 2025.

2.13 Complaints register.

Table 18: Complaints

| Source Code/ Name | Root Cause Analysis | Calculation of Impacts/ emissions associated with the incident | Dispersion modelling of pollutants where applicable | Measures implemented to prevent reoccurrence | Date by which measure will be implemented |
|----------------------|------------------------|--|--|---|---|
| None | | | | | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.14 Air quality improvements and social responsibility conducted.

Air quality improvements

None

Social responsibility conducted.

None

2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The June 2025 ambient air quality monitoring report is attached to this report as an addendum.

2.16 Electrostatic precipitator and Sulphur plant status

Unit 1

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 2

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 3

- Unit on outage.

Unit 4

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 5

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 6

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

SO₃ common plant

- The SO₃ common plant is operating normally with no abnormalities observed.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.17 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

- Fugitive dustfall out monitoring report and Ambient air quality report.
- Marapong ambient air quality report

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

Wikus Janse van Rensburg

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.