



Ms Nompumelelo Simelane  
Nkangala District  
P O Box 437  
MIDDLEBERG

1050  
By email Simelaneni@nkangaladm.gov.za

Date  
28 July 2025

Enquiries S Chokoe

Tel +27 13 647 6970

Dear Ms Nompumelelo Simelane

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

**SUBMISSION OF KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF MAY 2025**

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by

Tsakani Holeni

**ENVIRONMENTAL SENIOR ADVISOR- KENDAL POWER STATION**

Date:

Supported by


Solly Chokoe

**ENVIRONMENTAL MANAGER- KENDAL POWER STATION**

Date: 28/07/2025

**KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF MAY 2025**

Verified by



Jacob Zwane

**BOILER ENGINEERING: SENIOR SYSTEM ENGINEER- KENDAL POWER STATION**

Date: 29/07/2025

Validated by




Tendani Rasivhetshele

**BOILER ENGINEERING MANAGER-KENDAL POWER STATION**

Date:

Supported by



Phindile Takane

**ENGINEERING MANAGER-KENDAL POWER STATION**

Date: 04-08-2025

Approved by



Tshepiso Temo

**GENERAL MANAGER-KENDAL POWER STATION**

Date: 00 25 / 08 / 08

# KENDAL POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/15



## 1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate May-2025
	Coal	Tons	2 260 000	609 607
	Fuel Oil	Tons	5 000	9843.350
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate May-2025
	Energy	GWh	3 062.304	1 368.541
	Ash	Tons	770 000	260 693.454
	RE Ash	kg/MWh	not specified	19.391

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [4 116 MW] x 24 hrs x days in Month/1000 to convert to GWh

## 2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24 (MJ/kg)	18.580
Sulphur Content	%	<1 (%)	0.760
Ash Content	%	40 (%)	32.200

## 3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>x</sub>
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

#### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency May-2025	Technology Type	SO <sub>2</sub> Utilization May-2025
Unit 1	ESP + SO <sub>2</sub>	84.477%	SO <sub>2</sub>	93.5%
Unit 2	ESP + SO <sub>2</sub>	78.341%	SO <sub>2</sub>	93.5%
Unit 3	ESP + SO <sub>2</sub>	89.901%	SO <sub>2</sub>	90.3%
Unit 4	ESP + SO <sub>2</sub>	97.008%	SO <sub>2</sub>	38.7%
Unit 5	ESP + SO <sub>2</sub>	98.783%	SO <sub>2</sub>	48.4%
Unit 6	ESP + SO <sub>2</sub>	83.589%	SO <sub>2</sub>	67.7%

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised

There is no Sulphur value for SO<sub>3</sub> utilization due to switch failure on the server, however DCS signals used for its tripping alarms were used to get its utilization values. Sulphur flow will be available once we have commissioned the new PI system.

#### 5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>x</sub>	NO	O <sub>2</sub>
Unit 1	29.9	100.0	100.0	96.8
Unit 2	0.0	100.0	100.0	100.0
Unit 3	28.7	100.0	100.0	100.0
Unit 4	97.5	100.0	99.7	31.9
Unit 5	99.7	100.0	99.4	100.0
Unit 6	4.6	100.0	100.0	100.0

Note: NO<sub>x</sub> emissions is measured as NO in PPM. Final NO<sub>x</sub> value is expressed as total NO<sub>2</sub>

#### 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of May 2025

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	6 328.1	2 776	1 040
Unit 2	10 043.8	3 160	1 305
Unit 3	3 980.3	2 525	572
Unit 4	709.0	1 753	614
Unit 5	327.8	1 572	631
Unit 6	5 147.9	2 665	1 088
SUM	26 536.89	14 451	5 249

Table 6.2: Operating days in compliance to PM AEL Limit - May 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contraven- tion	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	0	1	0	30	31	3 789.7
Unit 2	0	3	0	26	29	6 121.6
Unit 3	0	3	0	22	25	3 052.8
Unit 4	0	5	0	15	20	791.2
Unit 5	0	4	0	14	18	455.4
Unit 6	0	2	0	21	23	4 625.8
SUM	0	18	0	128	146	

Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - May 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contraven- tion	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
Unit 1	31	0	0	0	0	1 761.0
Unit 2	30	0	0	0	0	1 769.2
Unit 3	29	0	0	0	0	1 741.6
Unit 4	23	0	0	0	0	1 883.1
Unit 5	23	0	0	0	0	1 519.5
Unit 6	24	0	0	0	0	2 009.6
SUM	160	0	0	0	0	



Table 6.4: Operating days in compliance to NOx AEL Limit - May 2025


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
Unit 1	31	0	0	0	0	604.8
Unit 2	30	0	0	0	0	716.7
Unit 3	29	0	0	0	0	383.5
Unit 4	23	0	0	0	0	637.7
Unit 5	23	0	0	0	0	563.3
Unit 6	24	0	0	0	0	779.2
SUM	160	0	0	0	0	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>


Table 6.5: Legend Description

Condition	Colour	Description
Normal	GREEN	Emissions below Emission Limit Value (ELV)
Grace	BLUE	Emissions above the ELV during grace period
Section 30	ORANGE	Emissions above ELV during a NEMA S30 incident
Contravention	RED	Emissions above ELV but outside grace or S30 incident conditions







High emissions can be attributed to the SO3 plant that was off due to burner vessel leak and due to the CE Rapper 1-3 on both Left Hand and Right Hand that tripped due to high Hopper levels.






High PM emissions can be attributed to the DHP that was standing with all Knife gates closed and there was no stream available.



High PM emissions can be attributed to the CE rapping program malfunctioning and ash backlogs.



High PM emissions can be attributed to DHP running with all Knife-gates 1-5 shut and due to most jacks that were tripping on undervoltage (short circuit condition).













Figure 14: Kendal Unit 2 NOx Emissions - May 2025




Figure 15: Kendal Unit 3 NOx Emissions - May 2025




Figure 16: Kendal Unit 4 NOx Emissions - May 2025




Figure 17: Kendal Unit 5 NOx Emissions - May 2025





Figure 18: Kendal Unit 6 NOx Emissions - May 2025



7 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

## ADDENDUM TO MONTHLY EMISSIONS REPORT

### Abatement Technology Table 4

In order to achieve the required operational dust removal efficiency based on measured values several assumptions such as

- ☐ Coal ash content (%) and burnt rate mass
- ☐ Fly Coarse ash ratio of 80/20 80% of fly ash mass obtained from burnt coal goes to ESP
- ☐ Measurement of dust emission by Dust Monitor over a period of time (monthly)

#### Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission from AQR Report (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)}$$

### Monitor Reliability Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average

The **monitor reliability** refers to **data reliability** because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours.

The formula is as follows:

$$= (1 - (\text{count hours above 99.325\%}/24\text{hours})) \times 100$$

#### Emissions Performance

- Average velocity values from the latest correlation report were used on the gaseous emissions on Units due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 1, 2, 3, 5 and 6 maxed out, meaning the emissions were higher than what the monitor was correlated for, in which case we use surrogate values. This is attributed to abnormal plant conditions
- Please note that the reported figures in tonnage calculation are the figures after the station used the maxing out quantification exercise which is the use of "surrogate values" on days when the monitor maxed out
- Flow was not working for the whole month because of sensors that are faulty and the sensors have to be replaced on all the units. The process for procuring new sensors is in progress
- Correlation curves for units 1, 4 and 5 were changed to suite changes of the data signals from "AAA" to "HME" data values because of the damaged cables for "AAA" signal giving values that were not reliable
- Surrogation values were recalculated after updating raw data based on curves update
- The QAL 2 average values for gaseous were used as raw data in cases where the monitor had an error, were used as surrogation values
- The O2 sensors are faulty as they all need to be replaced. Unit 5 and 4 O2 sensors were replaced in July 2025 and the process of replacing the other sensors is in progress
- The PM monitors were not 100% reliable due ash backlog dust flooded the dust motors
- Unit 1
  - Findings: The high emissions can be attributed to the DHP that was standing due to PLC and also due to the CE rapper 1.5 that had tripped LH (Left hand) 1.4 on the RH (Right hand) PC13/21 OC
  - Resolution: Plant repaired
- Unit 2
  - Findings: The high emissions can be attributed to the Dust Handling Plant that was running with high ash backlogs and Field 17 and 26 that was O/C due to electrical issue
  - Resolution: Plant repaired
- Unit 3
  - Findings: The high PM emissions can be attributed to the SO3 plant that was off due to burner vessel leak and due to the CE Rapper 1.3 on both Left Hand and Right Hand that tripped due to high Hopper levels
  - Resolution: Plant repaired
- Unit 4
  - Findings: The high PM emissions can be attributed to the SO3 plant that was off due to the DHP that was standing with all Knife gates closed and there was no stream available
  - Resolution: Plant repaired
- Unit 5
  - Findings: High PM emissions can be attributed to the CE rapping program malfunctioning and ash backlogs
  - Resolution: Plant repaired
- Unit 6
  - Findings: High PM emissions can be attributed to the DHP that was running with all knife-gates 1.5 shut and due to most fields that were tripping on undervoltage (short circuit condition)
  - Resolution: Plant repaired