

Ian Gildenhuys
Air Quality Management
246 Voortrekker Road
Vasco
7460

Date:
2 September 2025

Enquiries: Hilton Westman
+27 9415856

Ref: ACP/2025/08

Dear Mr Gildenhuys

ACACIA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2025

This serves as the monthly report required in terms of Section 6.4.1 of Acacia Power Station's Atmospheric Emission License **WCCT023**. The information is applicable for the month of August 2025.

1.Raw Materials and Products (Section 7.)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type: Diesel		
Total Fuel Consumption	5.438	Tons
Electricity Produced	2	MWh
Average Fuel Consumption	2.719	Tons / MWh
Maximum fuel consumption rate	5035	Kg per hour

2.Operating times of units (Section 6.4.1)

a. Total Hours

Unit	Hours operated	Total Fuel Consumption	Energy Production
Number	Hours and minutes	Litres	MWh
Unit One	0hr 23minutes	6588	0
Unit Two	0hr 21minutes		1
Unit Three	0hr 21minutes		1

b. Detailed Operating Times

See Annexure1.

3.Complaints Register (Section 8.6.1)

No complaints were recorded for August 2025.

4.General

KAS (Koeberg Auto Start) Testing was conducted on all 3 Units.

The monthly Ambient Air Quality Report compiled by Argos Scientific for air quality monitoring at the Acacia AQM station, will be sent to your office as soon as it is received.

We trust that the above information complies with your requirements.

Yours sincerely



Zukile Tshisa
O&M Manager
ACACIA POWER STATION

Acacia Power Station 08_2025
Hilton Westman
2.9.2025

Annexure 1. Acacia Hours of Operation

Date	Unit One			Unit two			Unit 3		
	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15	10:11:00	10:34:00	00:23:00	10:11:00	10:32:00	00:21:00	10:11:00	10:32:00	00:21:00
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
25									
26									
27									
28									
29									
30									
31									

Load Factor

0.0%

Acacia Power Station 08_2025
Hilton Westman
2.9.2025