	<b>Technical and Generic Report</b>	<b>Matimba Power Station</b>
---	-------------------------------------	------------------------------

Title: **Matimba Power Station July 2025 emissions report**

Document Identifier: **RP/247/063**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **27**

Report Date: **July 2025**

Disclosure Classification: **Controlled**

**Compiled by**

pp 

**Helry Ramahlare**  
**Senior Advisor**  
**Environment**

Date: 2025-08-29

**Reviewed by**

p.p.  MF

**MC Mamabolo**  
**Environmental**  
**Manager**

Date: 2025/08/29


**Supported by**

 Wikus Janse van Rensburg

**Jacky Mathobela**  
**Engineering Manager**

Date: 2025/08/29

**Authorized by**



**Obakeng Mabotja**  
**General Manager**

Date: 2025-08-29

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products .....	5
2.2 Abatement technology .....	5
2.3 Emissions reporting .....	6
2.3.1 Particulate Matter Emissions .....	6
2.3.2 Gaseous Emissions .....	9
2.3.2.a SOx Emissions .....	9
2.3.2.b NOx Emissions .....	11
2.3.3 Total Volatile Organic Compounds .....	14
2.3.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	15
2.4 Daily power generated .....	15
2.5 Pollutant Tonnages .....	19
2.6 Operating days in compliance to PM AEL Limit .....	19
2.7 Operating days in compliance to SOx AEL Limit .....	19
2.8 Operating days in compliance to NOx AEL Limit .....	20
2.9 Continuous Emission Monitors .....	20
2.10.1 Changes, downtime, and repairs .....	21
2.10.2 Sampling dates and times .....	22
2.10 Units Start-up information .....	23
2.11 Emergency generation .....	24
2.12 Complaints register .....	25
2.13 Air quality improvements and social responsibility conducted .....	25
Air quality improvements .....	25
Social responsibility conducted .....	25
2.14 Ambient air quality monitoring .....	25
2.15 Electrostatic precipitator and Sulphur plant status .....	25
2.16 General .....	26
3. Attachments .....	26
4. Report Conclusion .....	26
Table 1: Quantity of Raw Materials and Products used/produced for the month .....	5
Table 2: Abatement Equipment Control Technology Utilised .....	5
Table 3: Energy Source Material Characteristics .....	6
Table 4: Total volatile compound estimates .....	14
Table 5: Daily power generated per unit in MWh for the month of July 2025 .....	15
Table 6: Pollutant tonnages for the month of July 2025 .....	19

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 7: Operating days in compliance with PM AEL limit of July 2025 .....	19
Table 8: Operating days in compliance with SOx AEL limit of July 2025 .....	19
Table 9: Operating days in compliance with NOx AEL limit of July 2025 .....	20
Table 10: Monitor reliability percentage (%) .....	20
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 6. ....	22
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO <sub>2</sub> and NOx for unit 1, 5 and 6) ...	22
Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only .....	22
Table 16: Start-up information .....	23
Table 17: Emergency generation .....	24
Table 18: Complaints .....	25

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of July 2025 .....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of July 2025 .....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of July 2025 .....	7
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of July 2025 .....	8
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of July 2025 .....	8
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of July 2025 .....	9
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of July 2025 .....	9
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of July 2025 .....	10
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of July 2025 .....	10
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of July 2025 .....	11
Figure 11: NOx daily average emissions against emission limit for unit 1 for the month of July 2025 .....	11
Figure 12: NOx daily average emissions against emission limit for unit 2 for the month of July 2025 .....	12
Figure 13: NOx daily average emissions against emission limit for unit 4 for the month of July 2025 .....	12
Figure 14: NOx daily average emissions against emission limit for unit 5 for the month of July 2025 .....	13
Figure 15: NOx daily average emissions against emission limit for unit 6 for the month of July 2025 .....	13
Figure 16: Unit 1 daily generated power in MWh for the month of July 2025 .....	16
Figure 17: Unit 2 daily generated power in MWh for the month of July 2025 .....	16
Figure 18: Unit 4 daily generated power in MWh for the month of July 2025 .....	17
Figure 19: Unit 5 daily generated power in MWh for the month of July 2025 .....	17
Figure 20: Unit 6 daily generated power in MWh for the month of July 2025 .....	18

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for July 2025. The information recorded in the report is obtained from Matimba Emission Reporting tool MTB0725ERT.



During the period under review, Matimba experienced one hundred and twenty two (122) exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ), one hundred and ten (110) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and twelve (12) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ). There were no exceedances of the daily  $\text{NO}_x$  emission limit ( $750\text{mg}/\text{Nm}^3$ ).

Flue gas conditioning plant availability was below 90% for unit 2, unit 4 and unit 6. Unit 1  $\text{SO}_3$  plant's availability was 95%. Unit 2  $\text{SO}_3$  plant's availability was 70%. Unit 4  $\text{SO}_3$  plant's availability was 70%. Unit 5  $\text{SO}_3$  plant's availability was 91% and unit 6  $\text{SO}_3$  plant's availability was 84%.

The consumption rates for fuel oil for the month of July 2025 exceeded the limit of 1200 tons by 2804.1280 tons due to unit 3 cold start up attempts and combustion support.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1: Quantity of Raw Materials and Products used/produced for the month.**

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	903672
	Fuel Oil	Tons/month	1 200	2804.128
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2101.073
	Ash	Tons/month	547500	329398.877

The consumption rates for fuel oil for the month of July 2025 exceeded the permitted maximum limits due to unit 3 cold start up attempts and combustion support.

### 2.2 Abatement technology

**Table 2: Abatement Equipment Control Technology Utilised**

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	97.507%
Unit 2	Electrostatic Precipitator	100%	96.233%
Unit 3	Electrostatic Precipitator	100%	Off-line
Unit 4	Electrostatic Precipitator	100%	88.179%
Unit 5	Electrostatic Precipitator	100%	98.845%
Unit 6	Electrostatic Precipitator	100%	99.896%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	95%
Unit 2	SO <sub>3</sub> Plant	100%	70%
Unit 3	SO <sub>3</sub> Plant	100%	Off
Unit 4	SO <sub>3</sub> Plant	100%	70%
Unit 5	SO <sub>3</sub> Plant	100%	91%
Unit 6	SO <sub>3</sub> Plant	100%	84%

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 2, unit 4 and unit 6. Unit 2 SO<sub>3</sub> plant was on hold due to Sulphur flow transmitter isolator faulty. Unit 4 SO<sub>3</sub> Plant was on hold due to left hand Precipits inlet temperature low and right-hand bias blower motor faulty. Unit 6 SO<sub>3</sub> plant was on permit to repair sulphur flow control valve.

**Table 3: Energy Source Material Characteristics.**

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.318%
	Ash Content	40%	36.451%


Energy source characteristics remained within the ranges stipulated in the license.

## 2.3 Emissions reporting

### 2.3.1 Particulate Matter Emissions

The emission monitors correlation and parallel tests were performed on unit 2,3 and 4 in June 2024 and the curves were applied on emissions calculations for June 2025. Unit 1,5 and 6 emission calculations were done using the correlation/parallel tests curves from the spot test performed in August 2023. Unit 2 PM correlation curve applied is linear curve, Unit 3 and 4 PM correlation curve applied is polynomial curve.

#### Unit 1 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of July 2025**


**Interpretation:** Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1<sup>st</sup> to 31<sup>st</sup> of July 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions




**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of July 2025**

**Interpretation:** Unit 2 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1<sup>st</sup> to 29<sup>th</sup> and 31<sup>st</sup> of July 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## Unit 3 Particulate Emissions

Unit 3 is on outage

## Unit 4 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of July 2025**


**Interpretation:** Unit 4 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 3<sup>rd</sup> to 7<sup>th</sup> and 14<sup>th</sup> to 31<sup>st</sup> of July 2025. Exceedances from 5<sup>th</sup> to 8<sup>th</sup> and 16<sup>th</sup> to 31<sup>st</sup> of July 2025 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


## Unit 5 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of July 2025**

**Interpretation:** Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1<sup>st</sup> to 14<sup>th</sup> and 17<sup>th</sup> to 31<sup>st</sup> of July 2025. Exceedances from 1<sup>st</sup> to 14<sup>th</sup> and 19<sup>th</sup> to 31<sup>st</sup> of July 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## Unit 6 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of July 2025**

**Interpretation:** Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 5<sup>th</sup>, 7<sup>th</sup>, 25<sup>th</sup>, 26<sup>th</sup>, and 28<sup>th</sup> to 31<sup>st</sup> of July 2025. The exceedances from 30<sup>th</sup> and 31<sup>st</sup> of July 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### 2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in July 2025 as per the Eskom emission standard requirement.

The quality assurance tests (QAL2) used for July 2025 emission calculations were performed in June 2024 for Unit 2,3 and 4. Unit 1,5 and 6 quality assurance curves utilized are spot tests performed in August 2023

#### 2.3.2.a SO<sub>x</sub> Emissions

##### Unit 1 SO<sub>2</sub> Emissions




Figure 6: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of July 2025

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

##### Unit 2 SO<sub>2</sub> Emissions




Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of July 2025

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. SRM (Standard Reference Measurements) were used to calculate the SO<sub>2</sub> gaseous emissions for unit 1 in July 2025.


#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


**Unit 3 SO<sub>2</sub> Emissions**

Unit 3 is on outage

**Unit 4 SO<sub>2</sub> Emissions**

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of July 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. SRM (Standard Reference Measurements) were used to calculate the SO<sub>2</sub> gaseous emissions for unit 4 in July 2025.

**Unit 5 SO<sub>2</sub> Emissions**


**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of July 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 6 SO<sub>2</sub> Emissions****Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of July 2025**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.


**2.3.2.b NO<sub>x</sub> Emissions****Unit 1 NO<sub>x</sub> Emissions****Figure 11: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of July 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 2 NO<sub>x</sub> Emissions****Figure 12: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of July 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**Unit 3 NO<sub>x</sub> Emissions**

Unit 3 is on outage


**Unit 4 NO<sub>x</sub> Emissions****Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of July 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>. SRM (Standard Reference Measurements) were used to calculate the SO<sub>2</sub> gaseous emissions for unit 4 in July 2025.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 5 NO<sub>x</sub> Emissions****Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of July 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**Unit 6 NO<sub>x</sub> Emissions****Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of July 2025**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.3.3 Total Volatile Organic Compounds

**Table 4:** Total volatile compound estimates

		
<b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>		
<b>Date:</b>	Monday, 25 August 2025	
<b>Station:</b>	Matimba Power Station	
<b>Province:</b>	Limpopo Province	
<b>Tank no.</b>	1-4	
<b>Description:</b>	Outdoor fuel oil storage tank	
<b>Tank Type:</b>	Vertical fixed roof (vented to atmosphere)	
<b>Material stored:</b>	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
<b>MONTH:</b>	<b>July</b>	
<b>GENERAL INFORMATION:</b>	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	<b>2804.128</b>	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	17.66	°C
Daily maximum ambient temperature	25.87	°C
Daily minimum ambient temperature	10.47	°C
Daily ambient temperature range	15.40	°C
Daily total insolation factor	3.47	kWh/m²/day
Tank paint colour	<b>Grey/medium</b>	NA
Tank paint solar absorbance	0.68	NA
<b>FINAL OUTPUT:</b>	<b>Result</b>	<b>Unit</b>
Breathing losses:	<b>0.53 kg/month</b>	
Working losses:	<b>0.08 kg/month</b>	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0.61 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.3.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.4 Daily power generated.



**Table 5:** Daily power generated per unit in MWh for the month of July 2025

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2025/07/01	9213.47	9047.59	Unit off	8004.78	10157.5	7628.29
2025/07/02	9569.37	9017.64	Unit off	9349.76	10573.9	5767.84
2025/07/03	9606.67	9079.41	Unit off	11244.9	10137.9	9509.84
2025/07/04	9324.81	9033.49	Unit off	11342.4	9988.47	9566.16
2025/07/05	9380.6	9020.34	Unit off	11046	5721.64	9640.31
2025/07/06	8957.25	8990.67	Unit off	10611.4	8180.32	8992.75
2025/07/07	9177.19	9010.6	Unit off	10515.5	8783.58	10062.3
2025/07/08	9707.99	8997.98	Unit off	10612.6	9544.24	9812.14
2025/07/09	9726.39	8986.92	Unit off	11558.9	9769.05	11037.8
2025/07/10	9690.11	8994.99	Unit off	11648.4	9756.1	10848.5
2025/07/11	9684.64	9775.19	Unit off	9664.1	9864.52	9901.05
2025/07/12	9969.87	10672.7	Unit off	8095.3	10233.4	10350.9
2025/07/13	10287.7	10148.1	Unit off	8425.53	10546.8	10358.4
2025/07/14	10534	10505.1	Unit off	8675.73	6168.32	10739.7
2025/07/15	10616.3	11274.7	Unit off	8680	Unit off	10522.1
2025/07/16	10604.1	11085.3	Unit off	8699.61	9802.41	10328.4
2025/07/17	10324.9	10424.6	Unit off	8707.54	10771.6	9607.21
2025/07/18	10306.3	10432.8	Unit off	8468.73	11153.8	9008
2025/07/19	10273.5	10362.3	Unit off	8733.65	10935.8	10638.8
2025/07/20	9806.82	10390.9	Unit off	8262.01	11684.9	9114.18
2025/07/21	10271.4	10469.5	Unit off	8767.08	12870.7	10555.5
2025/07/22	10417.4	10017.3	Unit off	8837.42	12853.1	5885.6
2025/07/23	10354.5	9981.23	Unit off	8844.89	12865	10858.7
2025/07/24	10320	10550	Unit off	8760.73	12838.5	10581.9
2025/07/25	10442.5	10952.3	Unit off	8959.88	12800	10732
2025/07/26	10147.4	10074	Unit off	9613.2	12860.6	9311.19
2025/07/27	10159.8	10203.3	Unit off	10379	12771.6	9808.76
2025/07/28	10441.6	10418.3	Unit off	10249.7	12712.6	10831.9
2025/07/29	10307.9	4428.94	Unit off	10025.6	11702.4	10179.7
2025/07/30	10183.5	7377.26	Unit off	9224.52	13078	10174
2025/07/31	10223.1	10333.3	Unit off	9561.33	12158.7	10135.9

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.



No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Figure 16: Unit 1 daily generated power in MWh for the month of July 2025****Figure 17: Unit 2 daily generated power in MWh for the month of July 2025****CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 18: Unit 4 daily generated power in MWh for the month of July 2025****Figure 19: Unit 5 daily generated power in MWh for the month of July 2025****CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 20: Unit 6 daily generated power in MWh for the month of July 2025**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.5 Pollutant Tonnages

The emitted pollutant tonnages for July 2025 are provided in table 6.

**Table 6:** Pollutant tonnages for the month of July 2025

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	1 443.4	3 746	612
Unit 2	2 127.8	7 128	1 190
Unit 3	Off	Off	Off
Unit 4	6 774.1	8 468	1 470
Unit 5	702.9	2 305	457
Unit 6	60.1	3 020	665
<b>SUM</b>	<b>11 108.15</b>	<b>24 666</b>	<b>4 393</b>

## 2.6 Operating days in compliance to PM AEL Limit

**Table 7:** Operating days in compliance with PM AEL limit of July 2025

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm <sup>3</sup> )
Unit 1	0	0	0	31	31	857.6
Unit 2	0	0	0	30	30	995.9
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	7	4	0	20	24	2 458.2
Unit 5	0	2	0	27	29	503.9
Unit 6	22	6	0	2	8	44.7
<b>SUM</b>	<b>29</b>	<b>12</b>	<b>0</b>	<b>110</b>	<b>122</b>	

## 2.7 Operating days in compliance to SO<sub>x</sub> AEL Limit

**Table 8:** Operating days in compliance with SO<sub>x</sub> AEL limit of July 2025

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Limit Value	Mnth Avg (mg/Nm <sup>3</sup> )
Unit 1	31	0	0	0	0	3500	2 305.3
Unit 2	31	0	0	0	0	3500	3 214.1
Unit 3	Off	Off	Off	Off	Off	3500	Off
Unit 4	31	0	0	0	0	3500	3 072.7
Unit 5	30	0	0	0	0	3500	1 543.6
Unit 6	31	0	0	0	0	3500	2 134.1
<b>SUM</b>	<b>154</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.8 Operating days in compliance to NOx AEL Limit

**Table 9: Operating days in compliance with NOx AEL limit of July 2025**

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm <sup>3</sup> )
Unit 1	31	0	0	0	0	376.6
Unit 2	31	0	0	0	0	536.4
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	31	0	0	0	0	533.4
Unit 5	30	0	0	0	0	303.1
Unit 6	31	0	0	0	0	468.4
<b>SUM</b>	<b>154</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

## 2.9 Continuous Emission Monitors

**Table 10: Monitor reliability percentage (%)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	45.8	100.0	81.6	100.0
Unit 2	33.3	100.0	100.0	100.0
Unit 3	Off	Off	Off	Off
Unit 4	54.3	100.0	100.0	100.0
Unit 5	67.0	79.4	58.9	76.9
Unit 6	98.2	99.7	99.7	91.0

Note: NOx emissions are measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>.

Continuous emission monitors were reliable for less than 80% of the reporting period for unit 1, 2, 4 and 5 PM. Unit 1 PM monitor reliability was low zero because the dust monitor was not calibrated, and the monitor kept maxing out of the monitor's range. Unit 2 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 4 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 2 and 4 gaseous monitor reliability was 100% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 2 and 4.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### **2.10.1 Changes, downtime, and repairs**

#### **Unit 1**

- No adjustments done on the CEMs.
- Correlation test to be done.

#### **Unit 2**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### **Unit 3**

- No adjustments done on the CEMs.
- Correlation test to be done.

#### **Unit 4**

- No adjustments done on the CEMs.
- Correlation test to be done.

#### **Unit 5**

- No adjustments done on the CEMs.
- Correlation test to be done.

#### **Unit 6**

- No adjustments done on the CEMs.
- Correlation test to be done.

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**2.10.2 Sampling dates and times****Table 11:** Dates of last full conducted CEMS verification tests for PM for unit 6.

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
6	2020/09/09 06h41	New sampling tests in table 14	New sampling tests in table 14	New sampling tests in table 14

**Table 12:** Dates of last conducted CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> for unit 1, 5 and 6)

<b>Name of service provider:</b>		Levego Environmental services		
<b>Address of service provider:</b>		Building R6 Pineland site Ardeer Road Modderfontein 1645		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 13 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

Note: The CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> were performed in August 2023. PM spot verification test results for unit 6 failed and old curves are still in use.

**Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

<b>Name of service provider:</b>		Levego Environmental services		
<b>Address of service provider:</b>		Building R6 Pineland site Ardeer Road Modderfontein 1645		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
2	2024/07/02 08h50	2024/07/02 12h35	2024/07/02 12h35	2024/07/02 12h35
3	2024/06/23 16h34	2024/06/23 14h00	2024/06/23 14h00	2024/06/23 14h00
4	2024/06/29 16h05	2024/06/29 11h00	2024/06/29 11h00	2024/06/29 11h00

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.10 Units Start-up information

**Table 14:** Start-up information

<b>Unit</b>	2	
<b>Fires in</b>	2025/07/30	01h16
<b>Synchronization with Grid</b>	2025/07/30	06h22
<b>Emissions below limit</b>	2025/07/29	The unit did not go below the limit
<b>Fires in, to synchronization</b>	5.6	HOURS
<b>Synchronization to &lt; Emission limit</b>	N/A	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	2025/07/05	20h31
<b>Synchronization with Grid</b>	2025/07/05	22h51
<b>Emissions below limit</b>	2025/07/14	14h26
<b>Fires in, to synchronization</b>	2.20	HOURS
<b>Synchronization to &lt; Emission limit</b>	207.35	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	2025/07/15	23h22
<b>Synchronization with Grid</b>	2025/07/16	03h44
<b>Emissions below limit</b>	2025/07/17	11h00
<b>Fires in, to synchronization</b>	4.22	HOURS
<b>Synchronization to &lt; Emission limit</b>	31.16	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	6	
<b>Fires in</b>	2025/07/02	01h31
<b>Synchronization with Grid</b>	2025/07/02	04h35
<b>Emissions below limit</b>	2025/07/02	10h43
<b>Fires in, to synchronization</b>	3.4	HOURS
<b>Synchronization to &lt; Emission limit</b>	6.8	HOURS

<b>Unit</b>	6	
<b>Fires in</b>	2025/07/22	11h56
<b>Synchronization with Grid</b>	2025/07/22	19h09
<b>Emissions below limit</b>	2025/07/22	20h22
<b>Fires in, to synchronization</b>	7.13	HOURS
<b>Synchronization to &lt; Emission limit</b>	1.13	HOURS

## 2.11 Emergency generation

**Table 15:** Emergency generation

	<b>Unit 1</b>	<b>Unit 2</b>	<b>Unit 3</b>	<b>Unit 4</b>	<b>Unit 5</b>	<b>Unit 6</b>
<b>Emergency Generation hours declared by national Control</b>	744	744	744	744	744	744
<b>Emergency Hours declared including hours after standing down</b>	744.00	727.75	Off	744.00	702.70	731.89
<b>Days over the Limit during Emergency Generation</b>	31	30	Off	24	29	8

During the period under review all Units were on emergency generation in force from 01 July 2025 until 31 July 2025.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.12 Complaints register.

**Table 16:** Complaints

Source Name	Code/	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None						

## 2.13 Air quality improvements and social responsibility conducted.

### Air quality improvements

None

### Social responsibility conducted.

None

## 2.14 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The July 2025 ambient air quality monitoring report is attached to this report as an addendum.

## 2.15 Electrostatic precipitator and Sulphur plant status

### Unit 1

- High hopper levels cause a decline in precipitator performance.
- The SO<sub>3</sub> plant is operating normally with no abnormalities observed.

### Unit 2

- High hopper levels cause a decline in precipitator performance.
- The SO<sub>3</sub> plant is operating normally with no abnormalities observed.

### Unit 3

- Unit on outage.

### Unit 4

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- High hopper levels cause a decline in precipitator performance.
- The SO<sub>3</sub> plant is operating normally with no abnormalities observed.

**Unit 5**

- High hopper levels cause a decline in precipitator performance.
- The SO<sub>3</sub> plant is operating normally with no abnormalities observed.

**Unit 6**

- High hopper levels cause a decline in precipitator performance.
- The SO<sub>3</sub> plant is operating normally with no abnormalities observed.

**SO<sub>3</sub> common plant**

- The SO<sub>3</sub> common plant is operating normally with no abnormalities observed.

**2.16 General****Name and reference number of the monitoring methods used:**

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

**Sampling locations:**

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

**3. Attachments**

- Fugitive dustfall out monitoring report and Ambient air quality report.
- Marapong ambient air quality report

**4. Report Conclusion**

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

I hereby declare that the information in this report is correct.

Yours sincerely

*Wikus Janse van Rensburg*

GENERAL MANAGER: MATIMBA POWER STATION

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.