

Ms Tebogo Mogakabe  
 Manager: Municipal Environmental Services  
 Gert Sibande District Municipality  
 PO BOX 1748  
 ERMELO  
 2350

Date:  
 17 September 2025

Enquiries: Johan Swanepoel  
 Tel +27 17 799 2047

## MAJUBA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF AUGUST 2025

This serves as the monthly report required in terms of Majuba Power Station's Atmospheric Emission License (MPS/0014/2025/F05) under section 7.6 routine reporting and record keeping. The emissions are for the month of August 2025. Verified emissions of particulates are included. SO<sub>2</sub> and NO<sub>x</sub> (as NO<sub>2</sub>) emissions are included for all units. Greenhouse gases are excluded as per the agreement reached between Eskom and the Department of Forestry, Fisheries and the Environmental in the first quarter of 2017/18 financial year's MINTEC and MINMEC management meeting.

### Raw Materials and Products

**Table 1. Quantity of Raw Materials and Products used/produced for the month of August 2025**

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of August 2025
	Coal	Tons/month	1 800 000	672 461
	Fuel Oil	Tons/month	6 000	2 183.7
Production Rates	Product/ By-Product Name	Unit	Maximum Production Rate Permitted (Quantity)	Production Rate in Month of August 2025
	Energy	GWh	3 058	1 115.9
	Ash	Tons/month	429 746	209 202.6

### Abatement Technology

**Table 2. Abatement Equipment Control Technology for the month of August 2025**

Associated Unit	Technology Type	Actual Utilisation (%) for the month of August 2025	*Minimum Control Efficiency (%)
Unit 1	Fabric Filter Plant	100	99.95
Unit 2	Fabric Filter Plant	100	99.93
Unit 3	Fabric Filter Plant	0	Off-line
Unit 4	Fabric Filter Plant	100	99.97
Unit 5	Fabric Filter Plant	100	99.94
Unit 6	Fabric Filter Plant	100	99.93


\*Calculated from the assumption of 90% fly ash to 10% bottom ash and percentage ash as measured in coal

## Energy Source Characteristics


**Table 3. Energy Source Material Characteristics for the month of August 2025**

Characteristic	Stipulated Limit (Unit)	Monthly Average Content
Sulphur Content	<1.25%	0.63
Ash Content	<33.84%	31.11


## Emissions Reporting




**Figure 1. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 1.**




**Figure 2. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 2.**




**Figure 3. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 3.**




**Figure 4. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 4.**




**Figure 5. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 5.**




**Figure 6. Particulate Matter emissions (daily averages) for the month of August 2025 against emission limit for Unit 6.**




**Figure 7. SO₂ emissions (daily averages) for the month of August 2025 against emission limit for Unit 1.**




**Figure 8. SO₂ emissions (daily averages) for the month of August 2025 against emission limit for Unit 2.**




**Figure 9. SO<sub>2</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 3.**




**Figure 10. SO<sub>2</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 4.**




**Figure 11. SO<sub>2</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 5.**




**Figure 12. SO<sub>2</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 6.**




**Figure 13. NO<sub>x</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 1.**




**Figure 14. NO<sub>x</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 2.**




**Figure 15. NO<sub>x</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 3.**



**Figure 16. NO<sub>x</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 4**



**Figure 17. NO<sub>x</sub> emissions (daily averages) for the month of August 2025 against emission limit for Unit 5**



**Figure 18. NO<sub>x</sub> emissions (daily averages) for the month August 2025 against emission limit for Unit 6**

**Table 4: Monthly tonnages for the month of August 2025**

Unit	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	23.3	4 580	2 604
Unit 2	30.3	3 460	1 483
Unit 3	Off	Off	Off
Unit 4	7.5	1 877	972
Unit 5	25.8	3 477	1 804
Unit 6	22.3	3 077	1 122

**Table 5: Average monthly concentrations (mg/Nm<sup>3</sup>) for the month of August 2025**

Unit	PM (Mg/Nm <sup>3</sup> )	SO <sub>2</sub> (Mg/Nm <sup>3</sup> )	NO <sub>x</sub> (Mg/Nm <sup>3</sup> )
1	14.3	2 616.5	1 481.2
2	21.1	2 217.6	946.5
3	Off	Off	Off
4	10.5	2 235.0	1 136.6
5	19.3	2 483.5	1 286.0
6	16.9	2 110.0	753.5

**Table 6: Each unit and respective days operating in compliance to the AEL PM Emission Limits**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance
Unit 1	28	0	0	0	0
Unit 2	20	0	0	0	0
Unit 3	Off	Off	Off	Off	Off
Unit 4	13	0	0	0	0
Unit 5	22	0	0	0	0
Unit 6	18	0	0	0	0



**Table 7: Each unit and respective days operating in compliance to the AEL SO<sub>2</sub> Emission Limits**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance
Unit 1	26	3	0	0	3
Unit 2	22	0	0	0	0
Unit 3	Off	Off	Off	Off	Off
Unit 4	15	0	0	0	0
Unit 5	22	1	0	0	1
Unit 6	19	0	0	0	0

**Table 8: Each unit and respective days operating in compliance to the AEL NOX Emission Limits**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance
Unit 1	0	3	0	26	29
Unit 2	22	0	0	0	0
Unit 3	Off	Off	Off	Off	Off
Unit 4	5	6	0	4	10
Unit 5	0	2	0	21	23
Unit 6	19	0	0	0	0

**Table 9: Data Reliability (%)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	100.0	100.0	100.0	34.5
Unit 2	100.0	100.0	100.0	74.4
Unit 3	Off	Off	Off	Off
Unit 4	99.4	99.4	99.6	97.6
Unit 5	100.0	100.0	100.0	99.7
Unit 6	100.0	100.0	98.7	98.7

**Table 10: CO<sub>2</sub> and O<sub>2</sub> deviations of the Month of August 2025**

2025/09/12	Final O <sub>2</sub> CEMS Data (%)						CO <sub>2</sub> (Actual Dry %)						SUM CO <sub>2</sub> + O <sub>2</sub> CEMS Data (%)					
	U1	U2	U3	U4	U5	U6	U1	U2	U3	U4	U5	U6	U1	U2	U3	U4	U5	U6
2025/08/01	11.0	11.1			8.7	9.5	9.1	9.2			11.1	11.2	20.1	20.3			19.8	20.7
2025/08/02	11.7				8.4	9.0	9.2				11.1	11.2	20.8				19.4	20.2
2025/08/03	12.2				8.8	8.5	9.2				11.1	11.3	21.3				19.9	19.8
2025/08/04	12.1			12.5	8.4	8.8	9.2			7.9	11.2	11.4	21.3			20.4	19.6	20.2
2025/08/05	11.9			12.4	8.6	9.3	9.0			8.6	11.2	11.5	20.9			21.0	19.8	20.8
2025/08/06	12.2			11.1	8.5	8.7	8.8			9.5	11.2	11.5	21.1			20.6	19.6	20.2
2025/08/07	11.7			13.0	8.1	9.2	9.2			8.3	11.1	11.4	20.9			21.3	19.2	20.6
2025/08/08	11.8				8.2	9.9	9.1				11.2	11.5	20.9				19.4	21.4
2025/08/09	12.3				8.6		8.8				11.1		21.1				19.7	
2025/08/10	12.6				8.4		8.7				11.1		21.2				19.5	
2025/08/11	12.0	11.1			8.3		8.9	7.6			11.1		20.9	18.7			19.4	
2025/08/12	12.0	11.1		12.2	8.2		9.1	8.7		8.2	11.2		21.1	19.8		20.5	19.3	
2025/08/13	12.0	11.1		10.9	8.7	11.8	8.9	8.9		9.6	11.2	10.4	20.9	20.0		20.5	19.9	22.1
2025/08/14	12.0	11.1		11.9	9.3	9.9	9.1	9.2		9.3	11.3	11.2	21.0	20.3		21.2	20.6	21.1
2025/08/15	12.0	11.4		10.8	8.8	10.2	8.7	9.1		9.6	11.2	11.3	20.7	20.5		20.4	20.0	21.5
2025/08/16		11.5		11.5	8.4	10.1		9.4		8.5	11.2	11.3		20.9		20.0	19.6	21.4
2025/08/17		11.6		10.7	9.0	10.1		9.1		9.4	11.2	11.2		20.7		20.1	20.2	21.3
2025/08/18	12.0	11.3		12.0	8.4	9.9	9.0	9.3		9.2	11.2	11.3	21.0	20.6		21.2	19.6	21.2
2025/08/19	12.0	11.4		11.0	9.0	9.8	9.0	9.2		9.8	11.2	11.4	21.0	20.6		20.8	20.2	21.1
2025/08/20	12.0	11.6		10.4	9.1	9.7	9.0	9.0		9.7	11.2	11.4	21.0	20.5		20.1	20.3	21.2
2025/08/21	12.0	11.6		10.8	8.5	10.1	9.0	9.0		9.8	11.2	11.4	21.0	20.6		20.6	19.7	21.6
2025/08/22	12.0	11.2		10.3	8.9	9.9	9.0	9.2		9.3	11.3	11.5	21.0	20.4		19.6	20.2	21.3
2025/08/23	12.0	11.2				10.0	9.0	9.3				11.4	21.0	20.5				21.4
2025/08/24	12.0	11.3					9.0	9.3					21.0	20.5				
2025/08/25	12.0	10.6					9.0	9.7					21.0	20.3				
2025/08/26	12.0	10.2					9.0	10.0					21.0	20.3				
2025/08/27	12.0	10.1					9.0	10.2					21.0	20.3				
2025/08/28	12.0	10.2					9.0	10.2					21.0	20.4				
2025/08/29	12.0	11.0					9.0	9.6					21.0	20.5				
2025/08/30	12.0	11.2					9.0	9.3					21.0	20.6				
2025/08/31	12.0	11.4			10.5		9.0	9.2			11.3		21.0	20.6			21.8	

Calculation: CO<sub>2</sub>% + O<sub>2</sub>% = 19.5-21.5%

\*Blank spaces indicate that the unit was offline during that period

**Emergency Generation****Table 11: Emergency Generation for the month of August 2025**

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	0	0	0	0	0	0
<b>Emergency Hours declared including hours after stand down</b>	0	0	0	0	0	0
<b>Hours over the Limit during Emergency Generation</b>	0	0	0	0	0	0

**Comments on the performance and availability of each unit****UNIT 1**

The unit base loaded for most of the days during the month and off for two days. Twenty-four fabric filter bags were replaced during the month.

**UNIT 2**

The unit base loaded for most of the days during the month and off for nine days. Forty-five fabric filter bags were replaced during the month.

**UNIT 3**

The unit was on outage for the entire month. Twenty-five fabric filter bags were replaced during the month.

#### UNIT 4

The unit base loaded for most of the days during the month and off for sixteen days. Fifty-four fabric filter bags were replaced during the month.

#### UNIT 5

The unit base loaded for most of the days during the month and off for eight days. Twenty-three fabric filter bags were replaced during the month.

#### UNIT 6

The unit base loaded for most of the days during the month and off for twelve days. Twenty-one fabric filter bags were replaced during the month.

### Complaints Register

**Table 12: Complaints for the month of August 2025**

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
	No complaints were received in August 2025.				

### Area and or line source – management and mitigation measures


There were no incidents or leaks at the fuel oil tanks, loading and offloading area for the month of August 2025.

#### General

Unit 2 O<sub>2</sub> monitor has been repaired. Unit 1 O<sub>2</sub> monitor reliability was below 80%. The Original Equipment Manufacturer (OEM) will be onsite to repair the monitor. The exceedances on NO<sub>x</sub> are detailed in Table 8. The Station is tracking the actions from the investigation conducted and will provide feedback on the progress to the licensing authority.

Yours sincerely

Report compiled by:



Faith Kagoda

**ENVIRONMENTAL MANAGER: (MAJUBA)**

Date 17/09/2025

Report verified by:



Lindani Madonsela

**BOILER ENGINEERING MANAGER: (MAJUBA)**

Date 18/09/2025

Report approved by:



Johan Swanepoel

**ENGINEERING MANAGER: (MAJUBA)**

Date 18/09/2025