

**Generation**

Nkangala District Municipality
P O Box 437
Middelburg
1050

Date: 2025/11/18

Enquiries: Duvha Environmental Management
+27 13 690 0445
+27 66 212 2105

Attention:

Mr V Mahlangu
AND

Enquiries: Ms Simthandile Nhlapo
+27 13 690 0445
+27 66 212 2105

Directorate: Air Quality Management Services

The Chief Director:

Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Total number of pages: 13

Total number of Annexes: 0

DUVHA POWER STATION

Atmospheric Emission License: 17/4/AEL/MP312/11/07

GENERAL MANAGER

2025/11/29

DATE

DUVHA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License: 17/4/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Oct-2025
	Coal	Tons	2 260 000	473 764.04
	Fuel Oil	Tons	5 000	2873.48
Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Oct-2025
	Energy	GWh	2 678.400	834.76
	Ash	Tons	not specified	112 471.58

Note: Max energy rate = AEL capacity [3,600 MW] × 24 hrs × days in month ÷ 1,000 (to convert to GWh).

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	18-24	22.33
Sulphur Content	%	0.6 TO >1.2	0.72
Ash Content	%	27 TO 30	23.74

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	Daily Limit		
	PM	SO ₂	NO _x
Unit 1	50	2600	1100
Unit 2	50	2600	1100
Unit 4	100	2600	1100
Unit 5	50	2600	1100
Unit 6	100	2600	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	ESP Efficiency	Technology Type	SO ₃ Plant Utilization
Unit 1	FFP	99.876%	SO ₃	n/a
Unit 2	FFP	99.968%	SO ₃	n/a
Unit 4	ESP + SO ₃	Off-line	SO ₃	Off-line
Unit 5	ESP + SO ₃	99.868%	SO ₃	94.5%
Unit 6	ESP + SO ₃	99.886%	SO ₃	100.0%

Note: The ESP plant does not have a bypass mode; therefore, it operates at 100% utilization.

5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100 0	94 2	100 0	100 0
Unit 2	100 0	94 2	94 4	94 2
Unit 4	Off	Off	Off	Off
Unit 5	99 7	93 3	93 3	94 0
Unit 6	100 0	80 8	80 4	100 0

Note NO_x emissions are measured as NO in PPM. The final NO_x value is expressed as total NO₂ equivalent

6 EMISSION PERFORMANCE

Table 6 1 Monthly tonnages for October 2025

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	35 2	1 934	967
Unit 2	7 6	1 822	1 005
Unit 4	Off	Off	Off
Unit 5	38 6	1 783	698
Unit 6	10 2	974	414
SUM	91 64	6 512	3 084

Table 6 2 PM AEL Daily - October 2025

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	27	0	0	0	0	22 9
Unit 2	22	0	0	0	0	6 9
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	30	1	0	0	1	27 5
Unit 6	10	0	0	0	0	20 3
SUM	89	1	0	0	1	

Table 6 3 SO₂ AEL Daily - October 2025

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	28	0	0	0	0	1 223 6
Unit 2	23	0	0	0	0	1 435 9
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	31	0	0	0	0	1 299 6
Unit 6	13	0	0	0	0	1 556 5
SUM	95	0	0	0	0	

Table 6.4: NO_x AEL Daily - October 2025

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	28	0	0	0	0	610.6
Unit 2	23	0	0	0	0	785.8
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	31	0	0	0	0	506.2
Unit 6	13	0	0	0	0	655.5
SUM	95	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - October 2025




Figure 2: Duvha Unit 2 PM Emissions - October 2025




Figure 3: Duvha Unit 5 PM Emissions - October 2025




Figure 4: Duvha Unit 6 PM Emissions - October 2025




Figure 5: Duvha Unit 1 SO₂ Emissions - October 2025




Figure 6: Duvha Unit 2 SO₂ Emissions - October 2025




Figure 7: Duvha Unit 5 SO₂ Emissions - October 2025




Figure 8: Duvha Unit 6 SO₂ Emissions - October 2025




Figure 9: Duvha Unit 1 NO_x Emissions - October 2025




Figure 10: Duvha Unit 2 NO_x Emissions - October 2025



Figure 11: Duvha Unit 5 NO_x Emissions - October 2025





Figure 12: Duvha Unit 6 NO_x Emissions - October 2025



7 Shut-down and light-up information for OCTOBER 2025

	Event Description	Event 1	
Unit 1	Breaker Open (BO)	BO previously	BO previously
	Draught Group (DG) Shut Down (SD)	n/a	n/a
	BO to DG SD (duration)	n/a	DD:HH:MM
	Fires in time	9:35 pm	2025/10/03
	Synch. to Grid (or BC)	5:35 am	2025/10/04
	Fires in to BC (duration)	00:08:00	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2025/10/06
	Emissions below limit from BC (duration)	01:18:25	DD:HH:MM

	Event Description	Event 1	
Unit 2	Breaker Open (BO)	11:30 am	2025/10/10
	Draught Group (DG) Shut Down (SD)	12:35 pm	2025/10/19
	BO to DG SD (duration)	09:01:05	DD:HH:MM
	Fires in time	2:10 pm	2025/10/19
	Synch. to Grid (or BC)	10:00 pm	2025/10/19
	Fires in to BC (duration)	00:07:50	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2025/10/21
	Emissions below limit from BC (duration)	01:02:00	DD:HH:MM

	Event Description	Event 1		Event 2	
Unit 6	Breaker Open (BO)	BO previously	BO previously	11:25 pm	2025/10/10
	Draught Group (DG) Shut Down (SD)	n/a	n/a	5:30 am	2025/10/14
	BO to DG SD (duration)	n/a	DD:HH:MM	03:06:05	DD:HH:MM
	Fires in time	4:05 pm	2025/10/05	5:25 am	2025/10/25
	Synch. to Grid (or BC)	10:35 am	2025/10/06	10:55 am	2025/10/25
	Fires in to BC (duration)	00:18:30	DD:HH:MM	00:05:30	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2025/10/07	12:00 am	2025/10/27
	Emissions below limit from BC (duration)	00:13:25	DD:HH:MM	01:13:05	DD:HH:MM

8 COMPLAINTS

There were no complaints for this month.

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

9 GENERAL

Exceedances:

Particulate Matter:

Unit 5

01/10/2025

The SO3 plant scrubs were faulty due to blockages in the channels that caused pressure buildup that led to SO3 leaks. The SO3 plant had to be serviced for these leaks.

Additionally, the SO3 utilization was 94.5% for October due to the following reasons:

01/10/2025 - 02/10/2025:

On the 1st of October an electrical issue caused a loss of power to multiple plant areas on site including the SO3 skid and common plant. Upon the restoration of power, Unit 5 SO3 failed to run. Fault finding continued through the evening and on to the 2nd of October and there were defects identified on the VSD of the process air blower. The defects were attended, and the plant had to then be put onto preheat before starting to inject.

19/10/2025 - 20/10/2025

The return to service of Unit 2 had an impact on the pressure of the auxiliary steam range. The low steam pressure on the aux steam range caused the sulphur temperature to drop below the required values for SO3 plant to run. This led to the SO3 being out of service for part of the 19th and part of the 20th. Once pressure to aux steam range was restored, there was a period required to warm sulphur to the correct temperature and then preheat programme before SO3 could resume injecting.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

10. S30 Incidents Register

There were no section 30 incidents

Ben Hatchwayo B
Boiler Plant Engineering Manager

26/11/2025
Date

J P
Environmental Manager

2025/11/27
Date

R
Engineering Manager

2025/11/27
Date

Compiled by Environmental Officer

For Nkangala District Municipality Air Quality Officer

Copies Generation Environmental Management D Herbst
B McCourt

Generation Compliance Management R Rampiar
Generation Asset Management E Patel

Duvha Power Station
Engineering Manager
Operating Manager
Maintenance Manager
Production Manager
Boiler Engineering Manager
System Engineer
Environmental Manager