



**Generation**

Nkangala District Municipality  
P O Box 437  
Middelburg  
1050

**Date: 2025/12/22**

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105

**Attention:**

Mrs NL Simelane

AND

Directorate: Air Quality Management Services

The Chief Director:

Mr M Kekana

Department of Environmental Services

Private Bag X447

PRETORIA

0001

Tel: (012) 310 3263

Fax: (012) 320 0488

**Total number of pages: 13**

**Total number of Annexes:0**

**DUVHA POWER STATION**

Atmospheric Emission License: NDM/AEL/MP312/11/07

GENERAL MANAGER

2025/12/24

DATE

**DUVHA POWER STATION MONTHLY EMISSIONS REPORT**

Atmospheric Emission License: NDM/AEL/MP312/11/07



## 1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Nov-2025
	Coal	Tons	1400000	390 056.11
	Fuel Oil	Tons	5 000	4182.48

Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Nov-2025
	Energy	GWh	2160	682.23
	Ash	Tons	562 464	92 677.33

Note: Max energy rate = AEL capacity [3,600 MW] × 24 hrs × days in month ÷ 1,000 (to convert to GWh).

## 2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 - 1.2	0.70
Ash Content	%	30.2	23.76

## 3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	Daily Limit		
	PM	SO <sub>2</sub>	NO <sub>x</sub>
Unit 1	50	2600	1100
Unit 2	50	2600	1100
Unit 4	100	2600	1100
Unit 5	50	2600	1100
Unit 6	100	2600	1100

## 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	ESP Efficiency	Technology Type	SO <sub>3</sub> Plant Utilization
Unit 1	FFP	99.95%	SO <sub>3</sub>	n/a
Unit 2	FFP	99.95%	SO <sub>3</sub>	n/a
Unit 4	ESP + SO <sub>3</sub>	Unit off load	SO <sub>3</sub>	Unit off load
Unit 5	ESP + SO <sub>3</sub>	99.86%	SO <sub>3</sub>	97.8%
Unit 6	ESP + SO <sub>3</sub>	99.86%	SO <sub>3</sub>	100.0%

Note: The ESP plant does not have a bypass mode; therefore, it operates at 100% utilization.

## 5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	100 0	100 0	100 0	100 0
Unit 2	99 2	78 5	78 5	80 3
Unit 4	Unit off load	Unit off load	Unit off load	Unit off load
Unit 5	99 70	82 70	83 10	100 0
Unit 6	99.80	81 40	81 40	80 20

Note: NO<sub>x</sub> emissions are measured as NO in PPM. The final NO<sub>x</sub> value is expressed as total NO<sub>2</sub> equivalent.

## 6 EMISSION PERFORMANCE

Table 6 1 Monthly tonnages for November 2025

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	0 0	2	1
Unit 2	14 8	2 311	1 286
Unit 4	Unit off load	Unit off load	Unit off load
Unit 5	35 60	1 547	658
Unit 6	29 40	2 649	1 287
<b>SUM</b>	<b>79 88</b>	<b>6 510</b>	<b>3 232</b>

Table 6 2 PM AEL Daily - November 2025

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days in contravention	Total Exceedance	Mo Avg (mg/Nm <sup>3</sup> )
Unit 1	1	0	0	0	0	21 2
Unit 2	25	0	0	0	0	10 0
Unit 4	Unit off load	Unit off load	Unit off load	Unit off load	Unit off load	Unit off load
Unit 5	26	2	0	0	2	36 6
Unit 6	26	0	0	0	0	18 5
<b>SUM</b>	<b>78</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>2</b>	

Table 6 3 SO<sub>2</sub> AEL Daily - November 2025

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days in contravention	Total Exceedance	Mo Avg (mg/Nm <sup>3</sup> )
Unit 1	1	0	0	0	0	1 087 30
Unit 2	26	0	0	0	0	1 492 60
Unit 4	Unit off load	Unit off load	Unit off load	Unit off load	Unit off load	Unit off load
Unit 5	30	0	0	0	0	1 226 30
Unit 6	28	0	0	0	0	1 541 10
<b>SUM</b>	<b>85</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

Table 6.4: NO<sub>x</sub> AEL Daily - November 2025

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days in Contravention	Total Exceedance	Mo Avg (mg/Nm <sup>3</sup> )
Unit 1	1	0	0	0	0	519.90
Unit 2	26	0	0	0	0	822.90
Unit 4	<i>Unit off load</i>	<i>Unit off load</i>	<i>Unit off load</i>	<i>Unit off load</i>	<i>Unit off load</i>	<i>Unit off load</i>
Unit 5	30	0	0	0	0	520.00
Unit 6	28	0	0	0	0	746.50
<b>SUM</b>	<b>85</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - November 2025




Figure 2: Duvha Unit 2 PM Emissions - November 2025




Figure 3: Duvha Unit 5 PM Emissions - November 2025




Figure 4: Duvha Unit 6 PM Emissions - November 2025




Figure 5: Duvha Unit 1 SO<sub>2</sub> Emissions - November 2025




Figure 6: Duvha Unit 2 SO<sub>2</sub> Emissions - November 2025




Figure 7: Duvha Unit 5 SO<sub>2</sub> Emissions - November 2025




Figure 8: Duvha Unit 6 SO<sub>2</sub> Emissions - November 2025




Figure 9: Duvha Unit 1 NO<sub>x</sub> Emissions - November 2025




Figure 10: Duvha Unit 2 NO<sub>x</sub> Emissions - November 2025




Figure 11: Duvha Unit 5 NO<sub>x</sub> Emissions - November 2025





Figure 12: Duvha Unit 6 NO<sub>x</sub> Emissions - November 2025



7. SHUT-DOWN AND LIGHT-UP INFORMATION FOR NOVEMBER 2025

	Event Description	Event 1		Event 2	
Unit 1	Breaker Open (BO)	1:00 am	2025/11/01	11:10 pm	2025/11/01
	Draught Group (DG) Shut Down (SD)	8:25 am	2025/11/01	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	00:07:25	DD:HH:MM	n/a	DD:HH:MM
	Fires in time	1:35 pm	2025/11/01		
	Synch. to Grid (or BC)				
	Fires in to BC (duration)		DD:HH:MM		DD:HH:MM
	Emissions below limit from BC (end date)	not > limit	not > limit		
	Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM

	Event Description	Event 1		Event 2		Event 3		Event 4	
Unit 2	Breaker Open (BO)	11:20 am	2025/11/12	7:30 am	2025/11/17	9:45 pm	2025/11/26	4:20 pm	2025/11/27
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	4:30 pm	2025/11/17	12:10 am	2025/11/27	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM	00:09:00	DD:HH:MM	00:02:25	DD:HH:MM	n/a	DD:HH:MM
	Fires in time			7:10 pm	2025/11/17	4:15 am	2025/11/27		
	Synch. to Grid (or BC)			12:45 pm	2025/11/18				
	Fires in to BC (duration)		DD:HH:MM	00:17:35	DD:HH:MM		DD:HH:MM		DD:HH:MM
	Emissions below limit from BC (end date)			12:00 am	2025/11/20	not > limit	not > limit		
	Emissions below limit from BC (duration)		DD:HH:MM	01:11:15	DD:HH:MM		DD:HH:MM		DD:HH:MM

	Event Description	Event 1		Event 2		Event 3	
Unit 5	Breaker Open (BO)	4:30 pm	2025/11/02	3:30 am	2025/11/10	6:15 am	2025/11/12
	Draught Group (DG) Shut Down (SD)	6:10 pm	2025/11/02	8:40 am	2025/11/10	7:10 am	2025/11/12
	BO to DG SD (duration)	00:01:40	DD:HH:MM	00:05:10	DD:HH:MM	00:00:55	DD:HH:MM
	Fires in time	10:40 pm	2025/11/02	10:10 am	2025/11/10	6:15 am	2025/11/13
	Synch. to Grid (or BC)	6:10 am	2025/11/03	3:30 pm	2025/11/10	1:20 pm	2025/11/13
	Fires in to BC (duration)	00:07:30	DD:HH:MM	00:05:20	DD:HH:MM	00:07:05	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2025/11/04	7:00 am	2025/11/11	12:00 am	2025/11/14
	Emissions below limit from BC (duration)	00:17:50	DD:HH:MM	00:15:30	DD:HH:MM	00:10:40	DD:HH:MM

	Event Description	Event 1		Event 2	
Unit 6	Breaker Open (BO)	9:20 am	2025/11/02	7:30 am	2025/11/17
	Draught Group (DG) Shut Down (SD)	1:15 pm	2025/11/02	12:55 pm	2025/11/17
	BO to DG SD (duration)	00:03:55	DD:HH:MM	00:05:25	DD:HH:MM
	Fires in time	5:50 pm	2025/11/03	6:15 pm	2025/11/18
	Synch. to Grid (or BC)	2:40 am	2025/11/04	1:15 am	2025/11/19
	Fires in to BC (duration)	00:08:50	DD:HH:MM	00:07:00	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2025/11/05	12:00 am	2025/11/20
	Emissions below limit from BC (duration)	00:21:20	DD:HH:MM	00:22:45	DD:HH:MM

## 8 COMPLAINTS

There were no complaints for this month.

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Measures implemented to prevent reoccurrence and Dispersion modelling of pollutants where applicable	Date by which measures will be implemented.

## 9 GENERAL

### Exceedances:

Particulate Matter

#### Unit 5

10/11/2025 – 12/12/2025

The unit was returning from a light up, so the emissions abatement equipment's were not yet fully effective as the operating temperatures and conditions were still not yet stable within the first 8 hours of the light up


Additionally, Unit 2 SOx and NOx monitor reliability was below 80% in October due to the following reasons

On the 10<sup>th</sup> to the 13<sup>th</sup> of October and again on the 18<sup>th</sup> to the 20<sup>th</sup>, the stack gas monitoring instruments were unable to record emissions data. This was due to the failure of the 220 Volt power supply, which tripped as a result of heavy rainfall. The continuous emissions monitoring systems (CEMS) became temporarily offline.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

## 10 S30 Incidents


There were no Section 30's this month.

  
Boiler Plant Engineering Manager

24 Dec 2025  
Date

  
Environmental Manager

2025/12/24  
Date

  
Engineering Manager

2025-12-24  
Date

Compiled by Environmental Officer

For Nkangala District Municipality Air Quality Officer

Copies Generation Environmental Management D Herbst  
B Mccourt

Generation Compliance Management R Rampiar  
Generation Asset Management E Patel

Duvha Power Station  
Engineering Manager  
Operating Manager  
Maintenance Manager  
Production Manager  
Boiler Engineering Manager  
System Engineer  
Environmental Manager