



# NKANGALA DISTRICT MUNICIPALITY

☎ 013-249-2000  
✉ 437 or 2032  
Middelburg 1050  
www.nkangaladm.gov.za

📍 2A Walter Sisulu Street  
Middelburg 1050  
✉ records@nkangaladm.gov.za

My Ref.:  
Your Ref.:

Enquiries: NL Simelane Ref. 17/04/AEL/MP311/12/01 Tel: (013) 249 2000 Email: [Simelanenl@nkangaladm.gov.za](mailto:Simelanenl@nkangaladm.gov.za)

## ATMOSPHERIC EMISSION LICENCE HOLDER: ESKOM HOLDING SOC LIMITED KUSILE POWER STATION

ATMOSPHERIC EMISSION LICENCE NO.: 17/04/AEL/MP311/12/01

## ATMOSPHERIC EMISSION LICENCE AS CONTEMPLATED IN SECTION 43 OF THE NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT, 2004, (ACT NO. 39 OF 2004)

I, ML Mahlangu, in my capacity as the Acting General Manager: Community Development Services of Nkangala District Municipality (hereinafter referred to as "the Licensing Authority", in terms of Section 36(1) of the National Environmental Management: Air Quality Act, 2004 (Act 39 of 2004, hereinafter referred to as the "Act"), and as provided for in Section 40 (1) (a) of the Act, hereby grant the authorisation of the above-mentioned Atmospheric Emission Licence subject to Section 43 of the Act to the conditions specified herein.

This Atmospheric Emission Licence is issued to **Eskom Holding SOC Limited Kusile Power Station** in terms of Section 42 of the Act as amended, in respect of 21 Listed Activity **Subcategory 1.1; 2.4 and 5.1**. The Atmospheric Emission Licence is issued on the basis of information provided in the company's application dated **06 February 2024** and information that became available during processing of the application, as well as the site visit conducted on **21 February 2024**.

The Atmospheric Emission Licence is valid for five (05) years, until **09 April 2029**. This Atmospheric Emission Licence is a renewal initiated by the facility according to Section 47 (1) of the Act and is issued subject to the conditions and requirements set out below which form part of the Atmospheric Emission Licence, and which are binding on **Eskom Holding SOC Limited Kusile Power Station**, (hereinafter referred to as "the Licence Holder").

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 1 of 33



## 1. ATMOSPHERIC EMISSION LICENCE ADMINISTRATION

Name of the Licensing Authority	Nkangala District Municipality
Atmospheric Emission Licence Number	<b>17/04/AEL/MP311/12/01</b>
1 <sup>st</sup> Atmospheric Emission Licence Issue Date	06 March 2019
2 <sup>nd</sup> Atmospheric Emission Licence Issue Date (variation)	30 January 2023
3 <sup>rd</sup> Atmospheric Emission Licence Issue Date (variation)	13 June 2023
4 <sup>th</sup> Atmospheric Emission Licence Issue Date (variation) Appeal Decision	15 January 2024
5 <sup>th</sup> Atmospheric Emission Licence Issue Date (renewal)	09 April 2024
Atmospheric Emission Licence Type	Atmospheric Emission Licence
Atmospheric Emission Licence Review Date	As advised by Licensing Authority
Atmospheric Emission Licence Renewal Date	(Submit renewal application six months before expiry date) 09 October 2028

## 2. ATMOSPHERIC EMISSION LICENCE HOLDER DETAILS

Enterprise Name	Eskom Holding SOC limited
Trading As	Kusile Power Station
Type of Enterprise	State Owned Company
Enterprise Registration Number (Registration Numbers if Joint Venture)	2002/015527/06
Registered Address	Megawatt Park Maxwell Drive Sunninghill Sandton
Postal Address	PO Box 1091 Johannesburg 2000
Telephone Number (General)	011 800 8111
Fax Number (General)	011 800 2122
Industry Sector	Power Generation (Electricity Generation)
Contact Name (General Manager)	Christopher Nani

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 2 of 33



Telephone number	013 680 3250
Cell phone Number	082 805 3392
Fax Number	N/A
E-mail Address	<a href="mailto:Nanit@eskom.co.za">Nanit@eskom.co.za</a>
Contact Name (Emission Control Officer)	Lesiba Kgobe
Telephone Number	013 680 3250
Cell Phone Number	078 903 9211
Fax Number	N/A
Email Address	<a href="mailto:Kgobels@eskom.co.za">Kgobels@eskom.co.za</a>
After Hours Contact Details	082 805 3392

### 3. SITUATION AND EXTENT OF THE PLANT

#### 3.1. Location and extent of the plant

Physical Address of the Plant	Kusile Power Station 4.5 West of R545 Kendal/Balmoral Road, Haartebeesfontein Farm, Witbank, Emalahleni Local Municipality
Description of Site (Erf)	Farm Haartebeesfontein 537 – Portion 4, Remainder Portion 1, Portion 7 and Farm Klipfontein Portion 3, Portion 26 and Portion 58
Coordinates of Approximate Centre of Operations	North-south: 25° 55' 01"S East-west: 28° 55' 00"E
Extent (km <sup>2</sup> )	13:55
Elevation Above Mean Sea Level (m)	1,500
Province	Mpumalanga
Metropolitan/District Municipality	Nkangala District Municipality
Local Municipality	Emalahleni Local Municipality
Designated Priority Area	Highveld Priority Area

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 3 of 33



### 3.2. Description of surrounding land use (within 5km radius)

Agriculture, particularly crop farming, is the main land use in the vicinity of Kusile Power Station. Kendal poultry Farm is situated 5 km south-east of Kusile. Phola residential area is situated 14 km south-east of Kusile. Clewer is situated 20 km east of Kusile and Witbank (eMalahleni) is situated 27 km east of Kusile. There are numerous coal mines in the vicinity of Kusile.



Figure 1: Locality Map of Eskom Holding SOC Limited - Kusile Power Station




Figure 2: Locality of Map of Ambient Air Quality Monitoring Stations for Kendal Poultry and Phola.

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 4 of 33



## 4. GENERAL CONDITIONS

### 4.1. Process and ownership changes

- (a) The holder of the atmospheric emission licence must ensure that all unit processes and apparatus used for the purpose of undertaking the listed activity in question, and all appliances and mitigation measures for preventing or reducing atmospheric emissions, are at all times properly maintained and operated.
- (b) No building, plant or site of works related to the listed activity or activities used by the licence holder shall be extended, altered, or added to the listed activity without an environmental authorisation from the competent authority. The investigation, assessment, and communication of potential impact of such an activity must follow the assessment procedure as prescribed in the Environmental Impact Assessment Regulations published in terms of Section 24(5) of the National Environmental Management Act, 1998 (Act No. 107 of 1998) (NEMA), as amended.
- (c) Any changes in processes or production increases, by the licence holder, will require prior approval by the licensing authority.
- (d) Any changes to the type and quantities of input materials and products, or to production equipment and treatment facilities will require prior written approval by the licensing authority.
- (e) The licence holder must, in writing, inform the licensing authority of any change of ownership of the enterprise. The licensing authority must be informed within thirty (30) working days after the change of ownership.
- (f) The licence holder must immediately on cessation or decommissioning of the listed activity inform in writing the licensing authority.

### 4.2. General duty of care

- (a) The holder of the Licence must, when undertaking the listed activity, adhere to the duty of care obligations as set out in section 28 of the NEMA.
- (b) The Licence holder must undertake the necessary measures to minimize or contain the atmospheric emissions. The measures are set out in section 28(3) of the NEMA as amended.
- (c) Failure to comply with the above condition is a breach of the duty of care, and the Licence holder will be subject to the sanctions set out in section 28 of the NEMA as amended.

### 4.3. Sampling and/or analysis requirements

- (a) Measurement, calculation and/or sampling and analysis shall be carried out in accordance with any nationally or internationally acceptable standard. A different method may be acceptable to the licensing

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 5 of 33



authority as long as it has been consulted and agreed to the satisfactory documentation necessary in confirming the equivalent test reliability, quality and equivalence of analyses.

- (b) The licence holder is responsible for quality assurance of methods and performance. Where the holder of the licence uses internal or external laboratories for sampling or analysis, accredited laboratories and personnel shall be used. The certified copy of accreditation of the internal or external laboratory must be submitted to the license authority annually including its external audits certification.
- (c) The licence holder must provide the licensing authority on request with raw data obtained during sampling and /or analysis including methodology used to reach to the final results submitted to the Licensing Authority.

#### 4.4. General requirements for licence holder

- (a) The licence holder is responsible for ensuring compliance with the conditions of this licence by any person acting on his, her or its behalf including but not limited to an employee, agent, sub-contractor or person rendering a service to the holder of the licence.
- (b) The licence does not relieve the licence holder to comply with any other statutory requirements that may be applicable to the carrying on of the listed activity.
- (c) A copy of the licence must be kept at the premises where the listed activity is undertaken. The licence must be made available to the Environmental Management Inspector representing the licensing authority who requests to see it.
- (d) The licence holder must inform, in writing, the licensing authority of any change to its details including the name of the contact person, postal address and/or telephonic details within fourteen (14) working days after such change has been effected.

#### Special Conditions

- (e) The licence holder must attend and participate quarterly in the Highveld Priority Area Implementation Task Team and Air Quality Stakeholder Forum Meetings for the implementation of the Highveld Priority Air Quality Management Plan.
- (f) The licence holder must annually report atmospheric emissions on the National Atmospheric Emission Inventory System (NAEIS) <https://saelip.environment.gov.za> for the preceding year in terms of GNR 283 in Government Gazette 38633 of 02 April 2015.

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 6 of 33



#### 4.5. Statutory obligations

The licence holder must comply with the obligations as set out in Chapter 5 of NEMAQA (Act no. 39 of 2004) as amended.

### 5. NATURE OF PROCESS

#### 5.1. Process Description


The first unit of Eskom Kusile Power Station came into commercial operation in August 2017 and subsequent units were scheduled to be commissioned at 9 to 12 month intervals. The Station comprises six nominally rated 800 MW units or boiler-turbine-generator sets. The total station capacity is 4 800 MW gross output.

Each pulverized coal boiler has five mills allocated to it and nominally, four are required for the boiler to reach full load. All the mills are vertical spindle mills and each mill is fed from its own dedicated coal storage bunker. The bunkers are supplied by three (3) incline conveyors coming from the coal yard silos which are fed by conveyors from the open coal stockyard. The coal stockyard is located on the Station site. Coal is supplied to the stockyard by trucks until the overland conveyor from the mine is in place.

From the mills, which grind the coal into fine particles known as pulverized fuel (PF), PF is fed into the boilers via PF burners. To bring the boiler up to maximum operation, the boiler temperature has to be high enough to facilitate efficient combustion of PF. Correct boiler temperatures are achieved by starting-up the boiler using heavy fuel oil, which is in turn ignited by propane fired igniters. The boiler is brought up to high temperature using oil burners before PF is injected into the boiler. The oil burners also provide initial ignition of the pulverized coal, and flame stabilization for the coal during low firing rates. During start-up and at low loads, due to the fact that fuel oil is being burnt, exit emissions will greatly exceed those produced under normal operating conditions i.e. when only PF is burnt.

Within the boiler, demineralised water is heated to form super-heated steam which is sent to the turbines to turn the turbine blades. The turbine blades are attached to a shaft which rotates the generator to generate electricity. The cooled steam from the turbine exhaust is sent to the air-cooled condenser (ACC). In the air-cooled condenser, low pressure steam from the steam turbine exhaust is fed through a series of large diameter ducts to multiple banks of finned tubes in a large "A-frame" array. Axial fans blow ambient cooling

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 7 of 33



air over the finned tubes. A heat exchange takes place and the steam condenses back into demineralised water or condensate, which is sent back to the boiler.

Once PF has been combusted in the boilers, two types of ash result: fly ash, which stays buoyant in the exit flue gas stream and coarse ash (or bottom ash) which is too heavy to remain airborne and falls into the hopper at the bottom of the boiler.

Once in the boiler hoppers, coarse ash is quenched using water in a submerged scraper conveyor and sent via belt conveyors to a radial stacker. Fly ash, or particulate matter (PM), is captured using Pulse Jet Fabric Filter (PJFF) plant abatement technologies. The captured ash is pneumatically conveyed from the PJFF hoppers to fly ash silos where the ash is conditioned and deposited onto the same belt conveyors carrying the coarse ash to the radial stacker.

Due to the catastrophic chimney failure, units 1 to 3 require three temporary stacks (unit 1 associated stack 07, unit 2 associated with stack 08 and unit 3 associated with stack 09) will required to enable all 3 units to be brought back online to support the South African grid in the fastest possible timeframe. The possibility of demolishing the permanent chimney and rebuilding has not been ruled out. This option will only be eliminated once the 151m level within the chimney can be secured to the 181m level. The current design and placement of the temporary chimneys excludes the use of the existing flue gas desulphurization (FGD) plant. This is due to the proximity of the absorber to the permanent chimneys, should demolishing be required the surrounding infrastructure will be compromised. This operating condition will only be applicable for a limited duration, until the permanent stacks are remediated.

Once the permanent stack has been remediated and under normal operating conditions, Sulphur Dioxide (SO<sub>2</sub>) is scrubbed out of the flue gas downstream of the Pulse Jet Fabric Filter (PJFF) plant using a limestone based, wet, forced oxidation flue gas desulphurization (FGD) plant, before the flue gas exits the stacks at a height of 220m above ground level.

The temporary stacks for unit 1 to 3 have been fully completed and commissioned. Unit 3 returned to service (operation) on the 30<sup>th</sup> of September 2023. Unit 1 returned to service (operation) on the 16<sup>th</sup> of October 2023.

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 8 of 33



Unit 2 returned to service on the 28<sup>th</sup> of November 2023. Unit 5 is still being synchronised with the grid and has been taken to optimization. The planned commercial date of operation for Unit 5 is in August 2024.

A complete limestone handling system is provided to receive, store, and deliver limestone to the FGD reagent preparation plant. The reagent preparation plant pulverizes the limestone and prepares a slurry for use in the FGD. The FGD waste by-product (gypsum) is dewatered using vacuum belts and thereafter conveyed via belt conveyors and comingled with the coarse ash and the conditioned fly ash. The content of the gypsum is  $\geq 95\%$   $\text{CaSO}_4$  by weight. The FGD plant is able to accommodate a density of  $1170 \text{ kg/m}^2$  of gypsum and when the density reaches  $1200 \text{ kg/m}^2$ , the FGD plant is "bled", i.e. the release gypsum from the FGD absorbers. The coming waste product is delivered to a radial stacker via overland conveyors, or to an emergency ash dump, should the overland conveyors or radial stacker be out of service. Water from the FGD plant is taken to a dewatering plant where a filter press process takes place.

The combined waste product is deposited on the ground by the radial stacker in a dedicated open top concrete structure, and loaded onto trucks using front-end loaders. The trucks will deliver the waste product to the ash/gypsum co-disposal.

During commissioning, it is expected that not all pollution abatement equipment will be operational. The station will run on a continuous basis, but load will be higher during times of high electricity demand. However, it should be noted that for the first six to twelve months the station will operate in a load following mode in order to facilitate the commissioning and optimization of the each unit, however it is to be expected that multiple light up opportunities will be taken to address any commissioning noted defects. The planned timeframes for outages to enable operation/commercialisation of permanent stacks after the repair of the FGD will be communicated with Authorities.

## 5.2. Facility Wide Listed Activities with Regulatory Applicability

Category	Subcategory	Description of the Listed Activity
Category 1: Combustion Installations	Subcategory 1.1: Solid Fuel Combustion Installation	Solid fuels combustion installations used primarily for steam raising or electricity generation.

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 9 of 33



Category 2: Petroleum Industry, the production of gaseous and liquid fuels as well as petrochemicals from crude oil, coal, gas or biomass	Subcategory 2.4: storage and Handling of Petroleum Products	Petroleum products storage tanks and product transfer facilities.
Category 5: Mineral Processing, Storage and Handling	Subcategory 5.1: Storage and Handling of Ore and Coal	Storage and handling of ore and coal not situated on the premises of a mine or works as defined in the Mines Health and Safety Act 29/1996.

### 5.3. Unit Process or Processes

Unit Process	Process function	Batch or Continuous Process
Boilers	Pulverized coal boiler unit 1 to 6	Continuous
Coal stockpile	Storage of coal	Continuous
Fuel oil storage tanks	Storage and handling of fuel oil	Continuous
Coal conveyor	Coal conveyor	Continuous
Ash Conveyor	Ash conveyor	Continuous
Ash Dump	Ash, gypsum and filter press dump	Continuous
Ash Silo	Ash containment	Continuous
Limestone Storage area	Limestone storage	Continuous
Pulse Jet Fabric Filter Plant	Abatement technology for PM	Continuous
Flue Gas Desulphurization Plant	Abatement technology for SO <sub>2</sub>	Continuous
Gypsum conveyor	Gypsum conveyor	Continuous

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 10 of 33



### 5.4. Hours of operations

Unit Process	Operating Hours	Days of Operation per Year
Boilers	24	365
Coal stockpile	24	365
Fuel oil storage tanks	24	365
Coal conveyor	24	365
Ash Conveyor	24	365
Ash dump	24	365
Ash Silo	24	365
Limestone storage area	24	365
Pulse Jet Fabric Filter Plant	24	365
Flue Gas Desulphurization Plant	24	365
Gypsum conveyor	24	365

### 5.5. Graphical Process Information

The following diagrams depicting the graphical operation for the entire operation at Eskom Kusile Power Station:




Figure 2: Graphical Process Flow diagram

Air Quality Officer  
Signature: *[Handwritten Signature]*

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

*[Handwritten mark]*




Figure 3: Graphical process flow diagram during temporal operation (by passing FGD)





Figure 4: Location of temporary stacks (SV07, SV08 and SV09)

Air Quality Officer  
 Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 12 of 33



6. RAW MATERIALS AND PRODUCTS

6.1. Raw Materials used

Raw Material Type	Maximum Permitted Consumption Rate (Quantity)	Units (quantity/period)
Coal	1 818 083	tons/month
Fuel oil	5 533	tons/month
Limestone	72 017	tons/month

6.2. Production Rates

Product Name	Maximum Permitted Production Capacity (Quantity)	Units (quantity/period)
Electricity	4 800 / 3 571	Megawatts / Gigawatt Hours (GWh) per month

6.3. By Product Rates

Product Name	Actual Production Capacity	Units (quantity/period)
Ash	796 300	tons/month
Gypsum	155 100	tons/month

6.4. Materials used in energy sources

Materials for Energy Source	Maximum Permitted Consumption Rate	Designed Consumption Rate	Actual Consumption Rate	Sulphur %	Ash %
Coal	1 818 083	1 818 083	1 818 083	1.3	38
Fuel oil	5 533	5 533	5 533	3.5	0.1

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 13 of 33



## 6.5 Emission Units

### 6.5.1. Emission Unit - Stack Parameters (Point Source)

EU Code	Stack Name	Latitude (decimal degrees) South	Longitude (decimal degrees) East	Height of Release Above Ground (m)	Height Above Nearby Building (m)	Diameter at Stack Tip / Vent Exit (m)	Actual Gas Exit Temperature (°C)	Actual Gas Volumetric Flow (m³/s)	Actual Gas Exit Velocity (m/s)	Emission Hours	Type of Emission (Continuous / Batch)
EU001	SV01	-25.91913768 S	28.91670951 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU002	SV02	-25.91913768 S	28.91670951 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU0021	SV03	-25.91913768 S	28.91670951 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU0022	SV04	-25.91719534 S	28.91900556 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU0024	SV05	-25.91719534 S	28.91900556 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU0025	SV06	-25.91719534 S	28.91900556 E	220	100	8.9	48	1115.86	17.94	24	Continuous
EU001	SV07 (Temporary Stack)	-25.92002675 S	28.91642315 E	116	0	7	141	1 613.89	41.93	24	Continuous
EU002	SV08 (Temporary Stack)	-25.91038238 S	28.91719491 E	116	0	7	141	1 613.89	41.9	24	Continuous
EU0021	SV09 (Temporary Stack)	-25.91880249 S	28.91781662 E	116	0	7	141	1 613.89	41.9	24	Continuous

Air Quality Officer  
Signature: 

Date: 09.04.2024

70

ME

6.5.2. Emission Unit - Area/Line Source

EU Code	Source Name	Source Description	Latitude	Longitude	Height of release Above Ground (m)	Length of Area (m)	Width of Area (m)	Emission in Hours	Type of Emissions
EU0027	Coal stockpiles	<b>Emission Unit</b> Type: Storage of coal  <b>Description:</b> Storage and Material handling area	-25 9199	28.9176	220	1000	500	24	Continuous
EU0027	Coal conveyor	<b>Emission Unit</b> Type: Coal conveyor transfer points  <b>Description:</b> Fugitive dust	28° 55'18" E	25° 55'18" S	30	2150	10	24	Continuous

Air Quality Officer.  
Signature: 

Date: 07.04.2024



EU0026	Ash conveyor	emissions from the conveyor	<b>Emission Unit</b> Conveyor transfer points	-25.789444	29.500555	N/A	N/A	N/A	24	Continuous
EU0028	Ash dump		<b>Description:</b> Fugitive dust emissions from the Conveyors that contain ash <b>Emission Unit</b> Type: Ash dump <b>Description:</b> Fugitive emissions arising from ash transportation and storage	-25.9611	28.9131	130	3350	2825	24	Continuous

Air Quality Officer  
Signature: 

Date: 09.04.2024

Page 16 of 33

AEL Ref No.: 17/04/AEL/IMP31112/01



EU0029	Fuel oil tanks	<b>Emission Unit</b> <b>Type:</b> Fuel oil tanks vents <b>Description:</b> VOCs	Tank 1 -25.921064 Tank 2 -25.920605	Tank 1 -28.915701 Tank 2 28.91596	18.21	N/A	N/A	24	Continuous
EU0032	Limestone storage pile	<b>Emission Unit</b> <b>Type:</b> storage and handling of limestone <b>Description:</b> Fugitive emissions from receiving of limestone	-25.9248	28.9144	18	40	320	24	Continuous
EU0032	Limestone Storage Silo	<b>Emission Unit</b> <b>Type:</b> Limestone storage silo	-25.9248	28.9144	18	40	320	24	Continuous

Air Quality Officer  
Signature: 

Date: 09.04.2024  


EU0033	Gypsum	<b>Description:</b> Fugitive emissions from storage and handling of limestone	<b>Emission Unit</b> Gypsum conveyor transfer points	<b>Description:</b> Fugitive dust from the conveyors that contain gypsum	28°54'59" E	25°55'20" S	10	510	10	24	Continuous
--------	--------	--	---	---	-------------	-------------	----	-----	----	----	------------

Air Quality Officer  
 Signature: 

Date: 09.04.2024 

## 7. CONTROL DEVICES, EMISSION UNITS, AND REPORTING GROUPS

### 7.1. Control Devices

Emission Unit				Control Device							
Associated Source Code	Appliance / Process Equipment Number	Appliance Serial Number	Appliance Type / Description	Control devices Name and Model	Control Devices Manufacture Date	Commission Date	Date of Significant Modification / Upgrade	Device Type	Design Capacity Control Efficiency (%)	Minimum Control Efficiency (%)	Minimum Utilisation (%)
CD Unit 1 - 6 Flues 1 - 6	CD001	CD-S1	Pulse Jet Fabric Filter Plant	PD-X-14-66-8250	2016	07/31/2016	N/A	Filter, Fabric	100	99	100
CD Unit 4 - 6 Flues 4 - 6	CD001	CD-S2	Flue Gas Desulfurization Plant	DDHTK	2018	07/31/2018	N/A	Flue Gas Desulfurization	90	80	100

### 7.2. Reporting / Emission Unit – Maximum Emission Rates (Under Normal Working Conditions)

RG/EU Code	Listed Activity	Pollutant Name	Maximum Release Rate (mg/Nm <sup>3</sup> )	Date to be Achieved By	Average Period (Drop-down: Instantaneous, Hourly, Daily, Monthly, Annually)	Duration of Emissions (Hours)
EU001 (SV07 – Temporary Stack)	Subcategory 1.1	PM	50	Immediately	Daily	24 hours
		SO <sub>2</sub>	1000	31 March 2025	Daily	24 hours
			3500	Immediately	Daily	24 hours

Air Quality Officer  
Signature: 

Date: 09.04.2024

Page 19 of 33

AEL Ref No.: 17/04/AEL/MP311/12/01

EU002	(SV08 – Temporary Stack)	Subcategory 1.1	NO <sub>x</sub>	750	immediately	Daily	24 hours
			PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	31 March 2025	Daily	24 hours
				3500	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours
EU0021	(SV09 – Temporary Stack)	Subcategory 1.1	PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	31 March 2025	Daily	24 hours
				3500	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours
EU0022		Subcategory 1.1	PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours
			PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	Immediately	Daily	24 hours
EU0024		Subcategory 1.1	NO <sub>x</sub>	750	Immediately	Daily	24 hours
			PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours
			PM	50	Immediately	Daily	24 hours
EU0025		Subcategory 1.1	SO <sub>2</sub>	1000	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours
			PM	50	Immediately	Daily	24 hours
			SO <sub>2</sub>	1000	Immediately	Daily	24 hours
			NO <sub>x</sub>	750	Immediately	Daily	24 hours

Air Quality Officer  
Signature: 

Date: 09.04.2024  


## Point source – Operating Requirements

- 7.2.1. Eskom Kusile Power Station must report all non – compliance with the conditions stipulated in this Atmospheric Emission Licence.
- 7.2.2. A copy of this AEL shall be retained at a place convenient to be produced in case the authorities would like to view it.
- 7.2.3. The Licence holder shall notify the Licensing Authority in writing pertaining to any upgrades or building alterations associated with the listed activity, prior taking the action.
- 7.2.4. The Licence holder must comply with the National Greenhouse Gas Emission Reporting Regulations No. 40762 Government Gazette 03 April 2017.
- 7.2.5. All units must be fitted with continuous emission monitoring equipment for PM; SO<sub>2</sub> and NO<sub>x</sub>.
- 7.2.6. Any abnormalities experienced shall be part on the normal monthly reporting and be forwarded to the Licensing Authority.
- 7.2.7. In the event where there is an equipment failure, malfunction or break down, the responsible person/licence holder shall reduce the load to the extent that non-compliance to the licence conditions are avoided and if it still continues, the operation shall be halted.
- 7.2.8. The number of hours for which emissions exceeded the limit shall be reported immediately to the Licensing Authority.
- 7.2.9. Emissions must be measured and reported to Licensing Authority **as per condition 7.4** of the Atmospheric Emission Licence.
- 7.2.10. The licence holder must at all times prevent any deviation from the normal conditions of operations that may result in emission exceedances from the specified limit values. In case there is potential of such, the loading shall be scaled down or operations shall be halted completely if there is a likelihood that continued operation may result in harm to human health and well-being or otherwise be detrimental to the environment.
- 7.2.11. The licence holder shall be liable to prevent and mitigate against the risk of harm to human health and the environment and shall put in place measures necessary to prevent and/ or mitigate against such risks.
- 7.2.12. Where continuous emission monitoring is required for a listed activity-

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 21 of 33



- (a) The averaging period for the purpose of compliance monitoring shall be expressed on a daily average basis or as prescribed in the Atmospheric Emission License.
- (b) The emission monitoring system must be maintained to yield a minimum of 80% valid hourly average values during the reporting period.
- (c) The emission monitoring system must be maintained and calibrated as per the original equipment manufacture's specifications.
- (d) Continuous emission monitoring systems must be calibrated by a SANAS accredited laboratory at least every two (2) years.

7.2.13. The coal specifications shall not be lowered in regards to Service Level Agreements with coal supply contractors and has to undergo pre-qualification, i.e. has to be tested by an accredited laboratory in order to ascertain that it complies with the sulphur and ash content specified in condition 6.4, prior it being used by the facility.

**7.2.14. Special Minimum Emission Standards Postponement Conditions:**

Eskom Kusile Power station must establish and implement the following mitigation measures until the return of the Flue Desulphurisation Gas (FGD):

- (a) The License holder must implement all measures, activities and actions stipulated in the mitigation plan.
- (b) The Licence holder must take measures to mitigate harm caused by the exposure of SO<sub>2</sub> to its employees and surrounding communities. These measures must at minimum include independent health screenings and referral to appropriate public health facilities for treatment where necessary, as stipulated in the exemption letter dated 14 March 2023 issued by the Minister of Forestry, Fisheries, and the Environment.
- (c) The Licence holder must submit monthly progress reports on the implementation of the compliance road map and commitments made towards recommencing of the FGD in support of the postponement application for Kusile Power Station to the licensing authority and the National Air Quality Officer.

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 22 of 33



- (d) The Licence holder must conduct ambient air quality monitoring at Balmoral (at or around Laerskool Balmoral), Wilge (at the Chicken Farm Ambient Air Quality Monitoring Station), Phola, Sibongindawo (at or around the primary school) and Ogies (at or around the Ogies Clinic).
- (e) Monitoring should focus on pollutants with significant acute health impacts, including SO<sub>2</sub>, NO<sub>2</sub> and O<sub>3</sub>. Exceedances of the National Ambient Air Quality Standards for the aforementioned air pollutants must be immediately reported to the licensing authorities and the Department of Forestry, Fisheries and the Environment (DFFE). Ambient air quality monitoring data must be transferred on real time basis to the South African Air Quality Information System (SAAQIS).
- (f) The license holder must take necessary measures to reduce emissions when concentration reach Disabling/Trigger Levels from the monitoring stations listed in Condition 7.2.13 (e).
- (g) The License holder must make temporary stacks' continuous monitoring data accessible in real time, to the licensing authority and National Air Quality Officer for the following parameters:
- (i) Stack SO<sub>2</sub> concentration (mg/Nm<sup>3</sup>)
  - (ii) Stack temperature (°C)
  - (iii) Stack oxygen content (%)
  - (iv) Flue gas volumetric flowrate (Nm<sup>3</sup>/hr)
  - (v) SO<sub>2</sub> mass flowrate (tons/hr)
- (i) The Licence holder must implement the Health screening programme to identify people with air pollution related diseases, including asthma, chronic bronchitis, emphysema; Screening has to consider confidentiality and ethics approval is therefore required. Ethically acceptable screening methodology/tools must be used. The Licence Holder must provide evidence of the health screening to the licensing authority and National Air Quality Officer on a quarterly basis.
- (j) Based on the Health Screening programme, the Licence holder must implement the Emergency Response Plan and submit a report, as per condition 7.2.14 (k), to the licensing authority and the National Air quality Officer.
- (k) The Emergency Response Plan must include but not limited to:
1. Identification and ensuring the availability of health care facilities such as clinics and hospitals (both public and private) in the receiving area and health facilities must be notified in event of emergencies;
  2. Ensure the availability of emergency services and assurance of their adequacy.

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 23 of 33



3. The License holder's emergence response resources which will be available in case of emergence
  4. Emissions management/reduction measures that will be put in place in case of emergency
- (l) The Licence holder must report immediately to the licensing authority and DFFE on incidents and responses to SO<sub>2</sub> episodes above the agreed trigger levels according to the applicable legislation.
  - (m) The Licence holder's failure to comply with these conditions may result in the licensing authority revoking or suspending the licence in terms of Section 47A of NEM: AQA.
  - (n) This license is issued subject to Eskom Kusile Power station in complying with the compliance road map commitments made towards recommencing of the west stack and its FGD.

**7.2.16. Special Appeal decision conditions:**

- a) Eskom Kusile Power Station must submit monthly updates to the National Air Quality Officer on the progress of the repairs to the permanent stacks, for the duration of the operation of the temporary stacks. These reports must be made publicly available on Eskom's official website. This is to ensure that the postponement is of a temporary nature and Eskom Kusile Power Station is held to account.
- b) Kusile Power Station's Health Screening and Temporary Stack Emissions Monitoring Reports for the increased SO<sub>2</sub> emissions and associated health impacts must be made publicly available on monthly basis on Eskom's official website for the duration of the operation of the temporary stacks.
- c) Eskom Kusile Power Station must do monitoring of the animal health (poultry and pig) at the properties of Fairacres Products Proprietary Limited, GHB Farms Proprietary Limited and Topigs Norsvin SA Proprietary Limited, for the duration of the operation of the temporary stacks.

7.2.17. In line with the Minister's Appeal Decision as indicated in 7.2.14 above, the facility is required to submit all required monthly reports due to the National Air Quality Officer (and the Licensing Authority) after the end of each monthly reporting period.

Air Quality Officer  
Signature: \_\_\_\_\_



Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 24 of 33



7.3. Reporting Group / Emission Unit – maximum emission rates (under start-up, maintenance and shut-down conditions) there are no abnormal limit, therefore exceedance above maximum release rate shall be reported to the licensing authority.

RG/EU Code	Listed Activity	Pollutant Name	Maximum Release Rate (mg/Nm <sup>3</sup> )	Average Period (Drop-down: Instantaneous, Hourly, Daily, Monthly, Annually)	Maximum Gas Volumetric Flow (m <sup>3</sup> /hr)	Maximum Gas Exit Velocity (m/s)	Emission Hours	Permitted Duration of Emissions
All point source code	Subcategory 1.1	PM	50	Daily	N/A	N/A	N/A	Within 48 hours after commission of plant or equipment break-down/maintenance.
		SO <sub>2</sub>	1000					
			3500					
		NO <sub>x</sub>	750					

**The following conditions must be adhered to at a minimum during start-up, maintenance and shutdown conditions:**

- 7.3.1. The Licence Holder must take all reasonable measures to control atmospheric emissions during start-up, maintenance and shutdown operations.
- 7.3.2. Normal start-up, break-down/maintenance/upset and shut-down conditions shall not exceed a period of 48 hours. Should normal start-up, breakdown/maintenance and shut down conditions exceed a period of 48 hours, Section 30 of National Environmental Management Act, 107 of 1998 (as amended) shall apply.
- 7.3.3. In order to put into effect section 42 of the Act, the licence holder shall, on receipt of the Atmospheric Emission Licence, undertake an investigation to measure, monitor and report on point source emissions released during start-up, maintenance, and shut-down conditions.
- 7.3.4. In order to put into effect the provision of section 42 of the Act, the licensing Authority may from time to time review the conditions set herein and may set maximum emission limits to be adhered to by the licence holder during start-up, maintenance, and shutdown conditions.

Air Quality Officer  
 Signature: 

Date: 09.04.2024



- 7.3.5. The licence holder shall be liable to prevent and mitigate against the risk of harm to human health and the environment and shall put in place measures necessary to prevent and/ or mitigate against such risks.
- 7.3.6. PM, SO<sub>2</sub> and NO<sub>x</sub> emissions should be below the limit value within 24 hours of synchronizing with the grid.
- 7.3.7. Reporting on particulate emissions to commence 24 hours after the unit has synchronized with the grid during start-up.
- 7.3.8. During start-up, maintenance and shut-down, or in the event where there is an indication of adverse impacts to human health and/ or the environment the licence holder must take appropriate measures to avoid such adverse impacts from occurring and/ or recurring.
- 7.3.9. Licence holder is operating in the Highveld Priority Area and to put into effect the provision of section 42 of the Act, the Licensing Authority may from time to time review the conditions set herein and may set maximum emission limits to be adhered to by the Licence Holder during start-up, maintenance and shut-down conditions.
- 7.3.10. The licence holder must report on abatement utilization and efficiency monthly.
- 7.3.11. Abatement equipment must be maintained to ensure that is operational when the associated boiler is under normal operating conditions. The utilization values stated in Table 7.1 are applicable when the associated boiler is under normal operating conditions.

#### 7.4. Reporting Group / Emission Unit – emission monitoring and reporting requirements

RG/EU Code	Listed Activity	Pollutant	Emission Sampling/ Monitoring Method	Sampling Testing Frequency	Monitoring Duration)	Parameters to be Measured	Parameters to be Reported	Reporting Frequency
EU001 EU002 EU0021	Subcategory 1.1	PM SO <sub>2</sub> NO <sub>x</sub>	Isokinetic sampling as per Annexure A of GN893 of 22 November 2013	Every two yearly	As per Annexure A of GN893 of 22 November 2013 3 tests, each test must be	PM, SO <sub>2</sub> , NO <sub>x</sub>	PM, SO <sub>2</sub> , NO <sub>x</sub>	Annual

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 26 of 33



EU0022					minimum, one hour and maximum eight hours			
EU0024								
EU0025	Subcategory 1.1	PM	Continuous Emissions Monitoring as per Annexure A of GN893 of 22 November 2013	Continuous Emissions Monitoring	Continuous, min. 80% valid hourly averages.	PM, SO <sub>2</sub> , NO <sub>x</sub>	PM, SO <sub>2</sub> , NO <sub>x</sub>	Monthly
		SO <sub>2</sub>						
		NO <sub>x</sub>						

#### 7.5. Reporting Group / Emission Unit (Area and/or line source) – management and mitigation measures

RG/EU Code	Area and/or Line Source Description	Description of Specific Measures	Timeframe for Achieving Required Control Efficiency	Method of Monitoring Measures Effectiveness	Contingency Measures
EU0028	Ash dump	Dust suppression	NEM: AQA 39 of 2004; National Dust Control Regulations	Fall Out Dust Monitoring and report on or before 30 <sup>th</sup> of every month	In line with approved EMP, Dust Management Plan
EU0027	Storage and handling of coal stockpile	Dust suppression	NEM: AQA 39 of 2004; National Dust Control Regulations	Fall Out Dust Monitoring and report on or before 30 <sup>th</sup> of every month	In line with approved EMP, Dust Management Plan
EU0029	Storage and handling of fuel oil	Enclosed tanks and visual Inspection	NEM:AQA 39 of 2004	NEM:AQA 39 of 2004	In line with the approved, Leak detection and repair Program.

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 27 of 33



EU0030	Ash Storage Silo	Provide maintenance plan of silos within 60 days of issue of the licence	Maintenance Plan	Visual Inspections	In line with the Eskom approved Maintenance plan
EU0026 & EU0031	Ash and Coal Conveyor belts	Conveyors are covered and Visual inspections	NEM: AQA 39 of 2004; National Dust Control Regulations	Fall Out Dust Monitoring and report on or before 30 <sup>th</sup> of every month	In line with approved EMP, Dust Management Plan
EU0032	Limestone storage	Dust suppression	NEM: AQA 39 of 2004; National Dust Control Regulations	Fall Out Dust Monitoring and report on or before 30 <sup>th</sup> of every month	In line with approved EMP, Dust Management Plan
EU0033	Gypsum	Dust suppression	NEM: AQA 39 of 2004; National Dust Control Regulations	Fall Out Dust Monitoring and report on or before 30 <sup>th</sup> of every month	In line with approved EMP, Dust Management Plan

(a) The following special arrangement shall apply for the storage and handling of raw material, intermediate and final products with a vapour pressure greater than 14 kPa at operating temperature: - Leak detection and repair (LDAR) program approved by licensing authority must be instituted.

(b) The following transitional and special arrangement shall apply for control of TVOC's from storage of raw materials, intermediate and final products with vapour pressure of up to 14kPa at operating temperature, except during loading and offloading. (Alternative control measures that can achieve the same or better results may be used) – (i) storage vessels for liquids must be of the following type:

Air Quality Officer  
Signature: 

Date: 09.04.2004

AEL Ref No.: 17/04/AEL/MP311/12/01  
Page 28 of 33



Application	All permanent immobile liquid storage facilities at a single site with a combined storage capacity of greater than 1 000 cubic metres
True vapour of contents at product storage temperature	type of tank or vessels
Type 1: Up to 14 kPa	Fixed roof tank vented to atmosphere, or as per type 2 and 3
Type 2: Above 14 kPa and up to 91 kPa with a throughput of less than 50 000 m <sup>3</sup> per annum	Fixed roof tank with pressure vacuum vents fitted as a minimum to prevent "breathing" losses or as per Type 3
Type 3: Above 14 kPa and up to 91 kPa with a throughput of greater than 50 000 m <sup>3</sup> per annum	(a) External floating roof tank with primary rim seal and secondary rim seal for tank with a diameter greater than 20 m, or (b) Fixed roof tank with internal floating deck/roof fitted with primary seal, or (c) Fixed roof tank with vapour recovery system.
Type 4: Above 91 kPa	Pressure vessel

- (i) The roof legs, slotted pipes and/ or dipping well on floating roof tanks (except for domed floating roof tanks or internal floating roof tanks) shall have sleeves fitted to minimize emissions
  - (ii) Relief valves on pressurised storage should undergo periodic checks for internal leaks. This can be carried out using portable acoustic monitors or if venting to atmosphere with an accessible open end tested with a hydrocarbon analyser as part of the LDAR programme.
- (c) The following special arrangement shall apply for the storage and handling of ore and coal not situated on the premises of a mine or works as defined in the Mines Health and Safety Act 29 of 1996:
- (d) Three months running average of dust fall not to exceed limit value for adjacent land use according to Dust Control Regulations promulgated in section 32 of the NEM: AQA, 2004, in eight principal wind directions.

Air Quality Officer  
Signature: 

Date: 09.04.2024 AEL Ref No.: 17/04/AEL/MP311/12/01  
Page 29 of 33



## 7.6. Routine reporting and record-keeping

### ***Complaints register***

The licence holder must maintain a complaints register at its premises, and such register must be made available for inspections. The complaints register must include the following information on the complainant, namely, the name, physical address, telephone number, date and the time when the complaint was registered. The register should also provide space for noise, dust and offensive odours complaints.

Furthermore, the licence holder is to investigate and, monthly report to the licensing authority in a summarised format on the total number of complaints logged. The complaints must be reported in the following format with each component indicated as may be necessary:

- (a) Source code / name;
- (b) Root cause analysis;
- (c) Calculation of impacts / emissions associated with incidents and dispersion modelling of pollutants, where applicable;
- (d) Measures implemented or to be implemented to prevent recurrence; and
- (e) Date by which measure will be implemented.

The licensing authority must also be provided with a copy of the complaints register. The record of a complaint must be kept for at least 05 (five) years after the complaint was made.

### ***Annual reporting***

The licence holder must complete and submit to the licensing authority an annual report. The report must include information for the year under review (i.e. annual year-end of the company). The report must be submitted to the licensing authority not later than 60 (sixty) days after the end of each reporting period. The annual report must include, amongst others, the following items:

- (a) Pollutant emissions trend;
- (b) Compliance audit report(s);
- (c) Major upgrades projects (i.e. abatement equipment or process equipment);
- (a) Action taken to address complaints received, and

Air Quality Officer

Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 30 of 33



(b) Annual report on implementation of Highveld Priority Areas Air Quality Management Plan, projects and / or offset programs.

The holder of the licence must keep a copy of the annual report for a period of at least 5 (five) years.

**Greenhouse gas Reporting**

Reporting in terms of Section 43 (1) (l) shall be done in accordance with the National Greenhouse Gas Reporting Regulations.

**7.7. Investigation**

The following investigations are required:

Investigation	Purpose	Completion Date
None	None	None

**8. DISPOSAL OF WASTE AND EFFLUENT ARISING FROM ABATEMENT EQUIPMENT CONTROL TECHNOLOGY**

The disposal of any waste and effluent arising from the abatement equipment must comply with the relevant legislation and requirements of the relevant authorities

EU Code	Stack Code	Waste / Effluent Type	Hazardous Components Present	Method of Disposal
EU001,EU002,EU0021,E U0022,EU0024 and EU0025	SV01 –SV06	Ash	Heavy metals	Ash Dump (on-site)
EU001,EU002,EU0021,E U0022,EU0024 and EU0025	SV01 – SV06	Fabric Filter bags	Synthetic material	Registered Hazardous Waste Site
EU0033	SV01 –SV06	Gypsum	Heavy metals	Ash Dump (on-site)

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01



## 9. PENALTIES FOR NON-COMPLIANCE WITH LICENCE AND STATUTORY CONDITIONS AND OR REQUIREMENTS

Failure to comply with any of the licence and relevant statutory conditions and/or requirements is an offence, and license holder, if convicted, will be subjected to those penalties as set out in section 52 of the NEM: AQA.

## 10. APPEAL OF LICENCE

10.1 The Licence Holder must notify every registered interested and affected party, in writing and within ten (10) days, of receiving the Municipal decision.

10.2 The notification referred to in 10.1. must:

10.2.1 Inform the registered interested and affected parties of the appeal procedure provided for in the Municipal Systems Act (Act 32 of 2000);

10.2.2 Advise the interested and affected parties that a copy of the Atmospheric Emission Licence and reasons for the decision will be furnished on request;

10.2.3 An appeal against the decision must be lodged in terms of Section 62 of Municipal Systems Act (Act 32 of 2000), with the Appeal Authority on the following address:

Nkangala District Municipality,  
PO Box 437,  
Middelburg,  
1050

Tel No. 013 249 2000,

Fax No. 013 249 2173

and

Air Quality Officer  
Signature: 

Date: 09.04.2024

AEL Ref No.: 17/04/AEL/MP311/12/01

Page 32 of 33



10.2.4 Specify the date on which the Atmospheric Emission licence was issued.



MR ML MAHLANGU

ACTING GENERAL MANAGER: COMMUNITY DEVELOPMENT SERVICES

NKANGALA DISTRICT MUNICIPALITY

CONFIDENTIAL

Air Quality Officer  
Signature: 

Date: 09.04.2024 AEL Ref No.: 17/04/AEL/MP311/12/01

Page 33 of 33

