	Technical and Generic Report	Matimba Power Station
---	-------------------------------------	------------------------------

Title: **Matimba Power Station January 2026 emissions report**

Document Identifier: **RP/247/069**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **26**

Report Date: **January 2026**



Disclosure Classification: **Controlled**


Compiled by

Reviewed by

Supported by

Authorized by



Helry Ramahlare
Senior Advisor
Environment

MC Mamabolo
Environmental
Manager

Jacky Mathobela
Engineering Manager

Obakeng Mabotja
General Manager

Date: 2026/02/26

Date: 26 February 2026

Date: 2026/02/27

Date: 2026-02-27

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Emissions reporting.....	6
2.3.1 Particulate Matter Emissions.....	6
2.3.2 Gaseous Emissions	9
2.3.2.a SOx Emissions	9
2.3.2.b NOx Emissions.....	11
2.3.3 Total Volatile Organic Compounds	14
2.3.4 Greenhouse gas (CO ₂) emissions	14
2.4 Daily power generated.....	15
2.5 Pollutant Tonnages	18
2.6 Operating days in compliance to PM AEL Limit.....	18
2.7 Operating days in compliance to SOx AEL Limit	19
2.8 Operating days in compliance to NOx AEL Limit	19
2.9 Continuous Emission Monitors.....	19
2.10.1 Changes, downtime, and repairs	20
2.10.2 Sampling dates and times.....	20
2.10 Units Start-up information	22
2.11 Emergency generation	24
2.12 Complaints register.....	25
2.13 Air quality improvements and social responsibility conducted.....	25
Air quality improvements.....	25
Social responsibility conducted.....	25
2.14 Ambient air quality monitoring.....	25
2.15 Electrostatic precipitator and Sulphur plant status.....	25
2.16 General.....	26
3. Attachments.....	26
4. Report Conclusion.....	27
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics.....	6
Table 4: Total volatile compound estimates	14
Table 5: Daily power generated per unit in MWh for the month of January 2026.....	15
Table 6: Pollutant tonnages for the month of January 2026.....	18

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 7: Operating days in compliance with PM AEL limit of January 2026	18
Table 8: Operating days in compliance with SOx AEL limit of January 2026	19
Table 9: Operating days in compliance with NOx AEL limit of January 2026	19
Table 10: Monitor reliability percentage (%)	19
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 6.	20
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO ₂ and NOx for unit 1, 5 and 6) ...	20
Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only.....	21
Table 16: Start-up information	22
Table 17: Emergency generation	24
Table 18: Complaints.....	25

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2026.....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2026.....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2026.....	7
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2026.....	8
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2026.....	8
Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of January 2026	9
Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of January 2026	9
Figure 8: SO ₂ daily average emissions against emission limit for unit 3 for the month of January 2026	10
Figure 9: SO ₂ daily average emissions against emission limit for unit 4 for the month of January 2026	10
Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of January 2026	11
Figure 11: NOx daily average emissions against emission limit for unit 1 for the month of January 2026	11
Figure 12: NOx daily average emissions against emission limit for unit 2 for the month of January 2026	12
Figure 13: NOx daily average emissions against emission limit for unit 3 for the month of January 2026	12
Figure 14: NOx daily average emissions against emission limit for unit 4 for the month of January 2026	13
Figure 15: NOx daily average emissions against emission limit for unit 6 for the month of January 2026	13
Figure 16: Unit 1 daily generated power in MWh for the month of January 2026	16
Figure 17: Unit 2 daily generated power in MWh for the month of January 2026	16
Figure 18: Unit 3 daily generated power in MWh for the month of January 2026	17
Figure 19: Unit 4 daily generated power in MWh for the month of January 2026	17
Figure 20: Unit 6 daily generated power in MWh for the month of January 2026	18

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for January 2026. The information recorded in the report is obtained from Matimba Emission Reporting tool MTB0925ERT.



During the period under review, Matimba experienced four (4) exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$) which occurred within the 48-hour grace period.

There were no exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) and the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$).

Flue gas conditioning plant availability was above 90% for 1,2,3,4 and 6. Unit 6 flue gas conditioning plant (SO_3) was taken out of service from 21/01/2025 at 12:22 due to leak on the Sulphur burner and returned to service after repairs on 22/01/2025 at 18:00.

The consumption rates for fuel oil for the month of January 2026 exceeded the limit of 1200 tons by 3189.78 tons due to multiple units' light ups and combustion support across all operating units.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	799 892.00
	Fuel Oil	Tons/month	1 200	3189.78
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1 458.97
	Ash	Tons/month	547500	257 237.27

- The consumption rates for fuel oil for the month of January 2026 exceeded the permitted maximum limits due to Unit 1 and unit 4 multiple light ups.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.95%
Unit 2	Electrostatic Precipitator	100%	99.79%
Unit 3	Electrostatic Precipitator	100%	99.95%
Unit 4	Electrostatic Precipitator	100%	99.87%
Unit 5	Electrostatic Precipitator	100%	Unit Off-line
Unit 6	Electrostatic Precipitator	100%	99.95%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	96%
Unit 2	SO ₃ Plant	100%	99%
Unit 3	SO ₃ Plant	100%	97%
Unit 4	SO ₃ Plant	100%	99%
Unit 5	SO ₃ Plant	100%	Unit Off-line
Unit 6	SO ₃ Plant	100%	95%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was above 90% for unit 1, 2, 3, 4 and unit 6. All units SO3 plant availability was impacted by the plants was on hold when running with low loads. Unit 6 flue gas conditioning plant (SO3) was taken out of service from 21/01/2025 at 12:22 due to leak on the Sulphur burner and returned to service on 22/01/2025 at 18:00.

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.22%
	Ash Content	40%	32.16%

Energy source characteristics remained within the ranges stipulated in the license.

2.3 Emissions reporting

2.3.1 Particulate Matter Emissions

The emission monitors correlation and parallel tests were performed on unit 2, 3 and 4 in June 2024 and the curves were applied on emissions calculations for January 2026. Unit 1, 5 and 6 emission calculations were done using the correlation/parallel tests curves from the spot test performed in August 2023. Unit 2 PM correlation curve applied is linear curve, Unit 3 and 4 PM correlation curve applied is polynomial curve.

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2026

Interpretation: Unit 1 daily particulate emission remained within the limit of 50 mg/Nm³ for the month of January 2026. On the 19th of December 2025 the unit was taken down for maintenance and returned to service on 7th of January 2026. The PM emission are measured 24 hours after unit startup as per the Atmospheric Emission License, which is the reason for not having a value on the 08 January 2026.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2026

Interpretation: Unit 2 exceeded the daily particulate emission limit of 50 mg/Nm³ on 24 and 28 of January 2026 due to leak identified on the Sulphur burner, the plant was put on permit to work for the repairs and return to service is 28/01/2025. Both exceedances remain within the 48-hour grace period.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2026

Interpretation: Unit 3 daily particulate emission remained within the limit of 50 mg/Nm³ for the month of January 2026.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2026

Interpretation: Unit 4 exceeded the daily particulate emission limit of 50 mg/Nm³ on 9 and 21 of January 2026. The unit was taken down for maintenance on the 28 January 2025 and returned to service on the 06 January 2026, the unit tripped on the 13 January 2026 and returned to service on 15 January 2026 and tripped again on the 20 January 2026.

Unit 5 Particulate Emissions

Unit on outage

Unit 6 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2026

Interpretation: Unit 6 daily particulate emission remained within the limit of 50 mg/Nm³ for the month of January 2026. On the 03th of January 2026 the unit was taken down for maintenance and returned to service on the 05 January 2026.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed on 27 January 2026 as per the Eskom emission standard requirement.

The quality assurance tests (QAL2) used for January 2026 emission calculations were performed in June 2024 for Unit 2,3 and 4. Unit 1,5 and 6 quality assurance curves utilized are spot tests performed in August 2023

2.3.2.a SOx Emissions

Unit 1 SO₂ Emissions




Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of January 2026

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

Unit 2 SO₂ Emissions




Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of January 2026

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³. SRM (Standard Reference Measurements) from the QAL 2 tests report for all the gaseous parameters were used to calculate the SO₂ gaseous emissions for unit 2 in January 2026 due to defective monitor.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO₂ Emissions




Figure 8: SO₂ daily average emissions against emission limit for unit 3 for the month of January 2026

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.SRM (Standard Reference Measurements) for all the gaseous parameters were used to calculate the SO₂ gaseous emissions for unit 3 in January 2026 due to defective monitor.

Unit 4 SO₂ Emissions




Figure 9: SO₂ daily average emissions against emission limit for unit 4 for the month of January 2026

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO₂ Emissions

Unit on outage

Unit 6 SO₂ Emissions




Figure 10: SO₂ daily average emissions against emission limit for unit 6 for the month of January 2026

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

2.3.2.b NO_x Emissions

Unit 1 NO_x Emissions




Figure 11: NO_x daily average emissions against emission limit for unit 1 for the month of January 2026

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO_x Emissions




Figure 12: NO_x daily average emissions against emission limit for unit 2 for the month of January 2026

Interpretation: All daily averages below Nox emission monthly limit of 750 mg/Nm³. SRM (Standard Reference Measurements) from the QAL 2 tests report for all the gaseous parameters were used to calculate the NO_x gaseous emissions for unit 2 in January 2026 due to defective monitor.

Unit 3 NO_x Emissions




Figure 13: NO_x daily average emissions against emission limit for unit 3 for the month of January 2026

Interpretation: All daily averages below Nox emission monthly limit of 750 mg/Nm³. SRM (Standard Reference Measurements) from the QAL 2 tests report for all the gaseous parameters were used to calculate the NO_x gaseous emissions for unit 3 in January 2026 due to defective monitor.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO_x Emissions




Figure 14: NO_x daily average emissions against emission limit for unit 4 for the month of January 2026

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 5 NO_x Emissions

Unit on outage

Unit 6 NO_x Emissions




Figure 15: NO_x daily average emissions against emission limit for unit 6 for the month of January 2026

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

 CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Thursday, 19 February 2026	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
MONTHLY INPUT DATA FOR THE STATION Please only insert relevant monthly data inputs into the <i>blue cells</i> below Choose from a dropdown menu in the <i>green cells</i> The total VOC emissions for the month are in the <i>red cells</i> IMPORTANT: Do not change <i>any</i> other cells without consulting the AQ CoE		
MONTH:	September	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	3189.790	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	23.43	°C
Daily maximum ambient temperature	31.06	°C
Daily minimum ambient temperature	16.52	°C
Daily ambient temperature range	14.54	°C
Daily total insolation factor	4.41	kWh/m ² /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0.68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0.54	kg/month
Working losses:	0.09	kg/month
TOTAL LOSSES (Total TVOC Emissions for the month):	0.63	kg/month
<small>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</small>		

2.3.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4 Daily power generated.

Table 5: Daily power generated per unit in MWh for the month of January 2026

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2026/01/01	0	9499.8	9996.82	0	0	9143.68
2026/01/02	0	9450.3	12427.9	0	0	1109.64
2026/01/03	6691.96	9587.84	11525.2	0	0	0
2026/01/04	478.905	9230.08	12487	0	0	0
2026/01/05	0	8609.31	12200.4	0	0	0
2026/01/06	0	9483.1	12410.8	0	0	9765.61
2026/01/07	0	8818.31	12425.9	8318.83	0	10311.3
2026/01/08	5475.04	8527.76	12487.4	9332.89	0	10974.5
2026/01/09	7658.86	8444.6	10854.5	9847.39	0	10470.4
2026/01/10	9905.02	8514.51	10124	9541.26	0	9332.39
2026/01/11	10265.2	8465.11	10650.4	9017.22	0	10666.7
2026/01/12	10613.1	8504.64	12097.8	1797.91	0	10724.2
2026/01/13	10323.8	9321.09	12232.6	0	0	11136.7
2026/01/14	9767.32	8857.64	12269.2	0	0	11627.4
2026/01/15	10780.6	8130.18	6749.63	6965.71	0	10356.7
2026/01/16	10230.5	9394.57	10740.9	9033.31	0	9342.31
2026/01/17	9476.97	9219.7	9910.28	7972.86	0	9801.97
2026/01/18	9014.37	8881.74	9753.01	7757.69	0	9883.89
2026/01/19	9458.58	10376.4	11529.5	5637.8	0	10909.8
2026/01/20	10634.3	10806	12529.8	5255.71	0	11321.1
2026/01/21	9733.29	10943.5	10903	8856	0	10538.2
2026/01/22	10178.1	9456.97	10341.6	9749.15	0	9586.54
2026/01/23	11640.8	9946.34	11871.9	9950.99	0	9436.94
2026/01/24	12751.6	10176	11811.4	9290.42	0	10734.5
2026/01/25	12463.3	8009.22	11432.2	9382.71	0	10877.5
2026/01/26	12544.7	9495.29	11520.6	9611.01	0	10746.1
2026/01/27	11595.3	9003.83	11406.5	8952.51	0	9934.58
2026/01/28	10720.6	8572.49	11130.2	8899.71	0	10880.7
2026/01/29	10659.7	8445.07	10761.5	9256.42	0	11096
2026/01/30	9558.92	9250.91	10298.6	8451.41	0	9121.54
2026/01/31	9895.89	9393.24	9444.03	8713.61	0	9217

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of January 2026




Figure 17: Unit 2 daily generated power in MWh for the month of January 2026

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 3 daily generated power in MWh for the month of January 2026




Figure 19: Unit 4 daily generated power in MWh for the month of January 2026

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 6 daily generated power in MWh for the month of January 2026

2.5 Pollutant Tonnages

The emitted pollutant tonnages for January 2026 are provided in table 6.

Table 6: Pollutant tonnages for the month of January 2026

Associated Unit/Stack	PM (tons)	SO2 (tons)	NOx (tons)
Unit 1	18.2	3 148	522
Unit 2	103.6	8 319	1 388
Unit 3	24.0	4 356	704
Unit 4	42.1	3 969	758
Unit 5	Unit off	Unit off	Unit off
Unit 6	27.2	2 276	287
SUM	215.07	22 068	3 660

2.6 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of January 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm³)
Unit 1	23	0	0	0	0	14.5
Unit 2	29	2	0	0	2	40.0
Unit 3	31	0	0	0	0	17.5
Unit 4	18	2	0	0	2	36.2
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	28	0	0	0	0	29.4
SUM	129	4	0	0	4	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.7 Operating days in compliance to SOx AEL Limit

Table 8: Operating days in compliance with SOx AEL limit of January 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	26	0	0	0	0	383.7
Unit 2	31	0	0	0	0	536.4
Unit 3	31	0	0	0	0	501.2
Unit 4	23	0	0	0	0	543.8
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	29	0	0	0	0	296.7
SUM	140	0	0	0	0	

2.8 Operating days in compliance to NOx AEL Limit

Table 9: Operating days in compliance with NOx AEL limit of January 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Limit Value	Mnth Avg (mg/Nm ³)
Unit 1	26	0	0	0	0	3500	2 294.3
Unit 2	31	0	0	0	0	3500	3 214.1
Unit 3	31	0	0	0	0	3500	3 100.0
Unit 4	23	0	0	0	0	3500	2 842.3
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	29	0	0	0	0	3500	2 339.9
SUM	140	0	0	0	0		

2.9 Continuous Emission Monitors

Table 10: Monitor reliability percentage (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	93.1	100.0	85.5	100.0
Unit 2	100.0	100.0	100.0	100.0
Unit 3	94.7	100.0	100.0	100.0
Unit 4	99.8	99.1	99.1	100.0
Unit 5	Unit off	Unit off	Unit off	Unit off
Unit 6	100.0	71.1	68.7	100.0

Note: NO_x emissions are measured as NO in PPM. The final NO_x value is expressed as total NO₂ equivalent.

Comments:

Unit 2 and 3 gaseous monitor reliability was 100% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 2 and 3.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.1 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 3

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 4

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 5

- Unit off load.

Unit 6

- No adjustments done on the CEMs.
- Correlation test done in September 2025

2.10.2 Sampling dates and times

Table 11: Dates of last full conducted CEMS verification tests for PM for unit 6.

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
6	2020/09/09 06h41	New sampling tests in table 14	New sampling tests in table 14	New sampling tests in table 14

Table 12: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x for unit 1, 5 and 6)

Name of service provider:	Levego Environmental services
Address of service provider:	Building R6 Pineland site Ardeer Road

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

		Modderfontein 1645		
Stack/ Unit	PM	SO ₂	NO _x	CO ₂
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 13 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

Note: The CEMS Spot verification tests for PM, SO₂ and NO_x were performed in August 2023. PM spot verification test results for unit 6 failed and old curves are still in use.

Table 13: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

Name of service provider:		Levego Environmental services		
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645		
Stack/ Unit	PM	SO ₂	NO _x	CO ₂
2	2024/07/02 08h50	2024/07/02 12h35	2024/07/02 12h35	2024/07/02 12h35
3	2024/06/23 16h34	2024/06/23 14h00	2024/06/23 14h00	2024/06/23 14h00
4	2024/06/29 16h05	2024/06/29 11h00	2024/06/29 11h00	2024/06/29 11h00

Name of service provider:		Inthuu Measurement		
Address of service provider:		2/410 Seventh Road Bredell Kepton park 1619		
Stack/ Unit	PM	SO ₂	NO _x	CO ₂
6		2025/08/13 16h26	2025/08/13 16h26	2025/08/13 16h26

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10 Units Start-up information

Table 14: Start-up information

Unit	1	
Fires in	2026/01/02	12h04
Synchronization with Grid	2026/01/03	05h30
Emissions below limit	2026/01/04	03h16
Fires in, to synchronization	17.26	HOURS
Synchronization to < Emission limit	2.14	HOURS

Unit	1	
Fires in	2026/01/07	09h45
Synchronization with Grid	2026/01/08	03h46
Emissions below limit	2026/01/08	11h03
Fires in, to synchronization	18.1	HOURS
Synchronization to < Emission limit	7.17	HOURS

Unit	3	
Fires in	2026/01/15	09h00
Synchronization with Grid	2026/01/15	11h06
Emissions below limit	2026/01/15	13h03
Fires in, to synchronization	2.6	HOURS
Synchronization to < Emission limit	1.57	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	4	
Fires in	2026/01/06	16h49
Synchronization with Grid	2026/01/07	00h07
Emissions below limit	2026/01/07	18h02
Fires in, to synchronization	7.18	HOURS
Synchronization to < Emission limit	17.55	HOURS

Unit	4	
Fires in	2026/01/19	10h09
Synchronization with Grid	2026/01/19	15h18
Emissions below limit	2026/01/19	16h07
Fires in, to synchronization	5.9	HOURS
Synchronization to < Emission limit	0.49	HOURS

Unit	4	
Fires in	2026/01/14	22h48
Synchronization with Grid	2026/01/15	18h26
Emissions below limit	2026/01/15	22h01
Fires in, to synchronization	19.38	HOURS
Synchronization to < Emission limit	3.35	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	4	
Fires in	2026/01/20	01h38
Synchronization with Grid	2026/01/20	06h48
Emissions below limit	2026/01/20	10h09
Fires in, to synchronization	5.10	HOURS
Synchronization to < Emission limit	3.21	HOURS

Unit	6	
Fires in	2026/01/06	15h40
Synchronization with Grid	2026/01/05	22h42
Emissions below limit	2026/01/06	08h04
Fires in, to synchronization	7.20	HOURS
Synchronization to < Emission limit	9.22	HOURS

2.11 Emergency generation

Table 15: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	744	744	744	744	0	744
Emergency Hours declared including hours after standing down	592	744	735	517	0	653
Days over the Limit during Emergency Generation	0	2	0	2	0	0

During the period under review all Units were on emergency generation in force from 01 January 2026 until 31 January 2026.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.12 Complaints register.

Table 16: Complaints

Source Name	Code/ Cause	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None						

2.13 Air quality improvements and social responsibility conducted.

Air quality improvements

None

Social responsibility conducted.

None

2.14 Ambient air quality monitoring

The January 2026 ambient air quality monitoring report is attached to this report as an addendum.

2.15 Electrostatic precipitator and Sulphur plant status

Unit 1

- No issues on precipitators.
- The SO₃ plant operated normally with no abnormalities observed.

Unit 2

- Precipitator internal damage to be repaired during next opportunity.
- The SO₃ plant operated normally with no abnormalities observed.

Unit 3

- No issues with precipitators.
- The SO₃ plant operated normally with no abnormalities observed.

Unit 4

- No issues with precipitators.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- The SO₃ plant operated normally with no abnormalities observed.

Unit 5

- Unit on outage.

Unit 6

- Precipitator internal damage to be repaired during next opportunity.
- The SO₃ plant operated normally with no abnormalities observed.

SO₃ common plant

- The SO₃ common plant is operating normally with no abnormalities observed.

2.16 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. Eskom internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

- Fugitive dust falls out monitoring report.
- Marapong ambient air quality report

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

Wikus van Rensburg

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document August be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.