



Ms Nompumelelo Simelane
Nkangala District Municipality
PO Box 437
Middleburg
1050

Date:

March 2026

Enquiries: Lesiba Kgobe
Tel: +27 13 699 7817

Ref: *Kusile Power Station AEL (17/4/AEL/MP311/12/01)*


Dear Ms. Simelane

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026

This serves as the monthly report required in terms of Section 7.6 in Kusile Power Station's Atmospheric Emission License: 17/4/AEL/MP311/12/01. The emissions are for the month of February 2026.

Hoping the above will meet your satisfaction.


Yours sincerely



Christopher Nani
GENERAL MANAGER
DATE: *2026-03-30*

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026 -
17/4/AEL/MP311/12/01

**1. KUSILE POWER STATION MONTHLY EMISSIONS REPORT: Atmospheric Emission
License 17/4/AEL/MP311/12/01**



2. Raw Materials and Products

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Feb-2026
	Coal	Tons	1 818 083	788 371
	Fuel Oil	Tons	5 533	4 331.61
	Limestone	Tons	72 017	32 118

Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Feb-2026
	Energy	GWh	3 321.216	1 524.02
	Ash	Tons	796 300	276 228
	Gypsum	Tons	155 100	17 987
	RE PM	kg/MWh	not specified	0.02
	RE SOx	kg/MWh	not specified	0.37

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [4 464 MW] x 24 hrs x days in Month/1000 to convert to GWh

3. Energy source characteristics

Fuel Characteristic	Units	Stipulated Range	Monthly Average Content
Coal Sulphur	%	1.3	1.03
Ash in Coal	%	38	35.04
Fuel Oil Sulphur	%	3.5	2.51

4. Emissions Limits (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North Stack	50	1000	750
South Stack	50	1000	750

5. Abatement Technology (%)

Associated Unit/Stack	Technology Type	FFP Efficiency	Technology Type	FGD Efficiency
Unit 1	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.89%
Unit 2	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.94%
Unit 3	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.95%
Unit 4	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.97%
Unit 5	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.99%
Unit 6	Fabric Filter Plant (FFP)	99.99%	Flue Gas Desulphurisation (FGD)	99.97%

Note: The FFP and FGD plant does not have a bypass mode; therefore, it operates at 100% utilization.

6. Monitoring reliability (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	100.0	100.0	99.3
Unit 2	100.0	100.0	100.0
Unit 3	100.0	100.0	100.0
Unit 4	99.7	99.1	99.1
Unit 5	99.8	96.4	99.2
Unit 6	93.5	99.3	99.3

Note: NO_x emissions are measured as NO in PPM. The final NO_x value is expressed as total NO₂ equivalent.

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026 -
17/4/AEL/MP311/12/01

7. Emissions Performance

Table 7.1: Monthly tonnages for the month of February - 2026

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	0.5	58	99
Unit 2	4.6	136	366
Unit 3	6.4	165	615
Unit 4	7.8	94	448
Unit 5	3.7	28	327
Unit 6	0.8	81	510
SUM	23.79	562	2 364

Table 7.2: PM AEL Daily Compliance – February 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	4	0	0	0	0	3.3
Unit 2	23	0	0	0	0	4.3
Unit 3	26	0	0	0	0	3.7
Unit 4	28	0	0	0	0	3.8
Unit 5	19	0	0	0	0	3.8
Unit 6	23	0	0	0	0	0.6
SUM	123	0	0	0	0	

Table 7.3: SO₂ AEL Daily & Monthly Compliance – February 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	6	0	0	0	0	211.0
Unit 2	25	0	0	0	0	104.3
Unit 3	27	0	0	0	0	88.4
Unit 4	28	0	0	0	0	44.5
Unit 5	21	0	0	0	0	26.7
Unit 6	23	0	0	0	0	54.0
SUM	130	0	0	0	0	



Table 7.4: NO_x AEL Daily Compliance – February 2026




Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	6	0	0	0	0	394.8
Unit 2	25	0	0	0	0	308.0
Unit 3	27	0	0	0	0	340.2
Unit 4	28	0	0	0	0	216.2
Unit 5	21	0	0	0	0	307.4
Unit 6	23	0	0	0	0	353.7
SUM	130	0	0	0	0	




KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026 - 17/4/AEL/MP311/12/01




Table 7.5: Legend Description




Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions



















8. Correlation and Parallel test status

Unit 1:

- Unit 1 is operating with valid correlation curves and parallel factors.

Unit 2:

- Unit 2 is operating with valid correlation curves and parallel factors.

Unit 3

- Unit 3 is operating with valid correlation curves and parallel factors.

Unit 4:

- Unit 4 is operating with valid correlation curves and parallel factors.

Unit 5

- Unit 5 is operating with valid correlation curves and parallel factors.

Unit 6

- Unit 6 is operating with valid correlation curves and parallel factors

9. Shut down and Light up information

Event Description		Event 1		Event 2	
Unit 1	Breaker Open (BO)	3:05 pm	2026/02/01	2:40 am	2026/02/06
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM
	Fires in time				
	Synch. to Grid (or BC)	3:15 am	2026/02/03		
	Fires in to BC (duration)		DD:HH:MM		DD:HH:MM
	Emissions below limit from BC (end date)				
	Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM

Event Description		Event 1		Event 2		Event 3	
Unit 2	Breaker Open (BO)	8:05 pm	2026/02/07	9:50 am	2026/02/19	4:15 pm	2026/02/26
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM
	Fires in time						
	Synch. to Grid (or BC)						
	Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM
	Emissions below limit from BC (end date)						
	Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026 -
17/4/AEL/MP311/12/01

Event Description	Event 1		
Unit 3	Breaker Open (BO)	4:25 pm	2026/01/29
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM
	Fires in time		
	Synch. to Grid (or BC)		
	Fires in to BC (duration)		DD:HH:MM
	Emissions below limit from BC (end date)		
	Emissions below limit from BC (duration)		DD:HH:MM

Event Description	Event 1		
Unit 5	Breaker Open (BO)	9:30 pm	2026/02/12
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM
	Fires in time		
	Synch. to Grid (or BC)		
	Fires in to BC (duration)		DD:HH:MM
	Emissions below limit from BC (end date)		
	Emissions below limit from BC (duration)		DD:HH:MM

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR FEBRUARY 2026 -
17/4/AEL/MP311/12/01

Event Description	Event 1		
Unit 6	Breaker Open (BO)	11:30 pm	2026/02/23
	Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM
	Fires in time		
	Synch. to Grid (or BC)		
	Fires in to BC (duration)		DD:HH:MM
	Emissions below limit from BC (end date)		
	Emissions below limit from BC (duration)		DD:HH:MM

10.Complaints

There were no complaints for the month of February 2026

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence
No complaints reported for the month of February 2026.				