

Mr. Mcebo Mkhathshwa
Air Quality Officer
Fezile Dabi District Municipality
P.O Box 10
SASOLBURG
1947

Date:
30 March 2026

Enquiries:
S Xulu
Tel +27 16 457 5947

LRP09PLA009 _0511/2026/03/16

Dear Mr. Mkhathshwa

LETHABO POWER STATION EMISSION MONTHLY REPORT FOR FEBRUARY 2026

Please find attached Lethabo Power Station emission report for the month of February 2026.

Also attached are the Ambient Air Quality Monitoring Report, Complaints Register and the Fugitive Dust Fallout Monitoring Report for February 2026.

For any additional information please do not hesitate to contact us.

Yours sincerely



Karabo Rakgolela
POWER STATION GENERAL MANAGER



Report

Lethabo Power Station

Report name: **Lethabo Power Station
FEBRUARY 2026
Emission Report**

Reference number: **LRP09PLA009_0511/2026/03/16**
Document Type: **Report**
Area of Applicability: **Environment**
Report Date: **March-2026**
Classification: **Controlled Disclosure**

Signatures:

Compiled by:

S Zulu
Boiler Engineer

Date: 25/03/2026

Verified by :

S Xulu
Environmental Officer

Date: 2026/03/25

Reviewed by:

C. Govinden
BPE Manager

Date: 2026/03/25

Reviewed by:

P Malinga
PE Manager

Date: 2026/03/26

Reviewed by:

L Nel
C&I Manager

Date: 2026-03-27

Reviewed by:

M Hariram
Environmental Manager

Date: 2026 03 30

Reviewed by:

T. Njapha
Engineering Manager

Date: 2026-03-30

CONTROLLED DISCLOSURE

When downloaded from the database, this document is uncontrolled and it is the responsibility of the user to ensure that it is the same as the authorised revision on the data base
Copyright © 2008, Eskom Generation, Lethabo Power Station

LETHABO POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License: FDDM-MET-2011-08-P1-E1



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Feb-2026
	Coal	Tons	2 000 000	1 186 541
Fuel Oil	Tons	3 700	886	

Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Feb-2026
	Energy	GWh	2 560	1 581
Ash	Tons	940 000	458 598	
RE Ash	kg/MWh	not specified	0.559	

Note: Max energy rate = AEL capacity [3,810 MW] × 24 Hrs × Days in MONTH ÷ 1,000 (to convert to GWh).

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1.2	0.690
Ash Content	%	<47	39

Note: The "standard" is not a fixed limit but an optimal guideline. It may vary with coal quality. The stipulated range reflects station acceptance test values.

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	Daily Limit		
	PM	SO ₂	NO _x
Unit 1	100	2600	1100
Unit 2	100	2600	1100
Unit 3	100	2600	1100
Unit 4	100	2600	1100
Unit 5	100	2600	1100
Unit 6	50	2600	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	ESP Efficiency	Technology Type	SO ₃ Plant Utilization
Unit 1	ESP + SO ₃	99.682%	SO ₃	100.0%
Unit 2	ESP + SO ₃	99.906%	SO ₃	99.8%
Unit 3	ESP + SO ₃	99.836%	SO ₃	99.8%
Unit 4	ESP + SO ₃	99.574%	SO ₃	100.0%
Unit 5	ESP + SO ₃	99.928%	SO ₃	91.7%
Unit 6	ESP + SO ₃	99.873%	SO ₃	99.7%

Note: The ESP plant does not have a bypass mode; therefore, it operates at 100% utilization.

5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	99.1	99.8	99.9	99.7
Unit 2	100.0	99.8	97.9	99.5
Unit 3	100.0	100.0	100.0	99.8
Unit 4	99.7	100.0	92.4	100.0
Unit 5	99.7	100.0	100.0	100.0
Unit 6	100.0	100.0	100.0	100.0

Note: NO_x emissions are measured as NO in PPM. The final NO_x value is expressed as total NO₂ equivalent.

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for February 2026

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	285.0	3 424	1 723
Unit 2	62.3	2 348	812
Unit 3	113.9	3 540	1 651
Unit 4	289.6	3 410	1 526
Unit 5	26.7	1 955	654
Unit 6	105.6	3 927	1 956
SUM	883.09	18 604	8 322

Table 6.2: PM AEL Daily Compliance - February 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	15	10	0	3	13	148.4
Unit 2	21	0	0	0	0	47.8
Unit 3	22	2	0	0	2	68.3
Unit 4	9	14	0	4	18	165.5
Unit 5	12	0	0	0	0	35.1
Unit 6	18	9	0	1	10	48.3
SUM	97	35	0	8	43	

Table 6.3: SO₂ AEL Daily Compliance - February 2026

Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	28	0	0	0	0	1 767.0
Unit 2	23	0	0	0	0	1 611.7
Unit 3	25	0	0	0	0	2 053.2
Unit 4	27	0	0	0	0	2 008.2
Unit 5	17	0	0	0	0	2 158.0
Unit 6	27	0	0	0	0	1 930.6
SUM	147	0	0	0	0	

Table 6.4: NO_x AEL Daily Compliance - February 2026


Associated Unit/Stack	Normal	Grace	Section 30	NC	Total Exceedance	Mnth Avg (mg/Nm ³)
Unit 1	28	0	0	0	0	882.1
Unit 2	23	0	0	0	0	557.5
Unit 3	24	1	0	0	1	948.3
Unit 4	27	0	0	0	0	892.7
Unit 5	17	0	0	0	0	664.7
Unit 6	27	0	0	0	0	948.8
SUM	146	1	0	0	1	

Note: Daily limit compliance is shown in the bar charts; monthly compliance is summarized in the table above.

Table 6.5: Legend Description

Condition	Colour	Description
Normal	GREEN	Emissions below Emission Limit Value (ELV)
Grace	BLUE	Emissions above the ELV during grace period
Section 30	ORANGE	Emissions above ELV during a NEMA S30 incident
Contravention	RED	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Lethabo Unit 1 PM Emissions - February 2026



Reasons:	
Date	Description
08-Feb	Poor ESP LHI casing performance. Poor coal quality.
09-Feb	Poor ESP LHI casing performance. Clean rapping brought forward.
13-Feb	LHI ESP casing poor performance. Test rapping carried out.
14-Feb	LHI ESP casing poor performance. LHI casing isolated. Test rapping done.
16-Feb	LHI ESP casing poor performance. Clean rapping done.
19-Feb	ESP casings poor performance.
20-Feb	ESP casings poor performance. Clean rapping done.
22-Feb	LHI ESP casing Outage. Clean rapping done.
24-Feb	LHI ESP casing poor performance.
25-Feb	LHI ESP casing poor performance.
26-Feb	Poor ESP casings performance.
27-Feb	ESP Casing poor performance.
28-Feb	ESP Casing poor performance. LHO ESP casing performance.

Figure 2: Lethabo Unit 2 PM Emissions - February 2026






Figure 3: Lethabo Unit 3 PM Emissions - February 2026



Date	Description
23-Feb	Poor ESP casing performance. High hopper levels.
24-Feb	Poor ESP casing performance. High hopper levels. SO3 plant off due to low sec air heater temps. Test rapping done.

Figure 4: Lethabo Unit 4 PM Emissions - February 2026



Reasons:	
Date	Description
02-Feb	Poor ESP casing performance.
04-Feb	ESP casing outage (RHO) Poor ESP Casing Performance.
05-Feb	ESP casing outage (RHO) Poor ESP Casing Performance.
07-Feb	Poor ESP casing performance.
08-Feb	Clean rapping brought forward.
10-Feb	Clean rapping brought forward. Poor ESP Casing performance.
12-Feb	Clean rapping brought forward. Poor ESP Casing performance.
14-Feb	Poor ESP casing performance.
15-Feb	Poor ESP casing performance.
17-Feb	ESP casing performance.
19-Feb	Poor ESP casing performance.
20-Feb	LHO ESP casing on forced cooling for inspection and repairs.
22-Feb	Poor ESP casing performance.
23-Feb	DHP problems.
24-Feb	Poor ESP casing performance. 2 x hgh hopper levels. Clean rapping done.
25-Feb	Poor ESP casing performance.
26-Feb	Poor ESP casing performance. RHO ESP casing performance.
27-Feb	Poor ESP casing performance. Boiler tripped manually.

Figure 5: Lethabo Unit 5 PM Emissions - February 2026





Figure 6: Lethabo Unit 6 PM Emissions - February 2026



Reasons:	
Date	Description
02-Feb	Poor ESP casing performance. Clean rapping brought forward.
04-Feb	Poor ESP casing performance.
05-Feb	Poor ESP casing performance.
10-Feb	Poor ESP casing performance. High hopper levels.
11-Feb	Poor ESP casing performance.
13-Feb	Poor ESP casing performance.
19-Feb	Poor ESP casing performance.
20-Feb	Poor ESP casing performance. Clean rapping done.
25-Feb	Poor ESP casing performance. 2 x high hopper levels.
26-Feb	Poor ESP casing performance.
27-Feb	Poor ESP casing performance. Sulphur flow dropped to zero due to low load conditions.




Figure 8: Lethabo Unit 2 SO₂ Emissions - February 2026




Figure 9: Lethabo Unit 3 SO₂ Emissions - February 2026




Figure 10: Lethabo Unit 4 SO₂ Emissions - February 2026




Figure 11: Lethabo Unit 5 SO₂ Emissions - February 2026




Figure 12: Lethabo Unit 6 SO₂ Emissions - February 2026




Figure 13: Lethabo Unit 1 NO_x Emissions - February 2026




Figure 14: Lethabo Unit 2 NO_x Emissions - February 2026





Figure 15: Lethabo Unit 3 NO_x Emissions - February 2026



Reasons:	
Date	Description
19-Feb	Station does not have NO _x abatement technology in place

Figure 16: Lethabo Unit 4 NO_x Emissions - February 2026




Figure 17: Lethabo Unit 5 NO_x Emissions - February 2026





Figure 18: Lethabo Unit 6 NO_x Emissions - February 2026



7 SHUT-DOWN AND LIGHT-UP INFORMATION FOR FEBRUARY 2026

See Events sheet

8. MAINTENANCE

Unit 1				
Beginning of	2026/02/22 00:08:00			
Reason for Maintenance	LHI casing repairs.			
End (Time):	2026/02/22 18:54:00			
Duration	18:46:00			

Unit 2				
Beginning of				
Reason for Maintenance				
End (Time):				
Duration				

Unit 3				
Beginning of				
Reason for Maintenance				
End (Time):				
Duration				

Unit 4				
Beginning of	2026/02/04 00:00:00	2026/02/20 00:00:00		
Reason for Maintenance	RHO casing repairs.	LHO casing repairs.		
End (Time):	2026/02/04 23:59:00	2026/02/20 23:47:00		
Duration	23:59:00	23:47:00		

Unit 5				
Beginning of				
Reason for Maintenance				
End (Time):				
Duration				

Unit 6				
Beginning of				
Reason for Maintenance				
End (Time):				
Duration				

9 COMPLAINTS

There were no complaints

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence
--------------------	---------------------	---	--	--

10 GENERAL

Unit 2: Monitor Reliability

17/02/2026: NOx monitor reliability low due to Monitor faulty.

Unit 1:

On the 26/02/2026, unit 1 registered a non-compliance as the unit exceeded for greater than 48 hrs upset conditions due to ESP plant issues.

Unit 4:

On the 24/02/2026, unit 4 registered a non-compliance as the unit exceeded for greater than 48 hrs upset conditions due to poor ESP casing performance.

Unit 6:

On the 27/02/2026, unit 4 registered a non-compliance as the unit exceeded for greater than 48 hrs upset conditions due to poor ESP casing performance and Sulphur flow dropped to zero due to low load conditions.

ADDENDUM TO MONTHLY EMISSIONS REPORT

13. AVAILABILITY

ESP utilisation

Availability												
Month	Unit 1	Days Affected	Unit 2	Days Affected	Unit 3	Days Affected	Unit 4	Days Affected	Unit 5	Days Affected	Unit 6	Days Affected
Feb-25	99.18%	0.9	99.84%	0.2	100.00%	0.0	100.00%	0.0	#####	0.0	98.90%	1.24
Mar-25	98.08%	2.38	99.27%	0.91	98.99%	1.25	100.00%	0.00	#####	5.55	100.00%	0.00
Apr-25	98.21%	2.15	100.00%	0.00	100.00%	0.00	100.00%	0.00	#####	3.00	98.48%	1.82
May-25	99.33%	0.8	100.00%	0.0	97.26%	3.4	100.00%	0.0	#####	0.0	100.00%	0.00
Jun-25	98.12%	2.3	100.00%	0.0	100.00%	0.0	100.00%	0.0	99.16%	1.0	100.00%	0.00
Jul-25	97.94%	2.6	100.00%	0.0	100.00%	0.0	98.82%	1.5	98.41%	2.0	100.00%	0.00
Aug-25	97.72%	2.8	100.00%	0.0	99.62%	0.5	99.33%	0.8	98.18%	2.3	100.00%	0.00
Sept-25	96.23%	4.5	100.00%	0.0	100.00%	0.0	100.00%	0.0	#####	0.0	99.17%	1.0
Oct-25	100.00%	0.0	100.00%	0.0	99.21%	1.0	99.19%	1.0	#####	0.0	100.00%	0.0
Nov-25	97.77%	2.7	100.00%	0.0	100.00%	0.0	98.31%	2.0	#####	0.0	100.00%	0.0
Dec-25	98.27%	2.1	100.00%	0.0	100.00%	0.0	100.00%	0.0	97.58%	3.0	98.53%	1.8
Jan-26	98.27%	2.1	100.00%	0.0	100.00%	0.0	100.00%	0.0	97.58%	3.0	98.53%	1.8
Feb-26	99.30%	0.8	100.00%	0.0	100.00%	0.0	98.22%	2.0	#####	0.0	100.00%	0.0

SO3 plant utilisation

Availability												
Month	Unit 1	Days Affected	Unit 2	Days Affected	Unit 3	Days Affected	Unit 4	Days Affected	Unit 5	Days Affected	Unit 6	Days Affected
Feb-25	91.37%	2.4	95.28%	1.3	67.36%	9.14	95.45%	1.3	91.35%	2.4	97.77%	0.62
Mar-25	98.52%	0.5	96.36%	1.1	85.05%	4.63	98.61%	0.4	99.91%	0.0	88.42%	3.59
Apr-25	95.63%	1.3	OFF	OFF	89.52%	3.15	85.62%	4.3	88.61%	3.4	99.78%	0.07
May-25	95.99%	1.2	OFF	OFF	98.12%	0.58	99.01%	0.3	99.52%	0.1	98.36%	0.51
Jun-25	99.86%	0.0	OFF	OFF	99.25%	0.22	99.83%	0.1	98.19%	0.5	99.22%	0.24
Jul-25	99.87%	0.0	OFF	OFF	99.06%	0.29	100.00%	0.0	98.79%	0.4	66.67%	10.33
Aug-25	99.73%	0.1	OFF	OFF	96.41%	1.11	98.87%	0.4	99.87%	0.0	98.06%	0.60
Sept-25	99.17%	0.2	94.99%	1.5	99.31%	0.21	95.14%	1.5	86.85%	3.9	98.73%	0.4
Oct-25	99.54%	0.1	99.04%	0.3	93.28%	2.08	93.04%	2.2	OFF	OFF	98.96%	0.3
Nov-25	97.96%	0.6	99.97%	0.0	98.06%	0.58	87.67%	3.7	OFF	OFF	96.77%	1.0
Dec-25	97.92%	0.6	97.39%	0.8	89.91%	3.13	98.00%	0.6	OFF	OFF	95.34%	1.4
Jan-26	97.98%	0.6	96.81%	1.0	99.16%	0.26	94.41%	1.7	Off-line	#VALUE!	96.20%	1.2
Feb-26	100.00%	0.0	99.80%	0.1	99.83%	0.05	100.00%	0.0	91.67%	2.3	99.70%	0.1

ADDENDUM TO MONTHLY EMISSIONS REPORT

Particulate Emission Monitors

Availability						
	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Feb-25	98.72%	97.70%	85.64%	99.62%	93.53%	98.72%
Mar-25	93.15%	96.04%	96.08%	99.85%	92.61%	97.36%
Apr-25	98.70%	OFF	99.50%	90.90%	96.10%	99.10%
May-25	100.00%	OFF	98.70%	100.00%	98.90%	100.00%
Jun-25	98.50%	OFF	98.10%	99.80%	99.80%	99.20%
Jul-25	100.00%	OFF	100.00%	100.00%	98.40%	66.70%
Aug-25	99.90%	Exempt	96.30%	99.80%	99.50%	99.20%
Sept-25	100.00%	99.70%	100.00%	99.90%	92.70%	99.60%
Oct-25	100.00%	95.30%	97.80%	100.00%	OFF	99.70%
Nov-25	99.60%	99.80%	98.50%	99.20%	OFF	100.00%
Dec-25	98.90%	97.30%	97.10%	99.40%	OFF	99.50%
Jan-26	98.30%	100.00%	99.60%	99.80%	OFF	100.00%
Feb-26	99.10%	100.00%	100.00%	99.70%	99.70%	100.00%

Gaseous Emission Monitors

Month	Availability											
	Unit 1		Unit 2		Unit 3		Unit 4		Unit 5		Unit 6	
	SOx	NOx	SOx	NOx	SOx	NOx	SOx	NOx	SOx	NOx	SOx	NOx
Jan-25	99.3%	99.1%	99.3%	99.3%	0.0%	0.0%	100.0%	96.4%	100.0%	100.0%	100.0%	100.0%
Feb-25	98.2%	100.0%	100.0%	99.6%	86.1%	85.2%	96.0%	96.0%	94.6%	94.6%	96.2%	96.2%
Mar-25	93.8%	99.9%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Apr-25	98.6%	98.6%	OFF	OFF	98.6%	98.6%	92.6%	91.9%	96.1%	99.2%	99.2%	99.2%
May-25	97.7%	97.7%	OFF	OFF	98.1%	98.1%	97.5%	97.5%	97.8%	97.8%	98.1%	98.1%
Jun-25	99.9%	99.9%	OFF	OFF	96.0%	96.0%	99.8%	99.8%	99.7%	99.6%	99.6%	99.8%
Jul-25	99.7%	99.7%	OFF	OFF	99.7%	99.7%	99.9%	99.9%	99.9%	99.9%	100.0%	100.0%
Aug-25	100.0%	80.9%	100.0%	98.0%	93.6%	85.4%	99.8%	84.9%	99.5%	86.2%	99.2%	93.6%
Sept-25	92.9%	94.0%	92.9%	90.4%	94.3%	91.8%	94.3%	94.1%	98.1%	98.1%	92.5%	92.5%
Oct-25	99.9%	99.7%	99.9%	99.0%	100.0%	100.0%	100.0%	99.6%	OFF	OFF	100.0%	100.0%
Nov-25	100.0%	100.0%	100.0%	99.8%	100.0%	100.0%	100.0%	100.0%	OFF	OFF	94.4%	94.4%
Dec-25	84.4%	100.0%	84.4%	84.4%	99.3%	99.3%	100.0%	100.0%	OFF	OFF	99.8%	99.8%
Jan-26	99.6%	99.6%	99.6%	99.4%	99.6%	99.6%	99.1%	99.1%	OFF	OFF	99.5%	99.3%
Feb-26	99.8%	99.9%	99.8%	97.9%	100.0%	100.0%	100.0%	92.4%	100.0%	100.0%	100.0%	100.0%

Oxygen Monitor Availability						
	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Feb-25	99.70%	99.24%	85.19%	95.83%	94.39%	60.94%
Mar-25	100.00%	100.00%	100.00%	100.00%	99.81%	99.87%
Apr-25	98.82%	OFF	98.48%	98.07%	99.07%	99.88%
May-25	97.74%	OFF	99.44%	99.82%	99.78%	99.87%
Jun-25	99.83%	OFF	99.84%	99.84%	99.74%	99.93%
Jul-25	99.85%	OFF	99.82%	99.80%	99.46%	99.96%
Aug-25	99.83%	OFF	99.84%	99.82%	99.68%	99.62%
Sept-25	93.90%	92.90%	93.10%	94.20%	98.10%	92.50%
Oct-25	100.00%	99.70%	99.90%	100.00%	OFF	100.00%
Nov-25	100.00%	100.00%	72.50%	99.80%	OFF	94.20%
Dec-25	99.60%	99.90%	99.60%	99.50%	OFF	99.70%
Jan-26	99.50%	99.50%	99.60%	99.50%	OFF	99.30%
Feb-26	99.70%	99.50%	99.80%	100.00%	100.00%	100.00%

ADDENDUM TO MONTHLY EMISSIONS REPORT

14. EFFICIENCY

	ESP Efficiency (%)					
	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Feb-25	99.702%	99.242%	85.188%	95.833%	94.391%	60.938%
Mar-25	100.000%	100.000%	100.000%	100.000%	99.812%	99.866%
Apr-25	98.818%	OFF	98.484%	98.074%	99.067%	99.877%
May-25	97.740%	OFF	99.440%	99.820%	99.780%	99.870%
Jun-25	99.830%	OFF	99.840%	99.840%	99.740%	99.930%
Jul-25	99.850%	OFF	99.820%	99.800%	99.460%	99.960%
Aug-25	99.830%	OFF	99.840%	99.820%	99.680%	99.620%
Sept-25	99.810%	99.900%	99.860%	99.750%	98.870%	99.860%
Oct-25	99.940%	99.870%	99.850%	99.790%	OFF	99.890%
Nov-25	99.810%	99.900%	99.880%	99.750%	OFF	99.858%
Dec-25	99.820%	99.899%	99.828%	99.567%	OFF	99.899%
Jan-26	99.645%	99.871%	99.830%	99.785%	OFF	99.891%
Feb-26	99.682%	99.906%	99.836%	99.574%	99.928%	99.700%

15. REMARKS

UNIT	MWLOSS	REASON	ACTUALSTARTDATE	ACTUALENDDATE
1	170	Continuous rapping.	2026/02/10 00:00:00	2026/02/10 04:55:00
1	170	High stack emissions.	2026/02/10 07:33:00	2026/02/11 00:00:00
1	170	Clean rapping	2026/02/11 00:00:00	2026/02/11 04:45:00
1	70	High stack emissions	2026/02/11 04:45:00	2026/02/11 06:11:00
1	170	High stack emissions	2026/02/20 23:56:00	2026/02/22 00:08:00
1	70	LHI precip casing repairs	2026/02/22 00:08:00	2026/02/22 18:54:00
1	170	High stack emissions	2026/02/23 01:16:00	2026/02/23 05:05:00
1	120	High stack emissions	2026/02/23 05:05:00	2026/02/23 06:11:00
1	170	Ash plant standing	2026/02/23 15:55:00	2026/02/24 06:27:00
1	180	AM: High stack emissions.	2026/02/26 02:43:00	2026/02/27 03:57:00
1	170	AM: High stack emissions.	2026/02/27 03:57:00	2026/02/28 23:59:59
2	593	Unit tripped due to generator stator high level detector.	2026/02/02 11:08:00	2026/02/03 03:45:00
2	79	Correlation test.	2026/02/09 00:00:00	2026/02/09 02:41:00
2	593	Tripped during shutdown for cold reserve	2026/02/14 12:25:00	2026/02/14 12:26:00
2	0	Cold Reserve	2026/02/14 12:26:00	2026/02/15 02:45:00
2	593	Boiler tube leak repairs	2026/02/15 02:45:00	2026/02/16 17:56:00
2	0	Cold Reserve	2026/02/16 17:56:00	2026/02/17 10:32:00
2	168	Ash plant not available	2026/02/23 15:55:00	2026/02/24 07:00:00
2	593	Boiler tube leak	2026/02/25 09:14:00	2026/02/28 23:59:59
3	593	Boiler tube leak	2026/02/01 00:00:00	2026/02/03 07:16:00
3	0	Cold Reserve	2026/02/03 07:16:00	2026/02/04 04:34:00
3	124	Ash plant standing.	2026/02/23 15:55:00	2026/02/24 16:25:00
4	138	High stack emissions	2026/02/01 01:21:00	2026/02/01 04:27:00
4	40	High stack emissions	2026/02/01 18:20:00	2026/02/01 19:14:00
4	140	High stack emissions	2026/02/01 19:14:00	2026/02/01 20:42:00
4	160	High stack emissions	2026/02/01 20:42:00	2026/02/02 00:00:00
4	90	High stack emissions.	2026/02/03 04:54:00	2026/02/04 00:00:00
4	40	RH outer casing.	2026/02/04 00:00:00	2026/02/05 00:00:00
4	40	High stack emissions	2026/02/05 00:00:00	2026/02/05 01:53:00
4	138	high stack emissions.	2026/02/05 23:57:00	2026/02/06 16:18:00
4	90	High stack emissions	2026/02/06 16:18:00	2026/02/07 04:36:00
4	140	AM: Clean rapping.	2026/02/08 00:03:00	2026/02/08 04:38:00
4	140	Clean rapping	2026/02/08 23:45:00	2026/02/09 05:00:00
4	138	High stack emissions.	2026/02/09 05:00:00	2026/02/09 15:59:00
4	90	High stack emissions	2026/02/09 15:59:00	2026/02/10 00:00:00
4	140	Continuous rapping.	2026/02/10 00:00:00	2026/02/10 04:57:00
4	140	Clean rapping	2026/02/11 00:00:00	2026/02/11 04:54:00
4	36	Clean rapping	2026/02/11 04:54:00	2026/02/11 06:11:00
4	140	High stack emissions	2026/02/11 06:11:00	2026/02/11 15:54:00
4	90	High stack emissions	2026/02/11 15:54:00	2026/02/12 00:00:00
4	140	Clean rapping	2026/02/12 00:00:00	2026/02/12 04:41:00
4	140	High stack emissions.	2026/02/13 03:35:00	2026/02/14 03:33:00
4	140	High stack emissions.	2026/02/16 05:34:00	2026/02/17 09:01:00
4	140	High stack emissions	2026/02/18 04:09:00	2026/02/19 05:09:00
4	40	LH Outer precip casing repairs	2026/02/20 00:00:00	2026/02/20 23:47:00
4	54	High stack emissions	2026/02/20 02:20:00	2026/02/20 08:47:00
4	40	High stack emissions	2026/02/20 23:48:00	2026/02/20 23:58:00
4	140	High stack emissions	2026/02/20 23:58:00	2026/02/21 14:47:00
4	150	High stack emissions	2026/02/21 14:47:00	2026/02/21 16:54:00
4	158	High stack emissions.	2026/02/21 16:54:00	2026/02/22 00:28:00
4	140	High stack emissions	2026/02/23 01:02:00	2026/02/24 08:23:00
4	150	High stack emissions	2026/02/24 08:23:00	2026/02/24 17:10:00
4	80	High stack emissions	2026/02/24 17:24:00	2026/02/25 04:15:00
4	60	Clean rapping.	2026/02/24 19:50:00	2026/02/25 04:15:00
4	140	High stack emissions.	2026/02/25 04:15:00	2026/02/25 07:36:00
4	150	High stack emissions	2026/02/25 07:36:00	2026/02/25 07:46:00
4	160	High stack emissions	2026/02/25 07:46:00	2026/02/27 01:46:00
4	593	Low drum level due to BFPT tripped.	2026/02/27 01:46:00	2026/02/27 06:02:00
4	140	High stack emissions	2026/02/27 10:45:00	2026/02/27 12:04:00
4	593	Unit tripped on low drum level	2026/02/27 12:04:00	2026/02/27 13:34:00
4	593	Fuel oil repairs and Vacuum flashing & LH PA FAN MOTOR Replacement.	2026/02/27 13:34:00	2026/02/28 23:59:59
5	593	Boiler tube leak	2026/02/01 00:00:00	2026/02/04 06:33:00
5	0	Cold Reserve	2026/02/04 06:33:00	2026/02/04 22:01:00
5	593	B EFP discharge v/v gland failure.	2026/02/04 22:01:00	2026/02/06 18:23:00
5	317	Boiler tube leak.	2026/02/07 03:26:00	2026/02/07 03:55:00
5	593	Boiler tube leak.	2026/02/07 03:55:00	2026/02/12 05:52:00
5	593	Main steam stop valves A&B fails to open	2026/02/12 08:48:00	2026/02/15 19:57:00
5	593	Poor condenser vacuum.	2026/02/16 16:32:00	2026/02/16 17:56:00
5	593	Turbine overspeed trip test	2026/02/20 00:35:00	2026/02/20 01:49:00
5	48	ESP and SO3 optimisation	2026/02/22 03:20:00	2026/02/22 11:44:00
5	218	Ash plant standing	2026/02/23 15:55:00	2026/02/24 13:58:00
5	218	High hoppers level	2026/02/24 13:58:00	2026/02/24 17:07:00
6	199	AM Clean rapping.	2026/02/08 00:14:00	2026/02/08 04:41:00
6	200	SSC Standing	2026/02/08 07:01:00	2026/02/08 09:57:00
6	197	Continuous clean rapping	2026/02/09 00:11:00	2026/02/09 04:43:00
6	218	Continuous rapping.	2026/02/10 00:32:00	2026/02/10 05:17:00
6	218	Clean rapping	2026/02/11 00:00:00	2026/02/11 05:00:00
6	218	High stack emissions	2026/02/12 00:11:00	2026/02/12 07:41:00
6	218	High stack emissions	2026/02/21 00:51:00	2026/02/21 06:55:00
6	100	High stack emissions.	2026/02/21 10:38:00	2026/02/22 00:21:00
6	68	High stack emissions	2026/02/22 19:40:00	2026/02/22 21:55:00
6	118	High stack emissions	2026/02/22 21:55:00	2026/02/23 05:43:00

6	218	Ash plant not available	2026/02/23 15:55:00	2026/02/24 14:00:00
6	218	High hoppers levels	2026/02/24 14:00:00	2026/02/24 16:37:00
6	118	High stack emissions.	2026/02/26 22:28:00	2026/02/27 00:00:00
6	238	high stack emissions.	2026/02/27 17:51:00	2026/02/28 00:14:00