



Generation

Nkangala District Municipality
P O Box 437
Middelburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Chief Director:
Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2026/05/22

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

☎ +27 66 212 2105

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105

Total number of pages: 13

Total number of Annexes:0

DUVHA POWER STATION

Atmospheric Emission License: 17/4/AEL/MP312/11/07

GENERAL MANAGER

2026/05/29
DATE

**DUVHA POWER STATION MONTHLY EMISSIONS
REPORT**

Atmospheric Emission License: NDM/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Apr-2026
	Coal	Tons	1 400 000	422 500.22
	Fuel Oil	Tons	5 000	4400.83

Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Apr-2026
	Energy	GWh	2 160.000	745.64
	Ash	Tons	562 464	108 920.56

Note: Max energy rate = AEL capacity [3,600 MW] × 24 hrs × days in month ÷ 1,000 (to convert to GWh).

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 - 1.2	0.70
Ash Content	%	30.2	25.78

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	Daily Limit		
	PM	SO ₂	NO _x
Unit 1	50	2600	1100
Unit 2	50	2600	1100
Unit 4	100	2600	1100
Unit 5	50	2600	1100
Unit 6	100	2600	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	ESP Efficiency	Technology Type	SO ₃ Plant Utilization
Unit 1	FFP	99.946%	FFP	n/a
Unit 2	FFP	99.881%	FFP	n/a
Unit 4	ESP + SO ₃	99.674%	SO ₃	98.4%
Unit 5	ESP + SO ₃	99.869%	SO ₃	100.0%
Unit 6	ESP + SO ₃	99.830%	SO ₃	99.6%

Note: The ESP plant does not have a bypass mode; therefore, it operates at 100% utilization.

5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	Unit Offload	Unit Offload	Unit Offload	Unit Offload
Unit 2	100.0	99.6	99.8	99.1
Unit 4	100.0	99.5	99.7	100.0
Unit 5	100.0	99.5	99.8	100.0
Unit 6	100.0	99.8	99.8	100.0

Note: NO_x emissions are measured as NO in PPM. The final NO_x value is expressed as total NO₂ equivalent.

6 EMISSION PERFORMANCE

Table 6.1 Monthly tonnages for April 2026

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	Unit Offload	Unit Offload	Unit Offload
Unit 2	26.8	2,251	818
Unit 4	78.1	2,070	706
Unit 5	28.0	1,711	536
Unit 6	36.1	2,573	878
SUM	169.04	8,605	2,938

Table 6.2: PM AEL Daily - April 2026

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days In contravention	Total Exceedance	Mo Avg (mg/Nm ³)
Unit 1	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload
Unit 2	21	0	0	0	0	19.1
Unit 4	25	1	0	0	1	63.2
Unit 5	22	2	0	0	2	28.5
Unit 6	23	0	0	0	0	27.5
SUM	91	3	0	0	3	

Table 6.3: SO₂ AEL Daily - April 2026

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days In contravention	Total Exceedance	Mo Avg (mg/Nm ³)
Unit 1	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload
Unit 2	23	0	0	0	0	1 536.8
Unit 4	27	0	0	0	0	1 637.9
Unit 5	24	0	0	0	0	1 694.5
Unit 6	24	0	0	0	0	1 860.9
SUM	98	0	0	0	0	

Table 6.4: NO_x AEL Daily - April 2026

Associated Unit/Stack	Normal Days	Number of days in Grace period	Number of Section 30 days	Number of days In contravention	Total Exceedance	Mo Avg (mg/Nm ³)
Unit 1	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload	Unit Offload
Unit 2	23	0	0	0	0	543.5
Unit 4	27	0	0	0	0	556.7
Unit 5	24	0	0	0	0	526.1
Unit 6	24	0	0	0	0	628.5
SUM	98	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 2 PM Emissions - April 2026




Figure 2: Duvha Unit 4 PM Emissions - April 2026




Figure 3: Duvha Unit 5 PM Emissions - April 2026




Figure 4: Duvha Unit 6 PM Emissions - April 2026




Figure 5: Duvha Unit 2 SO₂ Emissions - April 2026




Figure 6: Duvha Unit 4 SO₂ Emissions - April 2026




Figure 7: Duvha Unit 5 SO₂ Emissions - April 2026




Figure 8: Duvha Unit 6 SO₂ Emissions - April 2026




Figure 9: Duvha Unit 2 NO_x Emissions - April 2026




Figure 10: Duvha Unit 4 NO_x Emissions - April 2026




Figure 11: Duvha Unit 5 NO_x Emissions - April 2026





Figure 12: Duvha Unit 6 NO_x Emissions - April 2026



7 Shut-down and light-up information for APRIL 2026

	Event Description	Event 1	
Unit 2	Breaker Open (BO)	10:30 pm	2026/04/16
	Draught Group (DG) Shut Down (SD)	2:15 am	2026/04/17
	BO to DG SD (duration)	00:03:45	DD:HH:MM
	Fires in time	11:15 am	2026/04/25
	Synch. to Grid (or BC)	3:25 pm	2026/04/25
	Fires in to BC (duration)	00:04:10	DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2026/04/27
	Emissions below limit from BC (duration)	01:08:35	DD:HH:MM

	Event Description	Event 1	
Unit 4	Breaker Open (BO)	10:45 am	2026/04/06
	Draught Group (DG) Shut Down (SD)	1:15 pm	2026/04/06
	BO to DG SD (duration)	00:02:30	DD:HH:MM
	Fires in time	9:00 pm	2026/04/09
	Synch. to Grid (or BC)	2:05 am	2026/04/10
	Fires in to BC (duration)	00:05:05	DD:HH:MM
	Emissions below limit from BC (end date)	2:00 am	2026/04/11
	Emissions below limit from BC (duration)	00:23:55	DD:HH:MM

	Event Description	Event 1	
Unit 5	Breaker Open (BO)	1:55 pm	2026/04/24
	Draught Group (DG) Shut Down (SD)	12:35 am	2026/04/25
	BO to DG SD (duration)	00:10:40	DD:HH:MM
	Fires in time	8:05 am	2026/04/25
	Synch. to Grid (or BC)		
	Fires in to BC (duration)		DD:HH:MM
	Emissions below limit from BC (end date)	not > limit	not > limit
	Emissions below limit from BC (duration)		DD:HH:MM

	Event Description	Event 1		Event 2	
Unit 6	Breaker Open (BO)	BO previously	BO previously	9:20 pm	2026/03/31
	Draught Group (DG) Shut Down (SD)	n/a	n/a	DG did not trip or SD	DG did not trip or SD
	BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM
	Fires in time	2:10 pm	2026/04/07		
	Synch. to Grid (or BC)	8:05 pm	2026/04/07		
	Fires in to BC (duration)	00:05:55	DD:HH:MM		DD:HH:MM
	Emissions below limit from BC (end date)	12:00 am	2026/04/09		
	Emissions below limit from BC (duration)	01:03:55	DD:HH:MM		DD:HH:MM

8 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

9 GENERAL

Exceedances

Particulate Matter

Unit4

25/04/2026

The Dust hopper right hand row number 1 was blocked due to water ingress on the precip field roof from rain This also caused the precip number 1 to be arching and sparking and needing to be switched off

Unit 5

15/04/2026

Dust hoppers number 14 & 18 were blocked due to ineffective air soot blowing This ineffective soot blowing also caused high back-end temperatures that led to precip fields 2 4 and 4 4 having sparks and thus switched off


22/04/2026

Dust hopper left hand row 1&3 and right hand 2&13 were blocked due to water ingress into the precip roofs from rain This caused all the precip fields to be arching and sparking and thus switched off


The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office

10 S30 Incidents Register


There were no section 30 incidents


Boiler Plant Engineering Manager

28/05/2026
Date


Environmental Manager

29/05/2026
Date


Engineering Manager

2026-05-28
Date

Compiled by Environmental Officer

For Nkangala District Municipality Air Quality Officer

Copies

Generation Environmental Management	D Herbst
	B Mccourt
Generation Compliance Management	R Rampiar
Generation Asset Management	E Patel
Duvha Power Station	Engineering Manager
	Operating Manager
	Maintenance Manager
	Production Manager
	Boiler Engineering Manager
	System Engineer
	Environmental Manager