

	Matimba Power Station annual emission report	Matimba Power Station
---	---	------------------------------

Title: **Matimba Power Station annual emission report for 2025/2026 financial year**

Document Identifier: **RP/247/071**

Plant Location: **N/A**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**


Revision: **1**

Total Pages: **23**

Report Date: **May 2026**

Disclosure Classification: **Controlled**


Compiled by



**Helry Ramahlare
Senior Advisor
Environment**

Date: 2026-05-29

Reviewed by



**MC Mamabolo
Environmental
Manager**

Date: 29.05.2026


**Functional
Responsibility**



**NJ Mathobela
Environmental
Manager**

Date: 2026/05/29

Authorized by



**JLJ van Renburg
General Manager**

Date: 29/05/2026

Content

	Page
1. Introduction	4
2. Annual emission information	5
2.1. Annual consumption rates	5
2.2. Energy source characteristics	7
2.3. Emission trends	10
2.4. Energy sent out	17
2.5. Ambient air quality monitoring	18
2.6. CEMS monitoring data availability/reliability.	22
2.7. Greenhouse gas emissions	22
2.8. Results of spot measurements or correlation tests:	22
2.9. Action taken addressing complaints.	23
2.10	24
3.10 Summary of exceedances of emission limits	24
2.11 NAEIS reporting.	24
3. Declaration of accuracy	25
Figure 1: Coal consumption for 2024/2025 financial year	5
Figure 2: Fuel oil consumption for 2025/2026 Financial year	6
Figure 3: Sulphur content in coal for 2025/2026 financial year	7
Figure 4: Ash content in coal for 2025/2026 financial year	8
Figure 5: Sulphur content in fuel oil for 2025/2026 financial year	9
Figure 6: Monthly Particulate Emissions in tons from Matimba Power Station 2025/2026	12
Figure 7: Monthly SO ₂ Emissions in tons from Matimba Power Station 2025/2026	13
Figure 8: Monthly NO ₂ Emissions in tons from Matimba Power Station 2025/2026	14
Figure 9: PM Emissions Trend in mg/Nm ³ from Matimba Power Station 2025/2026	15
Figure 10: SO _x Emissions Trend in mg/Nm ³ from Matimba Power Station 2025/2026	16
Figure 11: NO _x Emissions Trend in mg/Nm ³ from Matimba Power Station 2025/2026	16
Figure 9: Monthly Energy Sent out GWh at Matimba Power Station 2025/2026	17
Tables	
Table 1: Name, description and reference number of plant as specified in the AEL	4
Table 2: General overview of emissions at Matimba Power Station 2024/2025	10
Table 3: Pollutant Emission Trends	10
Table 4: Total volatile organic compound emissions 2024/2025 financial year	11
Table 5: Ambient Monitoring station availability	20

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 6: National Ambient Air Quality Limits exceedances21

Table 7: Monitoring data availability for Matimba Power Station 2024/202522

Table 8: Dates of last full conducted CEMS verification tests for PM for unit 6.22

Table 9: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x for unit 1, 5 and 6)23

Table 10: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only23

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Introduction

This annual emissions report is prepared as per the requirements of Section 7.7.3 of the Matimba Power Station's Atmospheric Emission License (AEL) "*The License Holder must complete and submit to the Licensing Authority, an annual Report. The report must include information for the year under review (i.e., annual year end of the company). The report must be submitted to the licensing authority not later than 60(sixty) days after the end of each reporting period*", as well as in terms other reporting requirements listed in the Minimum Emission Standards. The emissions are for Matimba's 2025/2026 financial year, which covers the period from 1 April 2025 to 31 March 2026. The data presented in the report is the verified emissions of particulates, SO₂ and NO_x (as NO₂), as measured by installed CEMS. Greenhouse gas reporting is done in accordance with the National Greenhouse Gas Reporting Regulations.

Table 1: Name, description and reference number of plant as specified in the AEL

Name of facility	Eskom Holdings SOC Limited Matimba Power Station
Description of facility	Electricity generation
Enterprise registration number	2002/015527/30
AEL reference number	H16/1/13-WDM05
AEL Issue Date and Validity	27 September 2022 – 27 September 2026

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Annual emission information

2.1. Annual consumption rates

Figure 1 and Figure 2 below indicates the monthly coal and fuel oil consumption rates, respectively, in tons for the 2024/2025 financial year.




Figure 1: Coal consumption for 2024/2025 financial year

Monthly coal consumption for the whole reporting period remained below the limit of 1 500 000 Tons per month.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 2: Fuel oil consumption for 2025/2026 Financial year

Matimba Power Station exceeded the monthly fuel oil usage limit of 1200 Tons per month from April 2025 to March 2026. The increased usage of fuel oil was due to multiple start-ups that had to be done after several unplanned unit trips and planned outages of units and the plants defects that resulted in operating with constant combustion support with fuel oil.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.2. Energy source characteristics

The figures 3, 4 and 5 below indicates the Sulphur content and ash content of the coal and Sulphur content of the fuel oil used in the 2025/2026 financial year.




Figure 3: Sulphur content in coal for 2025/2026 financial year

Monthly average Sulphur content of coal has remained within the specified range for 2025/2026 financial year.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 4: Ash content in coal for 2025/2026 financial year

The monthly average ash content within the coal remained within the required limits.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 5: Sulphur content in fuel oil for 2025/2026 financial year

Sulphur content of the fuel oil has remained below the limit of 3,50% in the 2025/2026 financial year except to September 2025 and October 2025.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3. Emission trends

The emission tonnages in tables 3 below are that of the 2024/2025 financial year.

Table 2: General overview of emissions at Matimba Power Station 2024/2025

Power Station	Coal-fired emissions (tons/annum)	Fuel-oil emissions (tons/annum)	Total (tons/annum)
Matimba Power Station	SO₂: 233632 PM: 54452.87 NO_x: 43534	SO₂: 1101.87	SO₂: 233632 PM: 54452.87 NO_x: 43534

Table 3: Pollutant Emission Trends

Month	PM	NO _x	SO _x
Apr-25	8784.160	5233.000	26709.000
May-25	11741.590	4453.000	25992.000
Jun-25	5594.220	3543.000	20955.000
Jul-25	11042.580	4408.000	24760.000
Aug-25	11911.590	4919.000	28134.000
Sept-25	2048.540	4547.000	23674.000
Oct-25	482.060	4834.000	26516.000
Nov-25	335.500	3686.000	21743.000
Dec-25	318.750	3586.000	21529.000
Jan-26	294.030	3122.000	20185.000
Feb-26	259.770	3675.000	22139.000
Mar-26	417.660	3916.000	25054.000

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 4: Total volatile organic compound emissions 2025/2026 financial year

Month	TVOC (Kg/month)
Apr-25	0.53
May-25	0.53
Jun-25	0.58
Jul-25	0.61
Aug-25	0.6
Sept-25	0.59
Oct-25	0.73
Nov-25	0.66
Dec-25	0.62
Jan-26	0.63
Feb-26	0.62
Mar-26	0.6

*Note: Total volatile organic compound emissions are calculated based on fuel oil quantities used within the specific month.

Figures 6 to 8 below illustrates the monthly tonnages of pollutants emitted in the 2025/2026 financial year.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 6: Monthly Particulate Emissions in tons from Matimba Power Station 2025/2026.

Matimba experienced increases in particulate emissions tonnages in the financial year 2025/2026. The station experienced challenges with the downstream ash evacuation due to the unreliability and poor performance of the ash conveyance plant. The ash conveyance plant issues lead to backlogs at the dust handling plant i.e. high hopper levels and precipitator fields trip or failure, then high emissions. The daily average limit of 50mg/Nm³ was exceeded 823 times in the period between April 2025 and March 2026, no section 30 incidents were reported for the financial year. Corrective actions to repair defective plant areas are underway. More information on exceedances will be provided in annexure 1. Detailed daily emission concentrations are illustrated in the monthly reports submitted to your office.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 7: Monthly SO₂ Emissions in tons from Matimba Power Station 2025/2026

The reduction in SO₂ emissions from May 2025 to June and October 2025 to February 2026 was due to several units taken on outage and repairs. Occasional daily peaks were observed in the sulphur content of coal which leads to sporadic increases of the SO_x emissions. Interventions such as blending high sulphur content coal with lower sulphur content coal, daily monitoring, and trending of sulphur content versus emissions is being conducted to manage the SO₂. There were no SO_x daily exceedances in the reporting period. Detailed daily emission concentrations are illustrated in the monthly reports submitted to your office.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 8: Monthly NO₂ Emissions in tons from Matimba Power Station 2025/2026

The decrease in Nox emissions from May 2025 to June and October 2025 to February 2026 was due to several units taken on outage and repairs There were no NOx daily exceedances in the reporting period. Detailed daily emission concentrations are illustrated in the monthly reports submitted to your office.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 9: PM Emissions Trend in mg/Nm3 from Matimba Power Station 2025/2026.

Matimba experienced increases in particulate emissions tonnages around the first eight months of the financial year. The station experienced challenges with the downstream ash evacuation due to the unreliability and poor performance of the ash conveyance plant. The ash conveyance plant issues lead to backlogs at the dust handling plant i.e. high hopper levels and precipitator fields trip or failure, then high emissions. The daily average limit of 50mg/Nm3 was exceeded 823 times in the period between April 2025 and March 2026, no section 30 incidents were reported for the financial year. Corrective actions to repair defective plant areas are underway.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 10: SOx Emissions Trend in mg/Nm3 from Matimba Power Station 2025/2026

There were sporadic daily Sox results that exceeded the 3500 mg/Nm3 in the reporting period, however no monthly average exceedances of the Sox emission limit was recorded. Detailed daily emission concentrations are illustrated in the monthly reports submitted to your office.




Figure 11: NOx Emissions Trend in mg/Nm3 from Matimba Power Station 2025/2026

There were sporadic daily Nox results that exceeded the 750 mg/Nm3 in the reporting period, however no monthly average exceedances of the Sox emission limit was recorded. Detailed daily emission concentrations are illustrated in the monthly reports submitted to your office.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4. Energy sent out

Figure 9 illustrates the monthly energy sentout for the 2025/2026 financial year




Figure 12: Monthly Energy Sent out GWh at Matimba Power Station 2025/2026

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.5. Ambient air quality monitoring

Matimba power Station monitors the effect of its emissions on the surrounding environment through an ambient air quality monitoring station located in the Marapong community. The station utilised Marapong ambient air quality monitoring station for reporting and detailed ambient monitoring reports were available and submitted to the licencing authority monthly along with the Matimba monthly emission report.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 5 and 6 below illustrates the compliance for the past financial year (April 2024 – March 2025) as per the National Air Quality Standards.

Ambient monitoring station availability															
	NO1	NO2	NOX	O3	SO2	TMP	WDR	WSP	WVL	PM2.5	PM10	CO	HUM	Data Recovery	Station Availability
Apr-25	78	78	78	100	100	100	100	100	100	ND	0	0	100	88	100
May-25	96	96	96	98	98	100	100	100	100	ND	98	98	100	98	98
Jun-25	53	53	53	99	99	99	99	99	99	ND	6	0	99	77	99
Jul-25	99	99	99	99	99	99	99	99	99	22	23	0	99	84	99
Aug-25	99	99	99	100	100	100	100	100	100	96	26	33	100	83	91
Sept-25	97	97	97	97	100	100	100	100	100	97	86	98	100	98	98
Oct-25	99	99	99	99	100	100	100	100	100	99	99	99	99	99	99
Nov-25	100	100	100	100	100	100	100	100	100	98	98	99	100	99	100
Dec-25	97	97	97	97	97	97	97	97	97	97	97	97	97	97	97
Jan-26	100	100	100	100	100	100	100	100	100	96	98	100	100	99	100
Feb-26	100	100	100	99	100	100	100	100	100	98	99	99	100	99	100

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Mar-26	99	99	99	99	100	100	100	100	100	99	44	99	100	96	100
Average	93	93	93	99	99	100	100	100	100	89	64	68	99	93	98

*ND = No Data

Table 5: Ambient Monitoring station availability

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Average data recovery was below the required 90% for all the Months of 2024/2025 financial year.

Table 6: National Ambient Air Quality Limits exceedances

Number of exceedances of the National Ambient Air Quality Limits							
	SO2 10-minute	SO2 hourly	SO2 daily	NO2 hourly	PM2.5 daily	CO hourly	O3 8-hourly
Apr-25	0	0	0	0	ND	ND	0
May-25	0	0	0	0	ND	ND	1
Jun-25	0	0	1	0	ND	ND	0
Jul-25	0	5	4	0	4	ND	0
Aug-25	0	0	0	0	1	0	44
Sept-25	0	0	0	0	11	0	68
Oct-25	0	0	0	0	2	0	37
Nov-25	0	0	0	0	0	0	17
Dec-25	0	0	0	0	0	0	0
Jan-26	0	0	0	0	0	0	0
Feb-26	0	0	0	0	0	0	0
Mar-26	0	0	0	0	0	0	20

*ND= No Data

The number of exceedances of the PM₁₀, , PM_{2.5} , SO₂ and O₃ daily limits has exceeded their allowed number of exceedances per year.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6. CEMS monitoring data availability/reliability.

Summary to put into annual report						
	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
PM (%)	77.34	75.83	70.09	75.23	36.14	87.06
SO ₂ (%)	94.86	93.02	76.80	90.77	54.30	88.02
NO _x (%)	93.67	94.81	75.13	82.59	57.06	86.98
CO ₂ (%)	100.00	100.00	75.10	100.00	49.78	99.25

Table 7: Monitoring data availability for Matimba Power Station 2025/2026

From the 18 December 2024 the station experienced an incident on the station service air failure which resulted in water ingress in the flue gas stack system that caused damage to the gaseous monitors. The gaseous monitors for all units were experiencing constant defects caused by the water ingress incident from the previous year and surrogate values obtained from the parallel/QAL 2 tests were used to calculate the emissions and the monitors reliability during the months where the monitor was operating optimally. The average monitor availability for the 2025/2026 financial year was above 80% for the units, 1, 2, 4 and 6. The low monitor reliability for the PM monitors for all units was caused by the monitor maxing out during the period when the station was experiencing the high dust emissions on the units due to challenges experienced with the downstream ash evacuation due to the unreliability and poor performance of the ash conveyance plant.

2.7. Greenhouse gas emissions

Greenhouse Gas Reporting shall be done in accordance with the National Greenhouse Gas Reporting Regulations

2.8. Results of spot measurements or correlation tests:

Table 8: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x for unit 5.

Name of service provider:		Levego Environmental services			
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645			
Stack/ Unit	PM	SO₂	NO_x	CO₂	
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 9: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

Name of service provider:		Levego Environmental services			
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645			
Stack/ Unit	PM	SO ₂	NO _x	CO ₂	
2	2024/07/02 08h50	2024/07/02 12h35	2024/07/02 12h35	2024/07/02 12h35	
3	2024/06/23 16h34	2024/06/23 14h00	2024/06/23 14h00	2024/06/23 14h00	
4	2024/06/29 16h05	2024/06/29 11h00	2024/06/29 11h00	2024/06/29 11h00	

Table 10: Dates of last full conducted CEMS verification tests for PM for unit 1 and 6 only

Name of service provider:		Inthuu Measurement			
Address of service provider:		2/410 Seventh Road Bredell Kepton park 1619			
Stack/ Unit	PM	SO ₂	NO _x	CO ₂	
1	2025/09/22 17:22	2025/08/16 16h21	2025/08/16 16h21	2025/08/16 16h21	
6	2025/10/01 17h30	2025/08/13 16h26	2025/08/13 16h26	2025/08/13 16h26	

2.9. Action taken addressing complaints.

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
----------------------	------------------------	---	---	--	---

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

None					
------	--	--	--	--	--

2.10

3.10 Summary of exceedances of emission limits

Refer to Annexure 1 - AEL exceedance reporting tool 2024/2025

2.11 NAEIS reporting.

Matimba Power Station has submitted all emission data On the NAEIS system before the 30th of March 2026 and still awaiting auditing feedback from the DEFF system administrators.

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Declaration of accuracy

The rest of the information demonstrating compliance with the emission license conditions is supplied in the monthly emission reports sent to your office.

I hereby declare the following:

- Normal operating conditions were maintained during emission tests.
- The information in this report is correct

pp 

JLJ van Renburg

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

