



Ck No. 2007/196934/23 VAT No: 4030265740

**Physical Address:** 49 3rd Avenue, Highlands North, 2192

**Postal Address:** P O Box 2363, Highlands North, 2037

**Tel:** 011 4401817 **Fax:** 086 607 9841

**Contact Person :** Judith Fasheun, **Cell:** 076 876 2672, **Email:** judy@mokgope.co.za

---

Dear all,

Thank you for attending the public meeting on the 10<sup>th</sup> October 2017.

We would like to draw your attention that these minutes were drawn from notes taken from the Public Meeting; please provide corrections / additions if applicable.

We would like to advise that while utmost care was taken to record your comments accurately and faithfully, there may be some discrepancies between what has been written in the minutes that follow and what was actually said. We apologise for this and request that you correct the minutes and e-mail back to us for final amendments.

Many thanks for your participation at the meeting, as well as for your understanding regarding the minutes.

Regards

Judith Fasheun

*Mokgope Consulting cc*  
Cell: 076 876 2672



Ck No. 2007/196934/23 VAT No: 4030265740

**Physical Address:** 49 3rd Avenue, Highlands North, 2192

**Postal Address:** P O Box 2363, Highlands North, 2037

**Tel:** 011 4401817 **Fax:** 086 607 9841

**Contact Person :** Judith Fasheun, **Cell:** 076 876 2672, **Email:** judy@mokgope.co.za

### **Proposed “Aggeneis-Paullups” 400kV Transmission Powerline & Substations Upgrade, Northern Cape Province**

**Meeting with I&APs held at 10h00 on 10<sup>th</sup> October 2017 at Aggeney's Rec Club**

#### **Attendees:**

Judith	Fasheun	JF	Mokgope Consulting
Victoria	Somo	VS	Mokgope Consulting
Mpilo	Masondo	MM	Eskom
Rene	Naidoo	RN	Eskom
Lungile	Lohlanga	LL	Eskom
Pumza	Jizala	PJ	Eskom
Fick	Booyens	FB	Eskom
Tebogo	Bhulose	TB	Eskom
Mxolisi	Mabindisa	MXM	Eskom
Anne-Marie	Cloete	AC	Black Mountain Mine

<b>Item No</b>	<b>Item Description</b>	<b>Response / Comment</b>
1.	<b>JF:</b> Welcome and Introduction	
2.	<b>MXM:</b> Presentation 1	
3.	<b>JF:</b> Presentation 2	
4.	<b>DISCUSSION</b>	
	<b>AC:</b> How large will the new structures be? Will the new structures be as tall and big as those of the existing line across (along) the N14?	<b>RN:</b> The tallest structure that will be used is the 529A (Cross rope tower) – height is about 42m (it will be the tallest structure used) – These structures are not final and may change in the detailed design stage.
	<b>AC:</b> We have no comments. We concur with the findings of the specialists. In particular, the biodiversity findings are similar to our	<b>JF:</b> Thank you for taking the time to attend this meeting and for representing the mine.

<b>Item No</b>	<b>Item Description</b>	<b>Response / Comment</b>
	assessment findings that we normally undertake in the area.	
5.	Meeting was declared closed.	