

14 April 2016

Dear Stakeholder

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.
- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschkliip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

Projects Organisations Stakeholders Calendar Reports Emails more

SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE - NOTIFICATION OF EIA PROCESS & AVAILABILITY OF SCOPING REPORT FOR REVIEW

Sea

Forward

Assigned to:	Gabriele Wood	Date Sent:	15/04/2016 12.46
Teams:	Global	Project:	Saldanha Bay Network Strengthening Project, WC
From:	Gabriele Wood <gabriele@savannahsa.com>		
To:			
Cc:			
Bcc:	<p>Andre Kruger <andre.kruger@sbm.gov.za>, Ayub Mohamed <ayub.mohamed@pgwc.gov.za>, Francois John Schippers <francois.schippers@sbm.gov.za>, Cor van der Walt <corvdw@elsenburg.com>, Owen Peters <owen.peters@eskom.co.za>, Nicole Abrahams <abrahamsn@nra.co.za>, Ndivhuwo Netshilaphala <ndivhuwo.netshilaphala@transnet.net>, Stehan Bouwer <johannes.bouwer@transnet.net>, Willem Louw <willem.louw@sanparks.org>, Rashid Khan <khanr@dwa.gov.za>, Skumsa Mancotywa <smancotywa@environment.gov.za>, Nicolaas Stephanus Louw <stephan.louw@sbm.gov.za>, Malcom Watters <malcolm.watters@westerncape.gov.za>, Duduzile Kunene <duduzile.kunene@dmr.gov.za>, Lars Starke <lstarke@pgwc.gov.za>, Mario J Brown <mario.brown@westerncape.gov.za>, Frank Pronk <frank.pronk@sbm.gov.za>, Nazeema Duarte <nazeema.duarte@sbm.gov.za>, Thoko Buthelezi <thokob@daff.gov.za>, Guy Thomas <guy.thomas@westerncape.gov.za>, Doretha Kotze <dkotze@wcdm.co.za>, Louis Scheepers <mun@sbm.gov.za>, Andrew Julyan <andrew.julyan@transnet.net>, Mashudu Marubini <mashuduma@daff.gov.za>, Alana Duffell-Canham <aduffell-canham@capenature.co.za>, Charles Malherbe <cjmalherbe@wcdm.co.za>, René de Kock <dekockr@nra.co.za></p>		
Subject:	SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE - NOTIFICATION OF EIA PROCESS & AVAILABILITY OF SCOPING REPORT FOR REVIEW		
Body:	<p>Dear Stakeholder</p> <p>Eskom Holdings SOC Ltd is proposing the Saldanha Bay Network Strengthening Project which involves the proposed construction of a new Distribution substation (Dx), Transmission substation (Tx), 2x 400kV Power Lines and associated upgrade and extension of the Aurora Substation. The proposed Saldanha Bay Network Strengthening is located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. Savannah Environmental has been appointed by Eskom to undertake the required Environmental Impact Assessment process required for this project. A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from 15 April 2016 – 18 May 2016. Kindly refer to the attached notification letter and background information document (BID) for further information regarding the proposed project.</p>		

Projects Organisations Stakeholders Calendar Reports Emails more

Kind regards

Mrs Gabriele Wood

Public Participation and Social Consultant

Savannah Environmental (Pty) Ltd

Tel: 27 11 656 3237

Fax: 086 684 0547

Email: gabriele@savannahsa.com

www.savannahsa.com

Show Plain Text

Attachments: [Reply Form.pdf](#)
[Saldannah Bay DSR Distribution Organs of State 14.05.2016.pdf](#)
[SBGSP BID \(Eng\).pdf](#)

Activities

(0 - 0 of 0)

Subject	Status	Contact	Due Date	Assigned User
No Data				

Attachments

(1 - 3 of 3)

Subject	Contact	Last Modified	
Reply Form.pdf		15/04/2016 12.46	<input type="button" value="edit"/>
Saldannah Bay DSR Distribution Organs of State 14.05.2016.pdf		15/04/2016 12.46	<input type="button" value="edit"/>
SBGSP BID (Eng).pdf		15/04/2016 12.46	<input type="button" value="edit"/>

Accounts

(0 - 0 of 0)

Account Name	Town/City	Phone
No Data		

Contacts



Projects Organisations Stakeholders Calendar Reports Emails more

No Data

Email Stakeholders

(1 - 10 of 29)

Name	Organisation	Email	
Nicole Abrahams	South African National Roads Agency Limited	Abrahamsn@nra.co.za	<input type="button" value="edit"/>
Stehan Boucher	Transnet Ltd	johannes.boucher@transnet.net	<input type="button" value="edit"/>
Mario J Brown	Western Cape Department of Transport and Public Works	Mario.Brown@westerncape.gov.za	<input type="button" value="edit"/>
Thoko Buthelezi	Department of Agriculture, Forestry & Fisheries	thokob@daff.gov.za	<input type="button" value="edit"/>
René de Kock	South African National Roads Agency Limited	Dekockr@nra.co.za	<input type="button" value="edit"/>
Nazeema Duarte	Saldanha Bay Municipality	nazeema.duarte@sbm.gov.za	<input type="button" value="edit"/>
Alana Duffel-Canham	CapeNature Scientific Services	aduffell-canham@capenature.co.za	<input type="button" value="edit"/>
Andrew Julyan	Transnet Ltd	andrew.julyan@transnet.net	<input type="button" value="edit"/>
Rashid Khan	Department of Water and Sanitation	KhanR@dwa.gov.za	<input type="button" value="edit"/>
Doretha Kotze	West Coast District Municipality	dkotze@wcdm.co.za	<input type="button" value="edit"/>

Users

Select

(0 - 0 of 0)

Name	User Name	Email	Phone
------	-----------	-------	-------

No Data

Projects

Create

(1 - 1 of 1)

Name	Assigned To	Start Date:	End Date:
------	-------------	-------------	-----------

Saldanha Bay Network Strengthening Project, WC	Gabriele Wood	01/09/2015	30/09/2016	<input type="button" value="edit"/>
--	---------------	------------	------------	-------------------------------------

[Projects](#) [Organisations](#) [Stakeholders](#) [Calendar](#) [Reports](#) [Emails](#) [more](#)



14 April 2016

CapeNature Scientific Services
Assegaaibosch Nature Reserve
Jonkershoek
Stellenbosch
7599

Tel: 021 866 8000
Email: aduffell-canham@capenature.co.za

Dear Alana Duffel-Canham

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Department of Agriculture, Forestry & Fisheries
Delpen Building, Office 270
Cnr Annie Botha & Union Streets
Pretoria
0084

Tel: 012-319-7619
Email: mashuduma@daff.gov.za

Dear Mashudu Marubini

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Department of Agriculture, Forestry & Fisheries
Delpen Building, Office 270
Cnr Annie Botha and Union Street
Pretoria
0084

Tel: 012-319-7634
Email: thokob@daff.gov.za

Dear Thoko Buthelezi

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

From the desk of Gabriele Wood
E-mail: gabriele@savannahSA.com



14 April 2016

Department of Environmental Affairs
Environment House
473 Steve Biko Road
Pretoria
0001

Tel: 012-399-9514
Email: smancotywa@environment.gov.za

Attention: Acting Deputy Director-General: Biodiversity and Conservation

Dear Skumsa Mancotywa

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschkliip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to

obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Department of Mineral Resources
Atterbury House, 9th Floor
c/o Lower Burg & Riebeeck Street
Cape Town
8012

Tel: 021-427-1000
Email: Duduzile.Kunene@dmr.gov.za

Dear Duduzile Kunene

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Department of Water and Sanitation
3 Blanckenberg Street
Cape Town
7530

Tel: 021-941-6000
Email: KhanR@dwa.gov.za

Dear Rashid Khan

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Heritage Western Cape
Protea Assurance Building
Green Market Square
Cape Town
8000

Tel: 021-483-9685
Email: guy.thomas@westerncape.gov.za

Dear Guy Thomas

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7192
Email: mun@sbm.gov.za

Dear Louis Scheepers

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7116
Email: nazeema.duarte@sbm.gov.za

Dear Nazeema Duarte

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
Ward 5
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7192
Email: frank.pronk@sbm.gov.za

Dear Councillor Frank Pronk

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
Ward 6
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7192
Email: andre.kruger@sbm.gov.za

Dear Councillor Andre Kruger

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
Ward 7
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7099
Email: francois.schippers@sbm.gov.za

Dear Councillor Francois John Schippers

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Saldanha Bay Municipality
Ward 8
12 Main Street, Ground Floor
Vredenburg
7380

Tel: 022-701-7192
Email: stephan.louw@sbm.gov.za

Dear Councillor Nicolaas Stephanus Louw

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

South African National Parks
Ipic Centre, 1st Floor
Cnr Bottelary Road & Amandel Drive
Kuilsriver
7583

Tel: 021-949-6414
Email: willem.louw@sanparks.org

Dear Willem Louw

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, S WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

South African National Roads Agency Limited
1 Havenga Street
Oakdale
Bellville
7530

Tel: 021-957-4600
Email: Dekockr@nra.co.za

Dear René de Kock

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, S WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

West Coast District Municipality
58 Long Street
Moorreesburg
7310

Tel: 022-433-8400
Email: dkotze@wcdm.co.za

Dear Doretha Kotze

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

West Coast District Municipality
58 Long Street
Moorreesburg
7310

Tel: 022-433-8400
Email: cjmalherbe@wcdm.co.za

Dear Charles Malherbe

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Western Cape Department of Agriculture and Rural Development
3rd Floor, Main Building
Muldersvlei Road
Elsenberg
7607

Tel: 021-808-5093/9
Email: CorvdW@elsenburg.com

Dear Cor van der Walt

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

From the desk of Gabriele Wood
E-mail: gabriele@savannahSA.com



14 April 2016

Western Cape Department of Local Government,
Environmental Affairs and Development Planning
Utilitas Building
1 Dorp Street
Cape Town
8001

Tel: 021-483-3722
Email: ayub.mohamed@pgwc.gov.za

Dear Ayub Mohamed

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Western Cape Department of Transport and Public Works
8th Floor
9 Dorp Street
Cape Town
8001

Tel: 021 483 2419
Email: malcolm.watters@westerncape.gov.za

Dear Malcom Watters

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.

Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

14 April 2016

Western Cape Department of Transport and Public Works
8th Floor
9 Dorp Street
Cape Town
8001

Tel: 021-483-2604
Email: Mario.Brown@westerncape.gov.za

Dear Mario J Brown

**ENVIRONMENTAL IMPACT ASSESSMENT PROCESS
PUBLIC PARTICIPATION PROCESS
SALDANHA BAY NETWORK STRENGTHENING PROJECT, WESTERN CAPE PROVINCE**

**NOTIFICATION OF ENVIRONMENTAL IMPACT ASSESSMENT PROCESS AND AVAILABILITY OF
SCOPING REPORT FOR REVIEW**

As part of the envisaged developments in the Saldanha Bay area, Eskom SOC Limited has been prompted to re-assess the capability of the existing electricity network in the area in order to meet the forecasted load requirements from industrial customers, the Saldanha Bay Industrial Development Zone (IDZ), local distributors and also to facilitate the integration of renewable energy generation. Power to the Saldanha Bay area is supplied from Aurora Substation which is located 28km east of Saldanha Bay. Aurora Substation supplies Distribution's Blouwater, Saldanha Steel and Smelter Substations. From the load forecast, it is evident that there will be a constraint at Aurora Substation. The projected new load of approximately 200 MVA that will be realised in the area together with the natural load growth will increase Aurora Substation demand from 517 MVA to approximately 890 MVA in year 2030. The firm capacity in the area will be exceeded in 2018 if the additional loads are to be supplied from Aurora Substation. The transformation capacity is also insufficient to evacuate all of the potential renewable energy generation planned in the area, amounting to 2 885 MW.

The scope of Saldanha Bay network strengthening project includes the following:

- » Construction of a new 400/132kV Transmission Substation in the Saldanha Bay area with a planned capacity of 3 x 500 MVA transformers. The transmission substation footprint will be 600m x 600m.
- » Construction of a new 132/66kV Distribution Substation near the current Blouwater Substation in the Saldanha Bay area. The distribution substation footprint will be 120m x 120m.

UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

- » The construction of two 400kV power lines (approximately 35 - 40 km) from the Aurora Substation to the new proposed distribution and transmission substations. A servitude of 55m is required for each power line.
- » Replacing two of the four existing 250 MVA 400/132kV transformers with 2 x 500 MVA transformers at Aurora Substation.
- » Establishing 2 x 132 kV feeder bays around Aurora Substation.

The proposed Distribution substation (Dx), Transmission substation (Tx) and power lines will be located in the Saldanha Bay area, approximately 130km north west of Cape Town, in the Western Cape Province. The location of the proposed substations and power lines will be within 20km from the coast. The closest towns are Saldanha Bay and Vredenburg. The following properties will potentially be affected by the construction of the proposed power lines and substations:

Yzervarkensrug Re/129; Yzervarkensrug 3/129; Yzervarkensrug 9/129; Muishond Fontein Re/6/137; Klipfontein Re/139; Klipfontein 1/139; Klipfontein 3/139; Klipfontein 4/139; Klipfontein 6/139; Adjoining Springfontein 174; Kerschbosch Re/175; Kerschbosch 1/175; Kerschbosch 3/175; Driehoeks Fontein Re/176; Driehoeks Fontein 1/176; Driehoeks Fontein 3/176; Springfontein 177 Re/177; Springfontein 4/177; Yzerfontein 3/178; Yzerfontein 5/178; Yzerfontein 8/178; Zoutekuylen 179; Groot Springfontein 1/180; Farm 181; Waschklip 183; Kleineberg 2/184; Farm 6/185; Farm 7/185; Farm 12/185; Farm 19/185; Langeberg Re/187; Langeberg 1/187; Langeberg 4/187; Langeberg Re/188; Langeberg 6/188; Uyekraal Re/189; Uyekraal 1/189; Uyekraal 2/189; Uyekraal 3/189; Everts Hope Re/190; Everts Hope 1/190; Oliphants Kop 2/191; Oliphants Kop 4/191; Oliphants Kop 5/191; Os Fontein Re/194 ; Farm 1/195; Farm 2/195; Farm Re/1029; Farm 1/1029; Farm 1038; Farm 185; Farm 1162; Farm 1223.

Alternative substation sites and power line corridors have been identified within a broader study area. These, together with any other feasible alternatives identified through the EIA process, will be assessed and preferred alternatives recommended for implementation.

Should the project be authorised by the National Department of Environmental Affairs (DEA), Eskom will then enter into a negotiation process with each affected landowner. The process of negotiating a servitude is independent of the EIA process, and will be undertaken directly by Eskom.

ENVIRONMENTAL IMPACT ASSESSMENT PROCESS

In terms of the EIA Regulations published in terms of Section 24(5) of the National Environmental Management Act (NEMA, Act No. 107 of 1998), Eskom requires authorisation from the National Department of Environmental Affairs (DEA) in consultation with the Western Cape Department of Environmental Affairs and Development Planning (DEA&DP) for the construction and operation of the proposed Dx substation, Tx substation and power lines. In terms of sections 24(5) of NEMA, the EIA Regulations published in GN R982 to GN R985, a Scoping and EIA are required to be undertaken for this proposed project. In order to obtain authorisation, comprehensive, independent environmental studies must be undertaken in accordance with the EIA Regulations.

Eskom has appointed Savannah Environmental, as the independent environmental consultants, to undertake the required EIA Process to identify and assess all the potential environmental impacts associated with the proposed project, and propose appropriate mitigation and management measures in an Environmental Management Programme (EMPr). As part of these environmental studies, I&APs will be actively involved through the public involvement process also being undertaken by Savannah Environmental.

The department and/or the organisation which you represent has been identified as a commenting authority for the proposed project. **In this regard, please can you provide us with the name and contact details of the relevant contact person at your department who should be liaised with regarding this project.** By registering on the project database, you will receive all information relating to the project and will be provided with an opportunity to provide comment and input into the EIA Process.

AVAILABILITY OF SCOPING REPORT

A Scoping Report has been prepared by Savannah Environmental and is available for review and comment by Interested and/or Affected Parties (I&APs). The 30-day period for public review is from **15 April 2016 – 18 May 2016**. The report can be viewed at the following locations:

- » Vredenburg Public Library (School Street, Vredenburg)
- » Hopefield Public Library (Oak Street, Hopefield)
- » Langebaan Public Library (Cnr. Oostewal & Bree Street, Langebaan)
- » Saldanha Bay Public Library (Berg Street, Saldanha)

The report is also available for download on www.savannahsa.com/projects. The due date for written comment is **18 May 2016**.


Please could you kindly submit your formal comments by sending written correspondence in this regard. All comments received will be included in the final Scoping Report which will be submitted to the DEA. Comments can be made as written submission via fax, post or email.

Our team welcomes your participation and looks forward to your involvement throughout this process.

Kind Regards

MRS GABRIELE WOOD
PUBLIC PARTICIPATION AND SOCIAL CONSULTANT
SAVANNAH ENVIRONMENTAL

From the desk of Lisa Pizzut-Nel
E-mail: lisa@savannahSA.com



MEMO

DATE: 15 April 2016
TO: Department of Environmental Affairs
ATT: Acting Deputy Director-General: Biodiversity and Conservation
REF: N/A
OUR REF: SE1376

Please acknowledge receipt of Notification of Environmental Impact Assessment Process and Availability of Scoping report for review for Saldanha Bay Network Strengthening Project, Western Cape (x1 CD)

NAME OF RECIEPIENT

Sello Phisoa

SIGNATURE:

Stamp

DATE RECEIVED:



UNIT 10, BUILDING 2, 5 WOODLANDS DRIVE OFFICE PARK, CNR. WOODLANDS DRIVE & WESTERN SERVICE ROAD, WOODMEAD, JOHANNESBURG
PO BOX 148, SUNNINGHILL, 2157, GAUTENG
TEL: +27 (0)11 656 3237 • FAX: +27 (0)86 684 0547 • E-MAIL: INFO@SAVANNAHSA.COM
WWW.SAVANNAHSA.COM

DIRECTORS: KM JODAS • J THOMAS • M MATSABU
COMPANY REGISTRATION NO.: 2006/000127/07
VAT REGISTRATION NO.: 4780226736

BFN (051) 001-3600
 CPT (021) 555-6777
 DUR (031) 569-3767
 ELS (043) 731-1480
 JNB (011) 928-8300
 M/O (021) 001-7188

PLZ (041) 581-8520
 PRY (012) 548-5056
 PTG (015) 285-0060
 WIT (013) 697-6100
 LON (+44) 1753-682-498



16926145

COURIER IT
 Excellence in motion

www.courierit.co.za

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

POD COPY

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	5E1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Langebaan Public Library	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	Cnr Oostersd & Bree street	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb		
City/Town		Code	City/Town	Langebaan	Code 7357
Contact	LISA	Tel. 011 656 3237	Contact	The Librarian	Tel. 022 707 5030
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E Q U I R E D D O M E S T I C	<input type="checkbox"/> BAKEDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	I N T E R N A T I O N A L	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY / AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS)	<input type="checkbox"/> INTERNATIONAL REGRAL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	<input checked="" type="checkbox"/> OVERNIGHT COURIER (18HR)	<input type="checkbox"/> OTHER SPECIFY	SPECIAL INSTRUCTIONS		VALUE FOR CUSTOMER		

CONTENTS	TOTAL PIECES	TOTAL MASS (Kgs)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
HC	1		DIMENSIONS (CM)				COLLECTED BY COURIERIT
INSURANCE: (PLEASE ✓)			NO.	L	W	H	DATE
REQUIRED <input type="checkbox"/> DECLARED VALUE R <input type="checkbox"/> DECLARED <input type="checkbox"/>			1	40	30	3	
OWNERS RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED BY			SIGNATURE				TIME
LISA			C. OFFER				8/6/16
NAME			PRICE OF DELIVERY				16:21
DATE			CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION				TIME
SIGNATURE			ID				
TIME			NO.				

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600
 CPT (021) 555-6777
 DUR (031) 569-3767
 ELS (043) 731-1480
 JNB (011) 928-8300
 H/O (021) 001-7188

PLZ (041) 581-8520
 PRY (012) 548-5058
 PTG (015) 285-0060
 WIT (013) 697-6100
 LON (+44) 1753-682-498



16926146

COURIER IT
 Excellence in motion

www.courierit.co.za

POD COPY.

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	54376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Vredenburg Library	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	School Street	
Suburb	CHR. WOODLANDS 'DR' WESTERN SERVICE WOODMEAD		Suburb		
City/Town		Code	City/Town	Vredenburg	Code 7380
Contact	LISA	Tel. 011 656 3237	Contact	Liberian	Tel. 082 701 7001
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E R V I C E D O D E S T I C I N T E R N A T I O N A L	<input type="checkbox"/> SAME DAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER @9H00	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	<input checked="" type="checkbox"/> OVERNIGHT COURIER 19H00	<input type="checkbox"/> OTHER SPECIFY			VALUE FOR CUSTOMS		

CONTENTS	TOTAL PIECES	TOTAL MASS (kg)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
HC	1		DIMENSIONS (CM)				COLLECTED BY COURIERIT
INSURANCE: (PLEASE ✓)			NO.	L	W	H	DATE
REQUIRED	<input type="checkbox"/>	DECLARED VALUE R	7	40	30	3	SIGNATURE
	<input type="checkbox"/>	DECLINED					DATE
OWNER'S SIGNATURE WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							NAME
USA							DATE
SIGNATURE							TIME
DATE							CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
15/11/16							ID NO.
SIGNATURE							
DATE							

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5056
 DJR (031) 560-3767 PTR (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-8100
 JNB (011) 828-8300 LON (+44) 1753-682-498
 W/O (021) 001-7188



16926147



www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Hopefield Library	
Street Address	UNIT 10, BLOCK 3, 5 WOODLANDS		Street Address	Oak Street	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb		
City/Town		Code	City/Town	Hopefield	
Contact	LISA	Tel. 011-656 3237	Contact		
E-mail			E-mail		

REQUERED
 SHOULD NO SERVICE BE SELECTED. COURIER IT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

<input type="checkbox"/> SAME DAY COURIER <input type="checkbox"/> DAYN COURIER (9AM) <input checked="" type="checkbox"/> OVERNIGHT COURIER (18H30)	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS) <input type="checkbox"/> ECONOMY (48 HRS PLMB) <input type="checkbox"/> OTHER SPECIFY	<input type="checkbox"/> SATURDAY <input type="checkbox"/> PUBLIC HOLIDAY / AFTER NOON	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS) <input type="checkbox"/> INTERNATIONAL COURIER (NOW DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY <input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT <input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
---	---	---	----------------------	--	--	--

VALUE FOR CUSTOMS

CONTENTS	TOTAL PIECES	TOTAL MASS (KG)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLAP
HC	1		DIMENSIONS (CM)				
INSURANCE (PLEASE CHECK)			NO	L	W	H	COLLECTED BY COURIER
REQUIRED <input type="checkbox"/>	DECLARED VALUE R	DECLINED <input type="checkbox"/>	1	30	30	3	SIGNATURE
DIMENSION RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							NAME
USA							DATE
15-4-16							TIME
SIGNATURE							CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
							ID NO

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 540-5056
 DUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 H/D (021) 001-7188



16926148

COURIER IT
 Excellence in motion

www.courierit.co.za

CO. REG. NO. 1998/010351/07
 VAT NO. 4120196526

POD COPY

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	5E1376	NOTE: PO. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Salisbury Bay Public Library	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	Boeg Street	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb		
City/Town	Code		City/Town	Code	
LISA		011-656-3227	Salisbury		7395
Contact	Tel.		Contact	The Librarian 022 714 1421	
E-mail			E-mail		

✓ **RESERVED** DOMESTIC

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

<input type="checkbox"/> SAMEDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
<input type="checkbox"/> DAWN COURIER (OWNED)	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY / AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
<input checked="" type="checkbox"/> OVERNIGHT COURIER (OWNED)	<input type="checkbox"/> OTHER SPEEDY			TAXES FOR CUSTOMS		

INTERNATIONAL

CONTENTS	TOTAL PIECES	TOTAL MARKS (UP)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
HC	1		DIMENSIONS (CM)				COLLECTED BY COURIERIT
INSURANCE: (PLEASE ✓)			NO	L	W	H	DATE
REQUIRED	DECLARED VALUE	DECLARED	1	50	3		SIGNATURE
OVERSEAS RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							NAME
L. J. ...							SIGNATURE
NAME			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				DATE
SIGNATURE			CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION				TIME
TIME			ID NO.				

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600
 CPT (021) 555-6777
 DJR (031) 569-3767
 ELS (043) 731-1480
 JNB (011) 829-8300
 H/O (021) 001-7188

PLZ (041) 591-8520
 PRY (012) 548-5058
 PTG (015) 285-0060
 WTT (013) 697-6100
 LON (+44) 1753-682-498



16926149

COURIER IT
 Excellence in motion

www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO.
TO BE BILLED

11860

NOTE: THE SENDER SHALL REMAIN
LIABLE FOR PAYMENT

SHIPPER'S
REFERENCE

SEB376

NOTE: P.O. BOX ADDRESSES
NOT ACCEPTED

From: (Sender) SAVANNAH ENVIRONMENTAL (PTY) LTD

Street Address: UNIT 10, BLOCK 2, 5 WOODLANDS
 Suburb: CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD
 City/Town: Code

Contact: LISA Tel: 011 656 3237

E-mail:

To: (Receiver) Department of Mineral Resources
 Street Address: Atterburg House, 9th Floor
 Suburb: 90 Lower Burg & Liebeck Street
 City/Town: Cape Town Code: 8012
 Contact: Duduzile Lunene Tel: 021 427 1000
 E-mail:

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E R V I C E D	DOMESTIC	<input type="checkbox"/> WEEKDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	INTERNATIONAL	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
		<input type="checkbox"/> DAY/NIGHT COURIER (9:00)	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS			<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> INTERNATIONAL REBAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
		<input checked="" type="checkbox"/> OVERNIGHT COURIER (1:00)	<input type="checkbox"/> OTHER SPECIFY				VALUE FOR CUSTOMS		

CONTENTS CO	TOTAL PIECES 1	TOTAL MASS (Kil) 1
INSURANCE: (PLEASE ✓)		
REQUIRED <input type="checkbox"/>	DECLARED VALUE R	DECLINED <input type="checkbox"/>
OWNER'S RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETELY COMPLETED BY		
NAME Lisa	DATE 15-4-16	
SIGNATURE	TIME	

COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				
DIMENSIONS (CM)				
NO.	L	W	H	
1	40	30	1	
DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				

EXPRESS PACK SECURITY NUMBER ON LIP OF FLAP	DATE
COLLECTED BY COURIERIT	TIME
SIGNATURE	PROOF OF DELIVERY
Stacey	13/04/16
(Signature)	12:05
SIGNATURE	TIME
CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION	
ID NO.	

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3500 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5058
 DUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WTY (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926151

COURIER IT
 Excellence in motion

www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED: 11860
 NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT
 SHIPPER'S REFERENCE: 5-1376
 NOTE: P.O. BOX ADDRESSES NOT ACCEPTED

From: (Sender) SAVANNAH ENVIRONMENTAL (PTY) LTD
 Street Address: UNIT 10, BLOCK 2, 5 WOODLANDS
 Suburb: CHR. WOODLANDS DREWESTERN SERVICE WOODMEAD
 City/Town: Code
 Contact: GISA Tel: 011-656-8237
 E-mail: 022-701-7116, 022-701-7099
 To: (Receiver) Sabonaha Bay Municipality
 Street Address: 12 main street, Ground Floor
 Suburb: Vredenburg
 City/Town: Code 7380
 Contact: Louw, @ Clr. Andie Kruger, @ Clr. Frank Prank, @ Clr. Niemand, @ Louis Scheepers (022-701-7192), @ Clr. F. Schippers, @ Nu Zeevogel

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R E Q U I R E D	<input type="checkbox"/> BAKEDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
<input checked="" type="checkbox"/> OVERNIGHT COURIER (1800)	<input type="checkbox"/> OTHER SPECIFY				TAXES FOR CUSTOMS		

CONTENTS: CDs (16)	TOTAL PIECES: 1	TOTAL MASS (kg):	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
INSURANCE: (PLEASE ✓)			DIMENSIONS (CM)				COLLECTED BY COURIERIT
REQUIRED <input type="checkbox"/>	DECLARED VALUE R	DECLINED <input type="checkbox"/>	NO	L	W	H	PROOF OF DELIVERY
SIGNATURE: GISA			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				CONFIRMED SECURITY PACK NUMBER AND RECD ID NO.
DATE: 15-4-16							

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF IT.

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 948-5058
 DUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 W/D (021) 001-7188



16926152

COURIERIT
 Excellence in motion

www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	5E1376	NOTE: PO, BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	West Coast District Municipality	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	58 Long Street	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb		
City/Town	Code		City/Town	Code	
Contact	LISA Tel. 011 656 8237		Contact	Maarreesburg 7310 Doretha Kotze 022 433 8400	
E-mail			E-mail	Charles Malherbe	

✓ **RESERVED** DOMESTIC SERVICE

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

<input type="checkbox"/> SAME DAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
<input type="checkbox"/> DAWN COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY / AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
<input checked="" type="checkbox"/> OVERNIGHT COURIER 18000	<input type="checkbox"/> OTHER SPECIALTY			VALUE FOR CUSTOMS		

CONTENTS	TOTAL PIECES	TOTAL MASS (KG)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY			EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
CD	1		DIMENSIONS (CM)			COLLECTED BY COURIERIT
INSURANCE: (PLEASE ✓)			NO.	L	W	H
REQUIRED <input type="checkbox"/>	DECLARED VALUE R	DECLINED <input type="checkbox"/>	1500	70	7	
WHEN RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED						SIGNATURE
COMPLETED BY						DATE
LISA						18/4/2016
NAME						DATE
DATE						11h24
SIGNATURE						TIME
TIME						
			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS			CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
			ID NO.			

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5056
 DJR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 791-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926153



POD COPY.

CO. REG. NO. 1998/010351/07
 VAT NO. 4120185526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	16E1370	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
--------------------------	-------	--	---------------------	---------	---------------------------------------

From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD	To: (Receiver)	SANRAL
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS	Street Address	1 Haverenga Street
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD	Suburb	Oakdale
City/Town		City/Town	Belville
Contact	LISA Tel. 011 656 3237	Contact	René de Kock 021 957 4600
E-mail		E-mail	

SHOULD NO SERVICE BE SELECTED, COURIER IT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ S E R V I C E D	DOMESTIC	<input checked="" type="checkbox"/> SAME DAY COURIER	<input type="checkbox"/> HIGH EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	INTERNATIONAL	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
		<input type="checkbox"/> DAYTIME COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLANS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS			<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
		<input checked="" type="checkbox"/> OVERNIGHT COURIER 10:00	<input type="checkbox"/> OTHER SPEEDY				VALUE FOR CUSTOMS		

CONTENTS	TOTAL PIECES	TOTAL MASS (kg)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER OR LIP OF FLYER	
CD	1		DIMENSIONS (CM)				COLLECTED BY COURIER IT	
INSURANCE: (PLEASE ✓)			NO	L	W	H		
REQUIRED <input type="checkbox"/> DECLARED VALUE R <input type="checkbox"/> DECLINED <input type="checkbox"/>			7	60	30	7		
WHEN THIS WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED BY								
USA								
SIGNATURE			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				PROOF OF DELIVERY	
DATE 15-4-16							Z. Tsholi	18.04.16
								09:32
							CONFIRMED ACCOUNT CASH RECEIPTS AND RECEIVED IN GOOD ORDER AND CONDITION	
							ID NO.	

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 591-8520
 CPT (021) 555-6777 PRY (012) 548-5056
 OUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WTT (013) 697-6100
 JNB (011) 828-8300 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926154

COURIER IT
 Excellence in motion

www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1370	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	ZAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	South African National Parks	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	TPIC Centre, 1st Floor	
Suburb	CHR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb	Chr Bottelary Road & Amondal Drive	
City/Town		Code	City/Town	Kullsviver	
Contact	LISA	Tel. 011 656 3237	Contact	Willem Louw	Tel. 021 94016414
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E Q U I R E D O M E A T I C	<input type="checkbox"/> SAMEDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	I N T E R N A T I O N A L	<input type="checkbox"/> INTERNATIONAL COURIER (DOCE)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER @0600	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCE)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	<input checked="" type="checkbox"/> OVERNIGHT COURIER 18000	<input type="checkbox"/> OTHER SPECIAL			VALUE FOR CUSTOMS		

SPECIAL INSTRUCTIONS

CONTENTS	TOTAL PIECES	TOTAL MASS (kg)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
CD	1	1	DIMENSIONS (CM)				COLLECTED BY COURIERIT
			NO	L	W	H	18/4/2016
			1	40	30	9	DATE
							SIGNATURE
							PROOF OF DELIVERY
							E. B. J. de
							NAME
							18/4
							DATE
							9:15
							TIME
							CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
							ID NO.

INSURANCE: (PLEASE ✓)
 REQUIRED DECLARED VALUE R DECLINED

OWNER'S SIGNATURE: *NDC* DATE: 15-4-16

SIGNATURE: *[Signature]* TIME: _____

DIMENSIONS GENERATED BY SWAD MACHINE
 SUPERSEDE MANUAL DIMENSIONS

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5058
 DUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926155



www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE9376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Herbige Western Cape	
Street Address	UNIT10, BLOCK 2, 5 WOODLANDS		Street Address	Protea Assurance Building	
Suburb	CHR. WOODLANDS 'DRAWESTERN' SERVICE WOODMEAD		Suburb	Green market Square	
City/Town	Code		City/Town	Code	8000
Contact	TEL	011-656-0237	Contact	TEL	021-4839685
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E Q U I R E D D O W N S E R V I C E	<input type="checkbox"/> BAKEDAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS 	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER 0600	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY/AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	<input checked="" type="checkbox"/> OVERNIGHT COURIER 1800	<input type="checkbox"/> OTHER SPECIFY			TALOR FOR CUSTOM		

CONTENTS	TOTAL PRICES	TOTAL MARK (R)
CD+HP 1		
INSURANCE: (PLEASE ✓)		
REQUIRED <input type="checkbox"/> DECLARED VALUE R. <input type="checkbox"/> DECLINED <input type="checkbox"/>		
CHIEF OF STA WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED		
COMPLETED BY: <u>dlon</u>	DATE: <u>15-4-16</u>	
SIGNATURE	TIME	

COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				
DIMENSIONS (CM)				
NO.	L	W	H	
1	40	30	3	
DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				

EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER	
COLLECTED BY COURIERIT	
SIGNATURE	DATE
PROOF OF DELIVERY	
SIGNATURE	DATE
<u>V. Robinson</u>	<u>18/04/2016</u>
	<u>09:50</u>
CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION	
ID NO. <u>6309170207184</u>	

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5056
 DUR (031) 559-3767 PTG (015) 285-0060
 ELS (043) 781-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926156



POD COPY

CO. REG. NO. 1998/010351/07
VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Dep Agriculture, Forestry & Fisheries	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		Street Address	Delpen Building, Office 270	
Suburb	CNR. WOODLANDS DRAWESTERN SERVICE WOODMEAD		Suburb	Cnr Annie Botha & Union Streets	
City/Town		Code	City/Town	Code 0084	
Contact	LISA	Tel.	Contact	Tel 012 319 7634	
E-mail			E-mail	012 319 7619	

SHOULD NO SERVICE BE SELECTED. COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

<input type="checkbox"/> SAMEDAY COURIER <input type="checkbox"/> DAWN COURIER 09H00 <input checked="" type="checkbox"/> OVERNIGHT COURIER 10H30	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS) <input type="checkbox"/> ECONOMY (48 HRS PLUS) <input type="checkbox"/> OTHER SPECIFY	<input type="checkbox"/> SATURDAY <input type="checkbox"/> PUBLIC HOLIDAY / AFTER HOURS	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.) <input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY <input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT <input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
--	---	--	----------------------	--	--	--

VALUE FOR CUSTOMS

CONTENTS	TOTAL PIECES	TOTAL MASS (kg)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER
CD'S	1		DIMENSIONS (CM)				DN LIP OF FLYER
INSURANCE: (PLEASE ✓)			NO.	L	W	H	COLLECTED BY COURIER
REQUIRED	<input type="checkbox"/> DECLARED VALUE R	<input type="checkbox"/> DECLARED	1	40	20	1	SIGNATURE
OWNERS RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							NAME
							SIGNATURE
							DATE
							TIME
							DATE
							TIME
							DATE
							TIME

DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS
 CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
 ID NO.

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3500 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5056
 OUR (031) 569-3767 PTG (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LOM (+44) 1753-682-498
 N/D (021) 001-7188



16926157

COURIERIT
Excellence in motion

www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010351/07
VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Dep. Wader & Sonutaker	
Street Address	UNIT 10, BLOCK 2, S WOODLANDS		Street Address	3 Blarckenberg street	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb		
City/Town		Code	City/Town	Cape Town	Code 7530
Contact	LISA	Tel 011 556 3237	Contact	RASHID KHAN	Tel 021 941 6000
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

✓ R S E Q U E R I D E D	<input type="checkbox"/> SUNDAY COURIER <input type="checkbox"/> DAWN COURIER 0600 <input checked="" type="checkbox"/> OVERNIGHT COURIER 1000	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS) <input type="checkbox"/> ECONOMY (A9 HRS PLUS) <input type="checkbox"/> OTHER SPECIFY	<input type="checkbox"/> SATURDAY <input type="checkbox"/> PUBLIC HOLIDAY/ AFTER HOURS	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.) <input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY <input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT <input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	VALUE FOR CUSTOMS						

CONTENTS	TOTAL PIECES	TOTAL MASS (Kgs)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER
CD + HC	1	1	DIMENSIONS (CM)				COLLECTED BY COURIERIT
INSURANCE: (PLEASE ✓)			NO	L	W	H	DATE
REQUIRED <input type="checkbox"/> DECLARED VALUE R <input type="checkbox"/> DECLINED <input type="checkbox"/>			7	30	3		SIGNATURE
OWNERS RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							SIGNATURE
NAME	DATE						DATE
SIGNATURE	TIME						TIME
			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
			ID NO.				

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFM (051) 001-3600
 CPT (021) 555-8777
 DUR (031) 569-3787
 ELS (043) 731-1480
 JNB (011) 928-6300
 N/O (021) 001-7188

PLZ (041) 581-8520
 PRY (012) 548-5058
 PTG (015) 285-0060
 WIT (013) 697-8100
 LON (+44) 1753-682-498



16926158

COURIERIT

Excellence in motion

www.courierit.co.za

POD COPY

CO. REG NO. 1998/010361/07.
 VAT NO. #120195625

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Cape Nature Scientific Services	
Street Address	UNIT 10, BLOCK 2, 5 WOODLANDS		By post Address	Aseycaribosch Nature Reserve	
Suburb	CHR. WOODLANDS DRAWESTERN SERVICE WOODMEAD		Suburb	Jonkershoek	
City/Town		Code	City/Town	Stellenbosch	
Contact	LISA	Tel. 011-656 3237	Contact	Stena Puffel-Cerriem	
E-mail			E-mail	021 866 8000	

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER.

REQU SERVI CED	<input type="checkbox"/> SAME DAY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DUE-1)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AIRFREIGHT
	<input type="checkbox"/> DAWN COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY / AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DUE-1)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
	<input checked="" type="checkbox"/> OVERNIGHT COURIER 19H30	<input type="checkbox"/> OTHER SPECIFY			VALUE FOR CUSTOMS		

CONTENTS	TOTAL PIECES	TOTAL MASS (KG)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER ON LAP OF FLYER
FL + CD	1		DIMENSIONS (CM)				COLLECTED BY COURIERIT
INSURANCE: (PLEASE CHECK)			NO.	L	W	H	19/10/2016
REQUIRED <input type="checkbox"/> DECLARED VALUE <input type="checkbox"/>			1	60	30	3	12:20
OTHERS P/B WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY
COMPLETED BY							SULET GLODUMS
NAME		DATE					NAME
SIGNATURE		TIME					SIGNATURE
			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION
			ID NO.				ID NO.

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT.

BFM (051) 001-3800 PLZ (041) 581-8520
 CPT (021) 553-8777 PRY (012) 548-3056
 DUR (031) 569-3787 PTG (015) 285-0060
 ELS (043) 731-1480 WIT (013) 897-6100
 JND (011) 828-8308 LON (+44) 1753-682-498
 H/O (021) 001-7188



16926159



www.courierit.co.za

POD COPY

CO. REG. NO. 1998/010361/07
 VAT NO. 4120195526

ACCOUNT NO. TO BE BILLED	11850	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE 1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SACANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Dep Agriculture & Rural Development	
Street Address	UNIT 10, BLOCK 2, S WOODLANDS		Street Address	3rd floor, main building	
Suburb	CNR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb	Muldersklei Road	
City/Town		Code	City/Town	Eisenberg	
Contact	LISA	011-656 0237	Contact	Car van der Walt Tel. 021 808 50819	
E-mail			E-mail		

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

<input type="checkbox"/> SANDEY COURIER	<input type="checkbox"/> NON EXPRESS DELIVERY (24 - 48 HRS)	<input type="checkbox"/> SATURDAY	SPECIAL INSTRUCTIONS	<input type="checkbox"/> INTERNATIONAL COURIER (DOCS.)	<input type="checkbox"/> CROSS BORDER ECONOMY	<input type="checkbox"/> INTERNATIONAL AFFRUIT
<input type="checkbox"/> GAWA COURIER SERVICE	<input type="checkbox"/> ECONOMY (48 HRS PLUS)	<input type="checkbox"/> PUBLIC HOLIDAY AFTER HOURS		<input type="checkbox"/> INTERNATIONAL COURIER (NON DOCS.)	<input type="checkbox"/> INTERNATIONAL REMAIL	<input type="checkbox"/> INTERNATIONAL DEFERRED COURIER
<input checked="" type="checkbox"/> OVERNIGHT COURIER 14H30	<input type="checkbox"/> OTHER SPECIFY			VALUE FOR CUSTOMS		

CONTENTS: CD

TOTAL PIECES: 1

TOTAL MASS (kg): 15-4-16

INSURANCE: (PLEASE ✓)

REQUIRED DECLARED VALUE R DECLINED

OWNERS RISK WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED COMPLETED BY

Signature: [Signature] NAME: LISA DATE: 15-4-16

COURIER SERVICES APPLY TO MAJOR CENTRES ONLY

DIMENSIONS (CM)

NO.	L	W	H
1	30	30	1

DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS

EXPRESS PACK SECURITY NUMBER ON LIP OF FLYER

COLLECTED BY COURIERIT

SIGNATURE: [Signature] TIME: [Time]

PROOF OF DELIVERY

NAME: [Signature] DATE: 19/4/16

UNIFORMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION

ID NO. [Blank]

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT

BFN (051) 001-3600 PLZ (041) 581-8520
 CPT (021) 555-6777 PRY (012) 548-5058
 DUR (031) 569-3767 PTC (015) 285-0060
 ELS (043) 731-1480 WIT (013) 697-6100
 JNB (011) 928-8300 LON (+44) 1753-682-498
 N/D (021) 001-7188



16926175

CO. REG. NO. 1898/010351/07
 VAT NO. 4120195526

COURIER IT
 Excellence in motion

www.courierit.co.za

ACCOUNT NO. TO BE BILLED	11860	NOTE: THE SENDER SHALL REMAIN LIABLE FOR PAYMENT	SHIPPER'S REFERENCE	SE1376	NOTE: P.O. BOX ADDRESSES NOT ACCEPTED
From: (Sender)	SAVANNAH ENVIRONMENTAL (PTY) LTD		To: (Receiver)	Cape Dep Transport & Public Works	
Street Address	UNIT10, BLOCK 2, 5 WOODLANDS		Street Address	8th Floor	
Suburb	CHR. WOODLANDS DR & WESTERN SERVICE WOODMEAD		Suburb	9 Dorp Street	
City/Town	LISA	Code	City/Town	Cape Town	Code 8001
Contact		Tel. 011-656-3237	Contact	Malcom walters	021 483 2419
E-mail			E-mail	Mario Brown	021 483 2604

✓
R
S
E
Q
U
I
R
E
D

D
O
M
E
S
T
I
C

SHOULD NO SERVICE BE SELECTED, COURIERIT RESERVES THE RIGHT TO MARK THE SERVICE OVERNIGHT COURIER OR INTERNATIONAL COURIER

- SAMEDAY COURIER
 MON EXPRESS DELIVERY (21 - 48 HRS)
 SATURDAY
 DAWN COURIER SERVICE
 ECONOMY (48 HRS PLUS)
 PUBLIC HOLIDAY/AFTER HOURS
 OVERNIGHT COURIER (1030)
 OTHER SPECIFY

SPECIAL INSTRUCTIONS

I
N
T
E
R
N
A
T
I
O
N
A
L

- INTERNATIONAL COURIER (DOCS)
 CROSS BORDER ECONOMY
 INTERNATIONAL AIRFREIGHT
 INTERNATIONAL COURIER (NON DOCS)
 INTERNATIONAL REMAIL
 INTERNATIONAL DEFERRED COURIER

VALUE FOR CUSTOMER

CONTENTS	TOTAL PIECES	TOTAL MALES (kg)	COURIER SERVICES APPLY TO MAJOR CENTRES ONLY				EXPRESS PACK SECURITY NUMBER	ON LIP OF FLYER
CDs	1		DIMENSIONS (CM)				COLLECTED BY COURIERIT	
INSURANCE: (PLEASE ✓)			NO.	L	W	H	DATE	
REQUIRED	DECLARED VALUE	DECLINED	1	400	20	1	SIGNATURE	TIME
OTHER FEES WILL APPLY IF THIS INSURANCE SECTION IS PARTIALLY OR NOT COMPLETED							PROOF OF DELIVERY	
COMPLETED BY							SA WEBB-OLIVER 18/4/2016	
LISA							DATE	
B-4-16							SIGNATURE	
SIGNATURE							TIME	
			DIMENSIONS GENERATED BY SWAD MACHINE SUPERSEDE MANUAL DIMENSIONS				CONFIRMED SECURITY PACK NUMBER AND RECEIVED IN GOOD ORDER AND CONDITION	
			ID NO.					

PLEASE NOTE: TERMS ARE STRICTLY 30 DAYS. I AGREE TO BE BOUND BY THE STANDARD CONDITIONS OF CARRIAGE WHICH APPEAR ON THE REVERSE SIDE OF THIS DOCUMENT