

A decorative graphic on the left side of the slide, consisting of four overlapping circles. The top circle shows a person working at a computer with a green circuit board background. The second circle shows a large, modern white building with a central tower. The third circle shows a city skyline at night with a prominent tower. The bottom circle shows a high-voltage power line tower against a blue sky with clouds.

The Eskom Transmission Development Plan 2018 to 2027 (TDP 2017)

Public Forum

19 October 2017

A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a high-voltage electricity pylon. The middle frame shows a large industrial facility with several tall cooling towers and a body of water in the foreground. The bottom frame shows a close-up of a white wind turbine against a blue sky.

Keynote address and setting-the-scene

Presented by: Thava Govender
Group Executive: Transmission
Acting Group Executive: Risk and Sustainability

The Objective of the presentation is to:

- Contextualise the planning timelines relating to the demand forecast and generation patterns
- Share assumptions and results from the Transmission Development Plan 2018 – 2027
- Share information and results relating to the integration of RE as per the DOE IPP programmes and address future requirements as per the IRP
- Share information on the estimated Transmission Capital Investment Requirements for period 2018 – 2027
- Solicit comments and inputs from stakeholders on the Transmission plans for improvements

Integrated Resource Plan (IRP)

- The Department of Energy (Energy Planner) is accountable for the Country Electricity Plan, which is called the Integrated Resource Plan For Electricity (IRP 2016 - draft).
- The Integrated Resource Plan (IRP) is intended to drive all new generation capacity development.
- NERSA licences new generators according to this determination.

Strategic Grid Plan (SGP)

- The Strategic Grid Plan formulates long term strategic transmission corridor requirements
- The Plan is based on a range of generation scenarios, and associated strategic network analysis
- Horizon date is 20 years
- Updated every 2 - 3 years

Transmission Development Plan (TDP)

- The Transmission Development Plan (TDP) represents the transmission network infrastructure investment requirements
- The TDP covers a 10 year window
- Updated annually
- Indicates financial commitments required in the short to medium term

The TDP 2017 was formulated to address the following:


- Attain Grid Code compliance by resolving both substation and line deviations
- Determine new network infrastructure requirements to sustain and allow for future demand growth
- Determine new network infrastructure requirements to integrate new generation (Eskom and IPPs)




Recent Achievements

To date, a large amount of construction work has been completed, adding ~8.363 MW, ~6.799 km of transmission network, and ~33.59 GVA sub-stations...


Generation (MW)




Transmission lines (km)




Transmission Substations (MVA)



Major Transmission Projects commissioned in the last 5 years




REIPP Programme Overview – end August 2017



Eskom has committed capital to enable the integration of successful bidders (Bid Window 1 – 4B, including Smalls) into the National Grid.

Distribution of approved IPP projects to date:

Total approved capacity: 8 269 MW



Status to date:

- 3 520 MW of REIPP, commissioned and in commercial operation
- 1 004.5 MW of DoE Peakers commissioned and in commercial operation

Total IPP Generation in commercial operation: 4 524.5 MW

Salient facts concerning future IPP integration:

- Much of the capacity in high interest areas is depleted
- Extensive network development will be required to enable integration of future IPPs
- EIA, Servitude requirements, licensing requirements and efficient project execution are critical for future IPP integration

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The larger, outer frame contains a low-angle shot of a white wind turbine against a clear blue sky. The smaller, inner frame, which is partially overlapping the bottom-left of the larger one, contains a vibrant sunset or sunrise scene with a bright sun low on the horizon, casting a golden glow over a dark landscape. The entire graphic is set against a background of blue and white curved lines that sweep across the slide.

Planning for the South African Integrated Power System

The TDP Assumptions

Presented by: Ronald Marais

Integrated Resource Plan (IRP)

- The Department of Energy (Energy Planner) is accountable for the Country Electricity Plan, which is called the Integrated Resource Plan For Electricity (IRP 2016 - draft).
- The Integrated Resource Plan (IRP) is intended to drive all new generation capacity development.
- NERSA licences new generators according to this determination.


Strategic Grid Plan (SGP)

- The Strategic Grid Plan formulates long term strategic transmission corridor requirements
- The Plan is based on a range of generation scenarios, and associated strategic network analysis
- Horizon date is 20 years
- Updated every 2 - 3 years


Transmission Development Plan (TDP)

- The Transmission Development Plan (TDP) represents the transmission network infrastructure investment requirements
- The TDP covers a 10 year window
- Updated annually
- Indicates financial commitments required in the short to medium term


Linkages between the various plans



TDP Timelines




Assumed Transmission Capacity Forecast and Comparisons




South Africa Load Overview


0 135 270 540 810 1 080 Kilometers






2018



2027




TDP Generation Base Scenario



2040 Tx Study – Generation Spatial Allocation

Transmission to enable IRP
requires Spatial Information


Generation Energy Resources for Electricity




However, there is uncertainty in terms of:

- Where is the location?
- What is the size?
- What is the type?



Solar





Wind




Gas




Coal






Current Generation Footprint



Future Generation Footprint



The new Generation Pool drives significant new Transmission Infrastructure over long distances


Tx Strategy to increase Grid Access to meet future needs of the IRP and customers

Change in generation diversity has major impact on future Tx Grid


- Grid Access – Increased connection capacity needed in new areas (**delivery time > 8yrs**)
- On Time Connection – Smaller IPP generation plant can be constructed faster (**delivery time < 5yrs**)
- Unknown locations - Multiple unspecified IPP sites require market access for best price

Change in Location - Spatial Footprint


Current Generation Footprint



Future Generation Potential Footprint



Change in Construction 3yr - 5yr Speed of IPP plant rollout



Beyond 2020 Demand Balance significantly changed by dispersed generation in South

Strategic EIAs & Servitudes can enable faster grid development



1. Strategic Investment in the EIAs & Land acquisition is critical to meet future IRP connection timeframes

2. Reducing Tx investment today compounds future Tx Grid rollout leading to high risk of Gx capacity delays

Significantly More transmission corridors and grid access required


SEA Corridor:




Change of Spatial Footprint into areas with limited Demand requires additional Transmission Capacity

Need to reduce the time to increase grid access by investing in strategic access and corridors servitudes

Assumed Generation Pattern for the TDP 2017





Questions?

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The top frame shows a white wind turbine against a clear blue sky. The bottom frame shows a sunset or sunrise over a landscape with hills, with the sun low on the horizon and a bright orange glow. The frames are surrounded by several thin, concentric, hand-drawn style lines in a light brown color.

Planning for the South African Renewable Energy IPP Integration

Presented by: Makoanyane Theku



Independent Power Producer (IPP) integration

Status to-date (end August 2017)



Program	No. of Projects	MW Contribution	Current Status
REIPPPP BW 1	28	1 436	All projects connected
REIPPPP BW 2	19	1 054	All projects connected
REIPPPP BW 3&3.5	23	1 656	14 projects connected, 8 in execution, 1 project in BW 3.5 awaiting financial close
REIPPPP BW 4	13	1 121	Budget quotation phase
REIPPPP BW 4B	13	1 084	Budget quotation phase
Smalls (1-5 MW)	10	50	Budget quotation phase
DoE Peakers	2	1 004.5	All projects connected
Coal Baseload	2	863.5	Budget quotation phase
Total	110	8 269	

Successful Bidders: REIPP Bid Window 1 - 4B



IPPs Bid Window 1 to 4b


Grid enablement for IPP integration in the medium to long term (2018 – 2027)*

- Most of the available grid capacity will be exhausted beyond BW 4B
- TDP assumption for IPP programmes beyond REIPP BW 3.5 are shown below:

IPP Bid window / Projects	Total allocated / Assumed capacity (MW)	Total cost estimates for Infrastructure requirements included in the 2018 – 2017 TDP
REIPPPP BW 4 & 4B	2205	✓
Coal Baseload (Khanyisa and Thabametsi)	900	✓
New OCGT / CCGT generation Dedisa and Athene Substations	3732	✓
Future REIPP (Solar PV)	3500	✓
Future REIPP (wind)	4400	
Future REIPP (CSP)	450	

* Assumptions as per the IRP Baseline Plan

Transmission Connection Requirements: Future DoE RE Programme (Wind, CSP, PV)



Issues to Consider

- Servitude and EIA restrictions
- Lead times:
 - Long Tx lines: 6 - 8 years
 - Large Power stations: 8 - 10 years
 - Distributed IPP plants: 2 - 5 years
- Use all appropriate proven technology available:
 - HVDC, EHV AC, HVDC conversions of existing AC lines, multiple circuit AC lines
- Transmission technology choice must be compatible with strategic power system development plan

RE Grid Access issues


- IPP developments tend to be in close proximity of Eskom substations. This sometimes restricts access to other RE IPP participants due to limited power line corridors through IPP properties.
- Subsequent to REBID 1 - 4 there is limited spare capacity on the Distribution networks and in some cases, Transmission networks.
- Due to uncertainty of allocation of Preferred IPP Bidders, quotations are issued on an individual basis i.e. no other application is considered in the quotation. This potentially raises / reduce the cost of connection per quotation.

Grid enablement initiatives to expedite future IPP integration (Strategic IPP Masterplan)

- The Grid Enablement team was established (under the auspices of Eskom and DoE IPP Office). The following grid enablement initiatives are in progress:
 - Conduct joint Distribution & Transmission infrastructure masterplan to enable future IPP integration. (Complete)
 - Identify strategic development corridors to enable speedy integration of future IPP (Complete)
 - Investment approval for EIA, servitude acquisition and required licenses (Pending)
 - Align the timetables of the IPP programme to the timetables of the grid plans (Pending)

IPP Connection Framework

Basis for enabling future IPP programmes




Spatial locations of identified REIPPs

Long term

Total **35 GW**


LEGEND

- CSP
- Solar PV
- Wind Energy



Province	Total
NC	19 GW
WC	6.6 GW
EC	5.2 GW
FS	3.2 GW
NW	1.1 GW

**Total RE generation capacity assumption per substation (2017 TDP period)
IRP Baseline Plan aligned**



TDP plans for IPP Integration


LEGEND

- Existing Transmission Substations
- New Transmission Substations (TDP)
- Additional 400/132kV transformer/s
- 400/132kV Integration
- New Transmission Substations
- 765 kV line
- 400 kV line
- 275 kV line
- 220 kV line
- 132kV line

Planned transmission lines are represented by dotted lines

2024r IPP integration plans: Strategic


- Rebuild of 132kV transmission structure
- Upgrade of 400kV transmission structure
- Upgrade of 275kV transmission structure
- Upgrade of 220kV transmission structure
- Upgrade of 132kV transmission structure
- OCGT Integration (Richards Bay)




Lowest level of Confidence

- Unconfirmed IPP location, timing & scope
- Some of the key development enabling activities have not started / in initial phase

Main corridor EA / servitude requirements supplementary to the SEA (Proposed modification)




- Grid Enablement team feedback:
 - Provided valuable insights and skills, which has enriched the infrastructure development process
 - Engagements are paramount in improving process effectiveness, quality of input assumption, connection criteria fundamentals as well as continually improving plans as necessary.
- Potential opportunities for future initiatives
 - Optimize integration process between DOE IPP and Eskom network development plan by:
 - Recommending IPP procurement programme towards areas where network capacity is available.
 - Target specific geographic areas for IPP projects to optimize on timelines for readiness of the grid infrastructure



Questions?

Provincial Plans TDP 2018 – 2027



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a worker in a white hard hat and blue shirt operating a red bucket lift. The middle frame shows a large industrial building with a curved roof and several tall smokestacks, with zebras in the foreground. The bottom frame shows a series of high-voltage power line towers stretching across a landscape under a blue sky.


North-West Province

Presented by: Queen Melato (Planning Engineer)

North-West Province Profile

Load

Peak load of 3171MW: 16 Nov 2015



Generation

Type		Name	Output
Base Load	Coal	Matimba	3360 MW
		Medupi	1588 MW
Renewable Energy	PV	RustMo1 Solar	7 MW
Total			4955 MW
Approved REIPPPP Projects		PV	225 MW
REIPPPP Total			225 MW



A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The top frame shows a low-angle shot of a white wind turbine against a clear blue sky. The bottom frame shows a sunset or sunrise over a landscape with hills, with the sun low on the horizon and a bright orange glow. The entire graphic is set against a background of blue and white curved lines.

Achievements in the Platinum Province

Carletonville Customer Load Network (CLN)



- Unlocked capacity for electrification and industrial activities.
- Created capacity for connection of RE plants in and around Vryburg.




- **Unlocked capacity for mining, industrial activities and tourism.**

Load Forecast



North-West Province Load Forecast



* Compound Annual Growth Rate



Generation Forecast



RE Projections (10 year):

- **Approximately 0.55 GW**
- Mookodi Substation:
475 MW
- Watershed Substation:
75 MW




Network Development Plan


Developments in the Rustenburg CLN



2028
2716MW




- 2x Medupi-Ngwedi 400kV lines (1x 765kV design) - near Mogwase
- Ngwedi substation - around Sun City
- Marang Extension - next to Rustenburg Municipality
- Bighorn Extension - near Marikana
- Dinaledi 3rd Transformer in Madibeng / Brits





Developments in the Carletonville CLN

2028
1883MW



- Pluto-Mahikeng 400kV line
- Mahikeng substation
- Mookodi-Mahikeng 400kV lines
- Hermes-Mookodi 400kV line
- Mookodi-Hotazel 400kV line



A decorative graphic on the left side of the slide, consisting of four overlapping circular frames. The top frame shows a worker in a red bucket. The middle frame shows wind turbines. The bottom-left frame shows a power plant with zebras in the foreground. The bottom-right frame shows high-voltage power lines.


Limpopo Province

Planning Engineer: Dalton Matshidza


Presented by: Queen Melato

Limpopo Province Profile

■ Peak load of 2960 MW : 19 October 2015



Type		Name	Output
Base Load	Coal	Matimba	3990 MW
		Medupi	1692 MW
Renewables	Photo Voltaic	Witkop	30 MW
		Soutpan	28 MW
		Villa Nora	60 MW
Eskom Total			5800 MW
Approved REIPPPP Projects		PV	118 MW
		Coal (Future)	600 MW
REIPPPP Total			118 MW




Achievements



Achievements


- Borutho 400kV Integration
- Foskor 3rd 250MVA Transformation
- Acornhoek Transformation Upgrade
- Spitskop Transformation Upgrade
- Dwarsberg 132kV Switching Station
- Medupi Transmission Integration



Load Forecast



Limpopo Province Load Forecast







Network Development Plan

Developments in the Polokwane CLN

2020
1162 MW




- Nzhelele 400kV Integration
 - Nzhelele 400/132kV substation (1st and 2nd 250MVA)
 - Tabor-Nzhelele 400kV line
 - Borutho-Nzhelele 1st 400kV line
- Limpopo East Corridor Strengthening
 - Spencer 400/132kV Transformation (1st 400MVA 400/132kV Transformer)
 - Foskor-Spencer 1st 400kV line (110km)
- Install Capacitor Banks at:
 - Tabor MTS
 - Spencer MTS
 - Nzhelele MTS




Developments in the Lephalale CLN

2027
2113 MW




- Medupi Transmission Integration
- Waterberg Generation Integration at 400kV
- Borutho 3rd 500MVA 400/132kV transformer






Developments in the Phalaborwa CLN

2017
1484 MW



- Highveld North-West and Lowveld North Reinforcement-Phase 2
 - Silimela 400/132kV substation
 - Manogeng Switching Station
- Tubatse Strengthening Scheme Phase 1
 - Senakangwedi B MTS) 400/275kV Substation (1st 800MVA 400/275 kV transformer)
- Foskop & Acornhoek 275/132kV Transformation Upgrades
 - Foskop-Merensky 2nd 275kV Line (400kV)
- Limpopo East Corridor Strengthening Tabor MTS
 - Foskop-Spencer 1st 400kV line



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a worker in a white hard hat and blue shirt working on a red structure. The middle frame shows a large industrial building with a curved roof and several tall chimneys, with zebras in the foreground. The bottom frame shows a series of high-voltage power line towers stretching across a landscape under a blue sky.

Mpumalanga Province

Planning Engineer: Kabir Singh

Presented by: Thamsanqa Ngcobo

2016 Peak load of 3934 MW

[illegible]

Achievements



- **Gumeni 400/132 kV 500 MVA substation**
- **Hendrina-Gumeni 400 kV line**




- **Kusile 400 kV HV Yard**
- **Minerva - Duvha and Kendal – Apollo 400 kV lines loop in and out**

Load Forecast



Mpumalanga Load Forecast 2018 - 2027



* Compound Annual Growth Rate

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The larger, outer frame contains a low-angle shot of a white wind turbine against a clear blue sky. The smaller, inner frame, positioned in front of the bottom-left of the larger one, shows a vibrant sunset or sunrise with a bright sun low on the horizon, casting a golden glow over a dark landscape. The entire graphic is set against a background that transitions from a deep blue at the top left to a light blue at the bottom left, with a thin, curved white line separating the blue areas.

Generation Forecast

Commissioning schedule

Station	Kusile		Khanyisa IPP	
Year	Unit	MW	Unit	MW
2018	1	722		
2019	2	722		
2020	3	722		
2021	4	722	1	150
2021			2	150
2022	5	722		
2023	6	722		





Network Development Plan

Developments in Witbank


• Kusile Integration

- Kusile-Duvha 400kV line
- Kusile-Minerva 400kV line
- Kusile-Apollo 400kV line
- Kusile-Lulamisa 400kV line
- Kusile-Zeus 400kV line
- Kendal-Zeus 400kV line




Developments in Witbank and Middelburg

- **Khanyisa IPP**
 - Kusile-Vulcan 400kV LILO
- **Emkhiweni Integration**
 - Arnot-Vulcan 400kV LILO
 - Emkhiweni-Silimela 400kV line



Developments in Highveld South


- **Mulalo (Sol B) Integration**
- Kriel-Zeus 400kV LILO
- Kriel-Tutuka 400kV LILO



Developments in the Lowveld CLN

- **Marathon 400kV Integration**

- **Marathon 1st 500 MVA 400/132 kV transformer**
- **Marathon-Gumeni 400 kV line**



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a high-voltage electricity pylon. The middle frame shows a large industrial facility with several tall cooling towers and a body of water in the foreground. The bottom frame shows a close-up of a white wind turbine against a blue sky.


Gauteng Province

Presented by: Thamsanqa Ngcobo (Planning Engineer)

Gauteng Province Profile

Load


■ Peak load of 9 885 MW : 28th July 2016



Generation

■ Kelvin Power Station (in Johannesburg) and Rooiwal Power Station (in Tshwane) are some of the Independent Power Producers (IPPs) that lie within the defined Gauteng grid area. There is also potential Biomass IPPs in the region.


■ The primary sources of power are Cahora Bassa, Lethabo, Matla, Kendal, Duvha, Grootvlei and Matimba power stations.



Load Forecast



Gauteng Province Load Forecast



Natural load growth:

- residential developments
- commercial and light industrial load growth

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The top frame shows a low-angle shot of a white wind turbine against a clear blue sky. The bottom frame shows a sunset or sunrise over a landscape with hills, with the sun low on the horizon and a bright orange glow. The background of the slide is white with a blue curved line on the left side.



Major Developments

Major developments in Pretoria East




Hazeldean Node Development (East Capital): The Hazeldean Consortium master plan includes a mall, hospitals, educational facilities, residential, retail, hospitality and tourism components.


Developments in the Tshwane CLN



- Tshwane Reinforcement – Wildebees integration
- Tshwane Reinforcement – Diphororo Phase 1
- Tshwane Reinforcement – Diphororo Phase 2



Key Developments in Joburg North/West Rand



Orlando Precinct




Vilakazi Precinct




Developments in the JHB North CLN

2017 → 2027
1527 MW → 2294 MW




- Kusile-Lulamisa 400kV line
- Apollo-Lepini 2nd 275kV line
- New MTS Sesui 400/88kV
- New MTS Kyalami 400/88kV
- New MTS Donatello 400/88kV




Developments in the West Rand and Vaal CLN



2017 → 2027
3729 MW → 5709 MW



- Vaal Strengthening Phase 2
- Soweto Strengthening
- West rand Strengthening Phase 1



Key Developments in Joburg South/East Rand



Zendai Modderfontein (Mixed Development)

- 30 000 Housing units, commercial and light industry envisaged
- Potential 200 000 jobs

Linbro Park (Mixed Development)

- 20 000 Housing units, commercial and light industry envisaged
- Alexandra Township re-blocking

Developments in the JHB East and South CLN






Photo: The Media Club South Africa


- City Power integration
- Mesong integration
- Sebenza integration
- Jupiter B integration
- Sisimuka integration



Developments in the JHB East and South CLN



- City Power integration
- Mesong integration
- Sebenza integration
- Jupiter B integration
- Sisimuka integration
- Lesokwana Integration



Servitude Constraints – GP Urban Area



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a high-voltage electricity pylon. The middle frame shows a large industrial facility with several tall cooling towers and a body of water in the foreground. The bottom frame shows a close-up of a white wind turbine against a blue sky.

KwaZulu-Natal Province

Presented by: Thokozani Bengani (Planning Engineer)

KwaZulu-Natal Province

Generation


- Power supply into the province is mainly from Mpumalanga Province power pool
- Drakensberg Pumped Storage with 1000 MW installed capacity
- Ingula Pumped Storage with 1330 MW installed capacity
- Avon OCGT with 680 MW installed capacity

Geographical area

- Newcastle, Ladysmith, Drakensberg, Pietermaritzburg, Pinetown, Port Shepstone, Amanzimtoti, Durban, KwaDukuza, Empangeni, Richards Bay, St Lucia, Hluhluwe and Ermelo

Economic Activity

- Redistributors, Commercial, Mining, Industrial, Residential, Agricultural, Traction



Achievements



Avon, Mersey and Incandu 3rd Transformers


1 x 500 MVA & 2 x 250 MVA transformers were installed in KZN in 2016, adding a total of 1000 MVA of capacity to the system



Load Forecast



KwaZulu-Natal Load Forecast



* Compound Annual Growth Rate



Network Development Plan

Key Developments in Empangeni, Ulundi, Vryheid and Newcastle


- Drivers for load growth:

- Coal Mining and Ermelo-Richards Bay Coal line
- Industrial activities
- Public infrastructure delivery

- Planned Project:


- Madlanzini substation loop into Camden-Normandie 400 kV line
- Nzalo substation loop into Normandie-Umfolozi 400 kV line
- Duma Substation loop into Pegasus-Athene 400 kV line

These substations will reinforce the Ermelo-Richards Bay coal link




Key Developments in Northern KZN

Empangeni
CLN: 2027
2283 MW



- Growth Drivers :
 - iSimangaliso wetland park eco-tourism
 - Agriculture
 - Public infrastructure delivery
- Planned Project:
 - Northern KZN Strengthening: Phase 1: Normandie-Iphiva 400 kV line and integration of Iphiva Substation near Mkuze
 - Phase 2: Duma-Iphiva 400 kV line



KwaZulu-Natal 765 kV Strengthening




- Purpose:

- To create sufficient capacity to meet the growth in demand
- Also provide opportunities to switch off critical circuits for maintenance


- KZN 765 kV Strengthening Planned Projects:

- Empangeni Integration
- Pinetown Integration




Key Developments in Pinetown CLN

Pinetown CLN: **2027**
4300 MW



- Drivers for load growth:
 - eThekweni Metropolitan:
 - Shongweni development
 - Cornubia development
 - Dube tradeport development
 - Old airport dig-out
 - South Coast:
 - Commercial and tourism
 - Public infrastructure delivery
- Planned Project:
 - Venus- Ariadne 2nd 400 kV line
 - eThekweni Strengthening
 - Integration of Inyaninga SS
 - Integration of Shongweni SS
 - South Coast Strengthening:
 - Ariadne-Eros 400 kV line and integration of St Faiths SS



Free State Province

Presented by: Thokozani Bengani (Planning Engineer)



Free State Province Profile

Generation


- Power supply into the province is mainly from Mpumalanga Province power pool and Lethabo Power Station 3558 MW
- There is a potential for renewable energy generation
- Solar PV commissioned 124 MW

Geographical area

- Harrismith, Bloemfontein, Botshabelo, Welkom, Sasolburg, Kroonstad, Parys, Phuthaditjhaba and Bethlehem

Economic Activity


- Redistributors, Mining, Commercial, Industrial, Residential, Agriculture and Traction



Load Forecast



Free State Load Forecast




* Compound Annual Growth Rate



Network Development Plan

Key Developments in Eastern Free State


Welkom
CLN: 2027
1023 MW




- Drivers for load growth:
 - Strategic Integrated Projects 2 (Harrismith Logistics Hub)
 - Public infrastructure delivery
- Planned Project:
 - Harrismith Strengthening: Extension of Sorata Substation (Phase 1 and 2)

Key Developments in Sasolburg

Sasolburg
CLN: 2027
541 MW




- Drivers for load growth:
 - Mining activities
 - Industrial activities
 - Public infrastructure delivery
- Planned Project:
 - Integration of Igesi Substation



Key Developments in Mangaung and surrounding regions

Bloemfontein 2027
CLN: 748 MW




• Drivers growth:

- Public infrastructure delivery
- Solar power generation


• Planned Project: Bloemfontein Strengthening:

- Everest-Merapi 400 kV Line
- Harvard 400/132 kV Substation
- 2 x Beta-Harvard 400 kV Lines



Venus – Ariadne – Eros 400 kV Line Route



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a worker in a red bucket on a lift. The middle frame shows a wind farm with several turbines. The bottom frame shows a large industrial building with a curved roof and zebras in the foreground. The bottom-most frame shows high-voltage power lines.

Northern Cape Province


Planning Engineer: Jamila Kombe

Presented by: Ahmed Hansa

Northern Cape Province Profile


LOAD

❖ Peak load of 728 MW: Feb 2016



GENERATION

Type		Name	Output
Peaking	Hydro	Van Der Kloof	240 MW
		Gariep	360 MW
Eskom Total			600 MW
REIPPPP Projects		Wind	150 MW
		PV	950 MW
		CSP	200 MW
		Hydro	10 MW
REIPPPP Total			1310 MW




Load Forecast



Load Forecast

CAGR* = 3.68%



- Load Drivers**
- Natural load growth
 - Anticipated mining loads in Kimberley


	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
Namaqualand CLN @ Provincial Peak	103.4	105.2	107.2	109.9	137.3	139.5	141.4	147.9	148.8	149.7
Karoo CLN @ Provincial Peak	197.9	218.8	225.3	228.0	231.5	235.0	238.6	242.1	245.6	248.1
West Coast CLN @ Provincial Peak	13.72	13.80	13.89	13.98	14.07	14.16	14.24	14.33	14.42	14.51
Kimberley CLN @ Provincial Peak	774.7	777.5	791.9	941.5	891.1	937.2	999.0	1035.0	1065.0	1098.2
Northern Cape Province (Area Max)/Province	1089.7	1115.3	1138.3	1293.3	1273.9	1325.9	1393.3	1439.3	1473.7	1510.5
Northern Cape Province (MSD)	974.7	984.5	1005.8	1149.8	1131.7	1180.0	1242.6	1285.3	1317.3	1351.4

* Compound Annual Growth Rate

Generation Forecast



NC Renewable Generation



Achievements



Achievements

Aries - Nieuwehoop
400 kV line

Kronos 400/132 kV
transformation for load
which also facilitated:


- Prieska 75 MW PV
- Sonnidex 75 MW PV

Helios 400/132 kV
transformation for:

- Loeriesfontein
140 MW wind farm
- Khobab 140 MW
wind farm

Paulputs
transformation for load
which also facilitated :

- Kaxu 100 MW CSP
- Xina 100 MW CSP
- Konkoonies
9.7 MW PV
- Neusberg Hydro
Electric 10 MW







Network Development Plan

Developments in the West Coast CLN

2027
14.5 MW





- Further transformation at Helios for load



Developments in the Namaqualand CLN


2027
150 MW




- Juno-Gromis-Oranjemond 400 kV line
- Gromis-Nama-Aggeneis 400 kV line
- Aggeneis-Paulputs 2nd 220 kV line
- Aries FACTS Device

Developments in the Karoo CLN

2027
248 MW




- Hydra transformation
- Ruigtevallei transformer normalisation and transformation
- Gariep Strengthening




Developments in the Kimberley CLN

2027
1098 MW



- Uppington Substation and Uppington-Nieuwehoop 400 kV line
- Nieuwehoop-Ferrum 400kV line
- Ferrum-Mookodi 400 kV line via Hotazel



A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a close-up of solar panels. The middle frame shows a large industrial facility with several tall, white cooling towers and a body of water in the foreground. The bottom frame shows a helicopter performing a hoist rescue or maintenance over a power line tower. The frames are connected by a series of concentric, overlapping circles.


Western Cape Province

Presented by: Ahmed Hansa (Planning Engineer)

Western Cape Province Profile


Load

■ Peak load of 3850 MW: 26th July 2016



Generation

Type		Name	Output
Base Load	Nuclear	Koeberg	1860 MW
Peaking	Gas	Acacia	171 MW
		Ankerlig	1332 MW
		Gourikwa	740 MW
	Pumped Storage	Palmiet	400 MW
Eskom Renewables	Wind	Sere	105 MW
Eskom Total			4608 MW
REIPPPP	PV	IPPs	134 MW
	Wind	IPPs	316 MW
REIPPPP Total			450 MW
City of Cape Town Total			258 MW




Cape Corridor

- Comprises of 400 kV and 765 kV lines originating from **Zeus Substation** and **Alpha Substation** in Mpumalanga to **Hydra Substation** in the Northern Cape.

- It then *extends into the Western Cape Province.*

Cape Corridor 765 kV Progress

- Zeus-Mercury and Mercury-Perseus in December 2012
- Hydra-Perseus in July 2013
- Perseus-Gamma and Hydra-Gamma in February 2014
- Gamma-Kappa in April 2015
- Kappa-Sterrekus in December 2016**



Achievements




Kappa-Sterrekus 765 kV line





Load Forecast

Western Cape Load Forecast




* Compound Annual Growth Rate




Network Development Plan

Developments in the Peninsula CLN

2027
3300 MW



- Ankerlig-Sterrekus 1st and 2nd 400 kV lines
- Relocate Koeberg offsite supply to Ankerlig
- Koeberg -Acacia 2nd 400 kV line
- Erica Substation
- Erica-Philippi 400 kV line
- Pinotage Substation



Pinotage Substation – Under construction




Developments in the Outeniqua CLN

2027


990 MW

- Asteria Substation
- Agulhas Substation
- Kappa 400/132 kV transformation
- Komsberg 400/132 kV Substation
- Narina Substation
- Gourikwa-Narina-Droërvier 400 kV line
- PCB series cap phase out plan




Developments in the West Coast CLN


2027
570 MW



- Aurora transformation upgrade
- Bokkom Substation
- Juno transformation upgrade
- PCB series cap phase out plan



- Zeus-Perseus 765 kV line
- Perseus-Gamma 2nd 765 kV line
- Gamma-Kappa 2nd 765 kV line
- Kappa-Sterrekus 2nd 765 kV line




A decorative graphic on the left side of the slide consists of three overlapping circles. The top circle shows a close-up of solar panels. The middle circle shows a large industrial facility with several tall, white cooling towers and a body of water in the foreground. The bottom circle shows a helicopter performing maintenance on a high-voltage power line tower. The circles are outlined with multiple concentric lines.

Eastern Cape Province

Planning Engineer: Caswell Ndlhovu

Presented by: Ahmed Hansa

Eastern Cape Province Profile



General

- EC Population ~ 6.7 million
- 3rd most populous province
- ~ 8 % of total South African GDP
- 4th largest contributor to GDP
- Major Industries
 - Automotive, tourism, agriculture, agro-processing, ocean economies

Generation in Eastern Cape

- Port Rex 171 MW
- Dedisa OCGT 372 MW
- RE IPP (Wind & Solar) ~ 1060 MW

Load Served

- Peak Load demand (2016) 1472 MW
- Geographic Areas: Nelson Mandela Metro, Buffalo City Metro, Mthatha




BUFFALO CITY
METROPOLITAN MUNICIPALITY

Load Forecast



Eastern Cape Load Forecast



	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
East London Peak (MW)	687	708	718	731	750	768	779	787	817	836	851	867
Port Elizabeth Peak (MW)	879	972	985	1003	1029	1053	1069	1080	1120	1147	1167	1190
Eastern Cape @ TOSP (MW)	1300	1326	1358	1385	1400	1428	1470	1499	1529	1550	1581	1630
Eastern Cape Grid Peak (MW)	1472	1548	1569	1598	1639	1678	1703	1721	1785	1828	1860	1896

Drivers - East London

- Electrification
- Construction – Commercial Growth
- Agriculture, Forestry and Agro-Processing
- East London IDZ



Drivers – Port Elizabeth


- Coega IDZs – Petro/ Ferrochrome Smelter(s)
- Manufacturing, Auto Industry, Exports





Generation Forecast

Eastern Cape Generation Forecast



	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
Year Total	470	928	1445	1702	1874	2074	2074	3074	3074	3074	3806	3806	5406
PV	0	0	70	70	70	70	70	70	70	70	70	70	70
Nuclear	0	0	0	0	0	0	0	0	0	0	0	0	1600
Wind	470	556	1003	1260	1432	1632	1632	1632	1632	1632	1632	1632	1632
Gas	0	372	372	372	372	372	372	1372	1372	1372	2104	2104	2104

Renewables (MW)

EL	PE	Total
250	1452	1702

Gas generation
~ 2000 MW


Thyspunt Nuclear,
depends on
government approval
and IRP ~ 1600 MW



Achievements



Achievements 2014 - 2017



- Eros-Vuyani line, Vuyani substation and Vuyani – Neptune line
- Poseidon 500 MVA 400/132 kV transformer
- ~ 1060 MW RE in the province and DOE OCGT generation at Dedisa




Network Development Plan

Key projects in the East London area


2027
867 MW




- 400 kV at Pembroke substation:
 - Neptune-Pembroke 400 kV line
 - Poseidon-Pembroke 400 kV line
- 3rd 120 MVA transformer and 100 Mvar 400 kV capacitor bank at Delphi substation



Key projects in the Port Elizabeth area



- 3rd 500MVA transformers and 100 Mvar 400 kV capacitor banks at Dedisa and Grassridge
- Thyspunt nuclear and 1.7 GW gas-to-power generation integration
- Gamma-Grassridge 1st and 2nd 765 kV lines




A decorative graphic on the left side of the slide, consisting of four overlapping circular frames. The top frame shows a group of Eskom staff in blue uniforms and yellow safety vests. The middle frame shows a high-voltage electrical substation at night. The bottom frame shows a worker in a white protective suit and helmet. The bottom-most frame shows a tree in front of a substation.

Transmission Refurbishment Plan 2018 - 2027

Presented by: Atha Scott

- The South African Grid Code stipulates that the Transmission company is responsible for the renewal, optimisation, reconfiguration and decommissioning of existing assets to ensure sustainability of the network.
- The development of the Transmission refurbishment plan is premised on an asset management (AM) framework.
- The asset management approach involves asset condition assessment and asset risk assessment, to support the compilation of refurbishment plans.
- The AM approach seeks to sustain a reliable and quality of supply, by managing the delicate balance between; network performance, network risks and capital constraints.


Development of TDP 2018 - 2027 (Asset Refurbishment Framework)



- **Development Mandate:**
 - Capital Spares: Supply restoration
 - Production Equipment: Maintenance support
 - Customer Connections: Secure revenue base
 - N-1 Transformation projects for regulatory compliance
 - Statutory network requirements
 - Refurbishment of network: long term sustainability and reliability of the network, covering asset classes in the following disciplines:
 - Substations
 - Transmission lines
 - Telecommunications
 - Associated general infrastructure



Transmission substations' refurbishment requirements (Needs)

TRANSMISSION'S SUBSTATION PLANT CONDITION ASSESSMENT OVERVIEW




The 10 year asset renewal plan formulation process

TRANSMISSION'S SUBSTATION PLANT CONDITION ASSESSMENT OVERVIEW



Plan Semi-constrained to reflect bottle necks in the Capital Plan value chain

- Starting point: assets identified based on condition rolled up per bay.
- Rolled up into substation
- Phased using criticality, importance and impact
- Generated projects to cost and enter into plan



Project Prioritisation Matrix (Snapshot)

Update Constraint Score			Score																		Overall Health Index Score
NAME	STAGE	Score	Ø Type of Customer and value to Customer	Ø Network Stability	Ø Likelihood of Load loss (MW)	Ø Interruption/Restoration of supply	Ø Performance (i.e. without the additional components)	Ø Statutory	Ø Safety and Environmental Improvements	Ø Spares	Ø Type of failure	Ø Cost of maintenance	Ø Prior Refurbishment	Ø Future need	Ø Skill Level	Ø Age	Ø Asset	Health Index Score	Ø Ter		
ITEM_NAME	STAGE	Bus Score	4%	4%	15%	10%	10%	4%	4%	3%	5%	5%	2%	3%	15%	4%					
Kriel HV Yard Refurb	PCRA	7.24	9	9	8	7	9	4	9	5	0	4	8	6	6	9	9	5			
Spitskop 2 X 500 Mva 400/132Kv Transformer Upgrade(Era)	ERA	7.2	9	9	9	9	7	9	9	-	4	2	7	6	1	7	7	6			
BREAKERS 11KV REPLACEMENT	PCRA	7.12	9	9	7	5	7	9	9	5	5	7	9	6	6	9	9	9			
Apollo CS: Breakers 11kv Replacement	PCRA	7.12	9	9	7	5	7	9	9	5	5	7	9	6	6	9	9	9			
FORDSBURG SS REFURBISHMENT - ERA	ERA	6.96	8	8	5	6	6	8	9	9	8	1	8	6	6	9	7	7			
Drakensberg Refurbishment Phase 1: Generator Breakers	ERA	6.88	9	9	7	8	7	2	4	8	6	7	8	6	6	9	6	6			
Venus S/S Replacement Of 3X 275Kv Bushings	ERA	6.78	8	8	6	7	8	2	8	8	7	3	8	6	6	9	9	9			
Tabor S/S : Replacement Of 3X275 Kv Bushings	ERA	6.74	9	6	6	7	8	2	8	8	7	3	8	6	6	9	9	9			
Phased Replacement Of High Risk Transformers	ERA	6.74	9	6	6	8	9	2	8	3	5	3	8	6	6	9	9	9			
Phased Replacement of High Risk TRFRS PH 2	PCRA	6.74	9	6	6	8	9	2	8	3	5	3	8	6	6	9	9	9			
Athene S/S Replacement Of 7X400Kv Bushings	ERA	6.70	8	6	6	7	8	2	8	8	7	3	8	6	6	9	9	9			
Inubu S/S:Replacement Of 3X275Kv Bushing	ERA	6.70	8	6	6	7	8	2	8	8	7	3	8	6	6	9	9	9			
Prospect SS Refurbishment	ERA	6.68	3	6	9	4	9	8	9	3	4	8	5	7	1	3	7	8			
Impala S/S :Replacement Of 4X275Kv Bushing	ERA	6.66	7	6	6	7	8	2	8	8	7	3	8	6	6	9	9	9			
PROSPECT S/S RFB SCOPE DEF	DRA	6.64	7	6	9	4	9	8	9	3	4	4	5	7	1	3	7	8			
North West Protection Ref - Marang	ERA	6.63	9	4	8	5	6	5	4	9	7	5	9	7	1	7	9	4			
Makalu SS Refurbishment	PCRA	6.54	9	8	7	5	6	8	8	6	6	3	8	6	2	7	7	5			
Neptune 132kV Reactor 2 Circuit Breaker Replacement	ERA	6.54	7	8	7	6	6	5	9	0	7	6	6	7	5	7	7	7			
Ariadne S/S :Replacement Of 3X 400Kv Bushings	ERA	6.50	3	6	6	7	8	2	8	8	7	3	8	6	2	7	9	9			
Camden Komati Tower No253 Rpl Exe	DRA	6.45	8	8	4	7	8	8	8	8	7	9	9	9	5	9	3	4			
Drakensberg Refurbishment Phase 2: Feeder Bays	PCRA	6.38	9	9	5	9	7	2	8	8	7	6	8	8	5	7	6	6			
Alpha 11kV Reticulation	PCRA	6.38	6	8	7	5	7	4	9	5	5	7	9	4	5	5	7	7			
Replacement of Delle Breakers at Bloedriver	PCRA	6.37	6	6	5	7	9	4	4	7	4	5	9	8	5	7	7	9			
South Grid DC Ref 2013/14-Neptune	ERA	6.36	8	9	7	5	5	5	9	8	6	3	6	5	2	7	7	8			
PORT REX - BUFFALO NO 2 132KV LINE TOWER (ERA)	ERA	6.36	8	9	7	5	5	5	9	8	6	3	6	5	2	7	7	8			
Hydra Ruigtevallei No1 220kV LineReplacement of 3 wood	DRA	6.34	6	4	7	7	4	8	8	7	6	4	7	6	1	7	9	4			
Various Ss Underrated Terminal Equip Ref	DRA	6.33	7	8	8	4	8	6	4	5	5	1	9	6	1	7	7	8			
Jupiter-Underrated Terminal Equip Ref	ERA	6.33	7	8	8	4	8	6	4	5	5	1	9	6	1	7	7	8			
Prospect-Underrated Terminal Equip Ref	ERA	6.33	7	8	8	4	8	6	4	5	5	1	9	6	1	7	7	8			
Zues, Auxiliaries	ERA	6.28	6	8	7	6	7	4	4	5	5	1	9	6	1	7	7	8			
Acacia SS Refurbishment	ERA	6.28	7	8	6	6	7	5	8	6	7	6	8	6	5	7	7	7			
Eiger SS Refurbishment	ERA	6.28	5	9	7	4	8	8	8	4	5	4	9	6	5	7	7	8			
Replace Underrated Terminal Equip Ref	ERA	6.27	9	8	6	5	5	9	9	4	5	6	8	6	5	7	7	8			
Arnot 275KV Refurbishment	ERA	6.27	9	9	8	6	6	4	4	3	4	4	9	6	5	7	7	8			
Minerva SS Refurbishment	ERA	6.26	9	9	9	6	2	8	4	3	8	3	9	6	5	7	7	8			
Craighall 88kV Refurbishment	ERA	6.26	9	9	9	6	2	8	4	3	8	3	9	6	5	7	7	8			
Acacia SS Refurbishment	ERA	6.25	7	9	7	6	7	5	4	6	7	6	8	6	5	7	7	8			
Hendrina 132kV Feeder Upgrade Phase 2	PCRA	6.23	9	6	4	6	9	4	4	3	5	4	8	6	6	9	9	6			
Hendrina - 132kV Optimum 1&2 feeder bays upgrade	PCRA	6.23	9	6	4	6	9	4	4	3	5	4	8	6	6	9	9	6			

16 Weighted criteria

Critical projects previously never stood out and had not been started


Prioritisation defined to eliminate sensitivity to interpretation

16 Weighted criteria

Prioritisation defined to eliminate sensitivity to interpretation

Critical projects previously never stood out and had not been started

- The current 10 year Transmission refurbishment plan is a reflection of needs of the network, since it is based on asset condition assessments, asset criticality and network risks.
- The prioritisation process that was employed in developing the portfolio of projects for the 10 year refurbishment plan embodies the requirements and stipulations of the Grid Code.
- The plan supports two key strategic imperatives of Eskom Holdings:
 - *Ensure the reliability and availability of power capacity to support South Africa's economic growth ambitions.*
 - *Continue capturing efficiencies in operating and capital costs to achieve a sustainable tariff path for the economy.*




Questions?

A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a high-voltage electricity pylon. The middle frame shows a large industrial facility with several tall cooling towers and a body of water in the foreground. The bottom frame shows a close-up of a white wind turbine against a blue sky.

TDP 2018 – 2027 Summary and Capex Analysis

Presented by: Leslie Naidoo

Network Planning: The role of Transmission Planning




Summary of transmission infrastructure requirements over the TDP period

Corporate Plan aligned 2017 TDP Plan

Transmission Assets for National View	New Assets expected in	New Assets expected in	Total New Assets
	2018 - 2022	2023 - 2027	
Power lines (km)			
765 kV	98	350	448
400 kV	2408	3565	5973
275 kV	33	211	244
Total length (km)	2539	4126	6665
Transformers			
Number of units	44	51	95
Total capacity (MVA)	16390	25045	41435

Planned transmission lines


2016 vs 2017 TDP Cumulative Total Line km Requirements




	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
Actual Built Cumulated	600	1043	1674	2461	3272	3591	3937	4522										
2016 TDP Corporate Plan								4522	5327	6275	6671	6797	6908	7197	8026	8810	9403	
2017 TDP Corporate Plan								4522	5199	5790	6184	6681	7061	7860	8310	8755	10251	11187

Planned transformer capacity

2016 vs 2017 TDP Cumulative Transformer MVA Requirements



Major projects planned for in the TDP period



1. Capacity Expansion and Network Strengthening:



- Connection of new and anticipated *customer loads* and *generation*
- N-1 Reliability Investments
- Mitigation of Fault-level Exceedances (existing and anticipated)
- Securing of Servitudes and Environmental Authorisations
- Compliance (Regulatory, OHSAct, Environmental etc.)

2. Refurbishment (i.e. Extension of Life of Existing Assets):

- Refurbishment of aging equipment (CTs, VTs, Surge Arresters, H.V. Circuit Breakers and Power Transformers)
- Targeted Asset Performance Improvements (lines and substation equipment)
- Strategic and operational spares holding (to reduce SML<1 and MI risk)
- Compliance (Regulatory, OHSAct, NKP Act, Environmental etc.)

3. Asset Purchases:

- Specialised equipment for: live-line work; fault location systems, and online condition monitoring, etc.



Transmission 10-year Capex Plan: FY 2018 – 2027

Summary of Transmission Capex Plan (R Million): FY 2018 - FY 2027


	Total: (FY18-27)
Capital Expansion ⁽¹⁾	119,151
Capital Expansion for IPPs ⁽²⁾	18,357
Refurbishment	23,442
Capital Spares	2,914
Telecoms	3,938
Production Equipment	1,537
Land & Rights	5,157
	174,496


Notes:

- 1) Capital Expansion: reliability projects (N-1), network strengthening for load growth, integration of generation (Medupi, Kusile, Ingula, IPPs up to Bid Window 3.5)
- 2) Capital Expansion for IPPs - to integrate IPPs beyond Bid Window 3.5 (Renewables, gas, new coal)

Transmission 10-year Capex Plan: FY 2018 – 2027

Transmission Capex Plan: 2018 - 2027
(R Million)






The total Transmission Capital Plan amounts to R174 billion over the TDP period 2018 – 2027 of which:

- R119 billion is required for reliability (N-1) projects, integration of committed generation (Medupi, Kusile, Ingula, IPPs up to Bid Window 4) and connection of new load onto the system.
- R18 billion is required to integrate new IPPs (ie. RE, gas, coal) beyond Bid Window 4 of the DoE's IPP program.

- The liquidity position of Eskom may impact the execution of the Transmission Development Plan.
- The IPP programme may also trigger extensive network reinforcements.
- The time taken to acquire servitudes continues to be a challenge to the TDP roll out.

- The demand forecast in the TDP assumptions compares favourably with all the forecasts (IRP and Eskom) and is therefore prudent
- The generation forecast assumptions will be sufficient to allow the 2017 TDP to meet the requirements of the IRP (Draft), and where necessary, sensitivity studies will be done to meet extreme conditions or stress test various scenarios
- We are confident that projects currently in construction will be completed in time
- We will continue engaging with our stakeholders to enable network access in anticipation of the Country's future demand and generation needs
- Investments in the Transmission infrastructure is a crucial enabler for economic growth and development



Questions?

Thank you

