



Welcome!

Eskom Transmission Development Plan (TDP) 2020 - 2029 Public Forum



The Eskom Transmission Development Plan (TDP) 2020 - 2029

31 October 2019





Keynote address

By: Segomoco Scheppers Group Executive: Transmission





Setting-the-scene

By: Mbulelo Kibido General Manager: Grid Planning

Overview and purpose of the TDP Public Forum


The objective of the presentation is to:

Contextualise the planning timelines relating to the demand forecast and generation patterns

(≹)€skom

- Share assumptions and results from the Transmission Development Plan 2020 – 2029
- Share information and results relating to the integration of IPPs, as per the DoE IPP programmes and address future requirements as per the IRP
- Share information on the estimated Transmission Capital Investment Requirements for the period 2020 – 2029
- More importantly, to solicit comments and inputs to improve on the Transmission Plans

A Simplified Transmission Network Infrastructure Investment Planning Model



Eskom

Basis of the TDP 2020 - 2029



The TDP 2020 - 2029 was formulated to address the following:



Attain Grid Code compliance by resolving both substation and line violations



Determine new network infrastructure requirements to sustain and allow for future demand growth




Determine new network infrastructure requirements to integrate new generation (Eskom and IPPs)




Recent Transmission Network Expansion Successes

To date, a large amount of construction work has been completed, adding ~10.7 GW of generation, ~7 850 km of transmission lines, and ~37.4 GVA substations...








Eskom

Transmission Substations (MVA)





DOE IPP Programme Overview – 31 July 2019



Peakers	REIPP	REIPP	REIPP	REIPP	REIPP	Small	Coal
	BW1	BW2	BW3&3.5	BW4	BW4B	1-5	Baseload
2 projects	28 projects	19 projects	23 projects	13 projects	13 projects	20 projects	2 projects
1200 MW	1436 MW	1054 MW	1656 MW	1121 MW	1084 MW	MW TBD	864 MW
All projects connected	All projects connected	All projects connected.	20 projects connected, 3 projects in execution phase	Projects in Execution Phase		Projects in Budget Quotation phase	Projects in Budget Quotation phase


8415 MW from 120 individual projects (The capacity for individual Smalls REIPP project TBD)

69 projects totalling 5241 MW have been commissioned, of which 4041 MW is from RE Sources

- Eskom has committed Capital Costs to enable the integration of successful bidders (Bid Window 1 4B, including Small REIPPs) into the National Grid.
- Grid connection capacity for future REIPP exhausted in some parts of the national grid, particularly in the Northern Cape Province.


Summary of major transmission corridor expansion projects completed recently

Eskom



Summary of transmission transformation projects completed recently

Eskom



The Different Plans



Integrated Resource Plan (IRP)

- The Department of Mineral Resources and Energy is accountable for the Country's Electricity Plan, which is the Integrated Resource Plan (IRP)
- The Integrated Resource Plan (IRP) is intended to drive all new generation capacity development
- NERSA licences new generators according to this determination

Strategic Grid Plan (SGP)

- The Strategic Grid Plan formulates long term strategic transmission corridor requirements
- The Plan is based on a range of generation scenarios, and associated strategic network analysis
- 20-year planning horizon, updated every 2 3 years

Transmission Development Plan (TDP)

- The Transmission Development Plan (TDP) represents the transmission network infrastructure investment requirements
- 10-year planning horizon, updated annually
- Indicates financial commitments required in the short to medium term




Planning for the South African Integrated Power System

The TDP 2020 - 2029 Generation Assumptions

Presented by: Ronald Marais Senior Manager: Strategic Grid Planning


Linkages Between the Various Plans



(Eskom

TDP Timelines

Eskom





Planning for the Integration of Independent Power Producers (IPPs)

DOE IPP Programme Overview – 31 July 2019



Peakers	REIPP	REIPP	REIPP	REIPP	REIPP	Small	Coal
	BW1	BW2	BW3&3.5	BW4	BW4B	1-5	Baseload
2 projects	28 projects	19 projects	23 projects	13 projects	13 projects	20 projects	2 projects
1200 MW	1436 MW	1054 MW	1656 MW	1121 MW	1084 MW	MW TBD	864 MW
All projects connected	All projects connected	All projects connected.	20 projects connected, 3 projects in execution phase	Projects in Execution Phase		Projects in Budget Quotation phase	Projects in Budget Quotation phase


8415 MW from 120 individual projects (The capacity for individual Smalls REIPP project TBD)

69 projects totalling 5241 MW have been commissioned, of which 4041 MW is from RE Sources


- Eskom has committed Capital Costs to enable the integration of successful bidders (Bid Window 1 4B, including Small REIPPs) into the National Grid.
- Grid connection capacity for future REIPP exhausted in some parts of the national grid, particularly in the Northern Cape Province.


Approved IPPs






Existing Transmission infrastructure - Overview of the constrained network






Transformer capacity enhancement for IPP Integration - TDP 2020 - 2029





Transmission integration plans for IPPs






Tx Strategy to increase Grid Access to meet future needs of the IRP and customers

() Eskom

Change in generation diversity has major impact on future Tx Grid

- Grid Access Increased connection capacity needed in new areas (delivery time > 8yr)
- On Time Connection Smaller IPP generation plant can be constructed faster (delivery time <5yr)
- Unknown locations Multiple unspecified IPP sites require market access for best price




1. Strategic Investment in the EIAs & Land acquisition is critical to meet future IRP connection timeframes


2. Reducing Tx investment today compounds future Tx Grid roll out leading to high risk of Gx capacity delays



SEA Corridors for SIP 10 project



Grid Insights - Flow implications (2019)





(Eskom

Grid Insights – Future generation and load

Eskom

Future Generation & Load Allocation





Demand

Gen Pattern Changing


- North to South Migration
- High Capacity required in the network that is traditionally weak

Dominant Load Areas

- No significant shift in dominant load areas
- Slight growth predicted


TDP Generation Assumptions – Based on IRP 2018





TDP Generation Assumptions – Spatial location


Eskom



Expansion drivers and network depletion



Change in Generation Spatial Footprint




Different generation scenarios indicate that the generation in the southern parts of the country will increase significantly

Irrespective of generation scenario

TDP Generation Base Scenario




2019 TDP Generation Plan (Base)



Current TDP 2020 - 2029


(Eskom

Assumptions based on 2018 IRP



Flow implications (2029)





2029 Midday

- The South Network will need to export 9GW Northwards
- The corridor connecting North and South is 4.5GW in Capacity
- The corridor was built over approx. 30years, it will need to be doubled in ten years under capital deferment conditions

2029 Peak Period

- There is a slight North South flow in 2029 under peak load conditions
- This is due to PV being out and higher load absorbing local generation
- There will be a need to manage voltage as the network will be very lightly loaded



Questions?



The TDP 2020 - 2029 Demand Forecast

Presented by: Jana Breedt Chief Advisor: Demand Forecasting




The purpose of the Transmission demand forecast is to provide an overview of the national grid electricity demand in South Africa that serves as input to the Eskom Transmission Development Plan

The presentation outlines the base of the Eskom demand forecast methodology, components used to model the demand forecast and the national forecast scenarios

Eskom Transmission demand forecast methodology

() Eskom




Eskom Transmission demand forecast methodology

() Eskom




Transmission forecast process & components

Eskom




Implementation of Forecast

- Input to TDP Planning
- Accuracy Tracking



Transmission national demand forecast 2020 – 2029







Transmission Low 2019

--- Actual Peak Demand


Change in Transmission demand forecast from 2018




Customer applications and market intelligence comparison



Integrated Resource Plan (IRP) demand forecast validation



Key growth areas for TDP period 2020-2029



Collaboration between role players

Eskom

Energy Department: Energy REPUBLIC OF SOUTH AFRICA

SEZs IN SOUTH AFRICA

GASTENG

fact ...o

Metros

Investors

Decision makers

Collaboration allows us to know more than we are capable of knowing by ourselves ~ Paul Solarz

Combined Forecasting Forum

MUTH-POLAN

our future throu




Customers Technology Experts Developers



Questions?



Provincial Development Plans 2020 – 2029









Limpopo Province TDP 2020 - 2029

Presented by: Caroleen Naidoo Chief Engineer

Limpopo Province Profile



Limpopo Province Load Forecast (2020 – 2029)



(Eskom

* Compound Annual Growth Rate


Completed projects and existing network

Eskom

Medupi-Ngwedi 400 kV line 1 part of the Medupi Integration was commissioned in September 2019









Developments in the Phalaborwa CLN

- Manogeng Switching Station and Silimela Substation
- Sekhukhune Substation
- 400 kV at Foskor
 Substation
- Merensky-Foskor-Spencer
 400 kV line
- Leseding 3rd 500 MVA
 Transformer
- Acornhoek 3rd 125 MVA
 Transformer






Developments in the Lephalale CLN


- Medupi Integration: Medupi-Ngwedi 400 kV line 2
- Waterberg Generation
 Integration: Medupi Witkop and Borutho Silimela 400 kV line
- Borutho 3rd 500 MVA
 Transformer
- Warmbad 1st 250 MVA
 Transformer






Developments in the Polokwane CLN


- Nzhelele 400/132 kV
 Substation
- 400 kV at Spencer
 Substation
- 2 x 36 Mvar
 Capacitor Banks at
 Tabor and Spencer
 Substations







Questions?






Mpumalanga Province TDP 2020 - 2029

Presented by: Kabir Singh Chief Engineer

Mpumalanga province profile



Load of ~ 4.3 GW



Completed projects for grid reliability



- For executability of:
 - The fault level mitigation-FCLR's
 - Refurbishment and upgrade of terminal equipment
- To be redeployed to the new Wonderkrag S/S

Normandie 2nd 400/132 kV 250 MVA transformer



- N-1 requirement
- Improved reliability of supply to Swaziland

Completed projects of the Kusile transmission integration




- Kusile 400 kV Yard
- Kendal-Apollo loop-in to Kusile
- Kusile-Zeus 400 kV line
- 2nd Kendal-Zeus 400 kV line

- Loop the Kendal-Duvha line to form Kendal-Arnot
- Loop the Duvha-Kendal line to form Duvha-Vulcan 2
- Duvha-Minerva loop-in to Kusile
- Sol-Camden 400 kV line 1 & 2 (Zeus bypass)




Mpumalanga generation forecast 2020 - 2029



(Eskom

Generation Developments in Mpumalanga



Mpumalanga Load Forecast 2020 - 2029





* Compound Annual Growth Rate

Strengthening developments in Mpumalanga

Eskom

Wonderkrag integration

- N-1 compliance
- Safety compliance
- Creating spare capacity
- Fault level mitigation


Emkhiweni integration


- N-1 Compliance
- Safety related to burning grounds
- Creating spare capacity

Marathon 400 kV integration

- N-1 compliance
- Creating spare capacity
- Increased cross-border transfer capability









Questions?






Gauteng Province TDP 2020 - 2029

Presented by: Thamsanqa Ngcoba Chief Technologist

Gauteng Province Profile






□ Grid peak demand: ~11000 MW

Generation

Type / Owner	Name
City Power	Kelvin
City of Tshwane	Rooiwal and PTA West



Gauteng projects in execution

Eskom

Benburg Ext. 3rd 250 MVA 275/132 kV Transformer

 Supports network reliability in the East Rand



Gauteng projects in execution

Eskom

Sisimuka 88 kV Busbar

- 1st Phase of converting Simmerpan to a 275/88 kV Substation
- Supplies growth in the Germiston area



Gauteng Projects in execution

Eskom

Lepini Ext. 275 kV 2 x 150 MVar Capacitors

Supports the Minerva-Lepini-Craighall 275 kV ring, which supplies the northern suburbs



Gauteng Load Forecast



*Compound Annual Growth Rate


Developments in the JHB East and South Area

Pictor The Media Club South Arri


Eskom

Key Projects:

- Mesong Substation
- Jupiter B integration
- Sisimuka Substation
- Lesokwana Substation




Developments in the Tshwane Area




Developments in the JHB North Area



- Kusile-Lulamisa 400 kV line
- Apollo-Lepini 2nd 275 kV line
- New MTS Sesui 400/88 kV
- New MTS Kyalami 400/88 kV
- New MTS Donatello 400/88 kV



Developments in the West Rand and Vaal Area





Questions?






KwaZulu-Natal Province TDP 2020 - 2029

Presented by: Thokozani Bengani Chief Engineer


KwaZulu-Natal Province Profile



(Eskom

KwaZulu-Natal Load Forecast






Growth drivers in the province: Commercial, Light industrial, Residential, Tourism and Universal access to electricity


KwaZulu-Natal 765 kV Strengthening



- Benefit
 - Will create additional capacity to meet the growth in demand in uMhlathuze, RBIDZ, KwaDukuza and Dube Tradeport
 - Will provide network
 redundancy
 - Ability to switch off critical circuits for maintenance
- Planned Projects:
 - Empangeni Integration
 - Pinetown Integration



400 kV Backbone Strengthening



Ermelo-Richards Bay freight rail upgrade

() Eskom

- Drivers for load growth:
 - Mining and Exports
- Planned Projects:
 - Madlanzini Substation loop into Camden-Normandie 400 kV line
 - Nzalo Substation loop into Normandie-Umfolozi 400 kV line
 - Duma Substation loop into Pegasus-Athene 400 kV line



Jozini and Umhlabuyalingana Municipalities

() Eskom

- Drivers for growth:
 - iSimangaliso wetland park ecotourism
 - Agriculture
 - Universal access
 to electricity
- Planned Project:
 - Northern KZN Strengthening: Phase 1: Normandie-Iphiva 400 kV line and integration of Iphiva Substation near Mkuze



Dube Tradeport – Durban Aerotropolis

• Drivers for load growth:

- Dube Tradeport development
- eThekwini Metropolitan
- KwaDukuza Municipality

Planned Project:

 Integration of Inyaninga Substation

• Benefits:

- Will cater for the demand growth around the Dube Tradeport
- Will free up capacity on the existing transmission network supplying eTE and iLembe DM








eThekwini Western Region

() Eskom





- Drivers for load growth:
 - Durban-Gauteng Logistics
 Corridor
 - Mixed use developments

Planned Project:


Integration of Shongweni
 Substation

• Benefits:

- Will cater for the demand growth in the western region
- Will free up capacity on the existing transmission network supplying eTE and the south coast



Questions?





Free State Province TDP 2020 - 2029

Presented by: Thokozani Bengani Chief Engineer

Free State Province Profile

IPPs

199 MW


3761 MW

PV

Total Installed Generation




Load




Free State Load Forecast





Growth drivers in the province: Commercial, Light industrial, Logistics & Universal access to electricity

Everest-Merapi 400 kV line, operated at 275 kV




Key Developments in Mangaung and Surrounding Regions



- Drivers for load growth:
 - Solar power generation
 - Universal access to electricity
- Planned Project:
 - Bloemfontein
 Strengthening Phase 2
 - Harvard 400/132 kV
 Substation
 - 2 x Beta-Harvard 400 kV lines





Key Developments in Eastern Free State

() Eskom

- Drivers for load growth:
 - Harrismith
 Logistics Hub
 - Universal access
 to electricity
- Planned Project:
 - Harrismith Strengthening: Extension of Sorata Substation (Phase 1 and 2)



Key Developments in Sasolburg


() Eskom

- Drivers for load growth:
 - Mining
 - Industrial activities
 - Universal access to electricity
- Planned Project:
 - Integration of Igesi
 Substation





Questions?






North-West Province TDP 2020 - 2029

Presented by: Queen Melato Chief Engineer

North-West Province Profile



North-West Province Load Forecast



(Eskom

* Compound Annual Growth Rate

Renewable Energy in North-West Province

() Eskom

Renewable Energy Projections:

- Approximately 0.75 GW (10 year horizon)
- Mookodi Substation 375 MW
 - Approved 75 MW Waterloo Solar Park
- Watershed Substation 375 MW
 - Approved 75 MW Zeerust Solar Park



Completed Projects


Eskom

MEDUPI Mookodi Substation Integration SPITSKC Dinaledi 3rd **monkase** DINALE NGWEDI transformer Zeerust **ARARA** Pretoria TRIDEN Mahikeng MAR Ngwedi Substation APOLLO Lichtenburg PLUTO Johannesbui integration WATERSHED Potchefstroom Vereeniging HERMES Medupi-Ngwedi Vryburg 400 kV line 1 MERCURY MOOKODI Kuruman Welkom **O** THESEUS **O**PERSEUS

Developments in the Rustenburg CLN

() Eskom


- Medupi-Ngwedi 400
 kV line 2 (765 kV
 design)
- Bighorn Extension
- Rustenburg Reactive Compensation (Bighorn, Marang and Dinaledi)



Developments in the Carletonville CLN

() Eskom

- Watershed
 Strengthening
- Pluto-Mahikeng
 400 kV line
- Mahikeng Substation
- Mookodi-Mahikeng 400 kV line





Questions?






Eastern Cape Province TDP 2020 - 2029

Presented by: Queen Melato Chief Engineer

Eastern Cape Province Profile







Eastern Cape Load Forecast 2020 - 2029









* Compound Annual Growth Rate

Eastern Cape Generation Forecast



Developments and completed projects (2016 – 2018)






Key projects in the East London area





Key Projects in the Port Elizabeth CLN





Questions?






Northern Cape Province TDP 2020 - 2029

Presented by: Ahmed Hansa Chief Engineer

Northern Cape Province Profile


() Eskom



Completed Projects



- Gromis-Oranjemond 2nd
 220 kV line (built at 400 kV)
- Paulputs 2nd transformer 250 MVA 220/132 kV



Northern Cape Province Load Forecast





* Compound Annual Growth Rate


Northern Cape Province Renewable Energy Generation Forecast



(Eskom




Transmission Development Plan



Developments in the Namaqualand CLN


() Eskom

- Juno-Gromis 400 kV line and Gromis 500 MVA 400/220 kV transformer
- Nama 20 MVA 66/22 kV transformer
- Aries SVC device
- Helios 20 MVA
 132/66 kV
 transformer
- Gromis-Nama-Aggeneis 400 kV line
- Aggeneis-Paulputs 2nd 220 kV line (built at 400 kV)



Developments in the Kimberley CLN






Developments in the Karoo CLN

() Eskom

- Ruigtevallei
 10 MVA 132/22 kV
 transformer
- Derate Hydra-Ruigtevallei 220 kV line to 132 kV
- Hydra-Roodekuil
 132 kV line
 strengthening





Questions?






Western Cape Province TDP 2020 - 2029


Presented by: Ahmed Hansa Chief Engineer

Western Cape Province Profile





Existing generating facilities in the Western Cape










Eskom

*excludes small scale embedded generation (SSEG)



Load Forecast

Western Cape Load Forecast




(Eskom

* Compound Annual Growth Rate

Developments in the Peninsula CLN



- Ankerlig-Sterrekus
 1st and 2nd 400 kV
 lines
- Relocate Koeberg offsite supply to Ankerlig
- Koeberg-Acacia 2nd
 400 kV line
- Erica Substation
- Pinotage Substation



Pinotage Substation – under construction Photo Credits – Grant Duncan Smith (http://www.subiaco.co.za)






Developments in the Outeniqua CLN

Eskom

- Asteria Substation
- Agulhas Substation
- Kappa 400/132 kV transformation
- Komsberg 400/132 kV Substation
- Narina Substation
- Gourikwa-Narina-Droërivier 400 kV line – Strategic EIA




Komsberg Substation – under construction





Developments in the West Coast CLN

Eskom





Questions?



Eskom Transmission Refurbishment Plan 2020 - 2029

By: Atha Scott Senior Manager: Asset Investment Planning




The purpose of this presentation is to provide an overview of Transmission asset replacement planning and sustainability requirement to ensure the renewal and optimisation of our existing assets as well as the stability of the network.

Contents

- Asset Management Framework
- Transmission Network Refurbishment Plan (TNRP) Development
- Transmission System Sustainability
- Asset Condition Assessment
- Grid Refurbishment Plans
- Conclusion


Transmission Asset Management Framework



Eskom

Transmission Refurbishment Plan

Eskom



Network Sustainability Framework

Eskom

To maintain continuity of supply, compliance to Statutory Network requirements and support of a sustainable Transmission network

Maintenance supported by Sufficient Production Equipment

System Operator Guidelines and Emergency Preparedness Plans

Capital Spares to ensure fast Supply restoration

N-1 Transformation projects for regulatory compliance and alternative corridors

Refurbishment of network for long term sustainability and reliability of the network

Key Focus Areas in Sustainability

- 1. Sustain existing good performing areas
 - Maintenance Plan Execution
 - Enhanced Human Performance
- 2. Refurbishment replacement of high risk plant
- 3. Improve
 - Line and Equipment Performance
 - Plant Availability
 - ✓ Restoration response

4. Manage operational risks effectively

 Outage scheduling, planning, management of obsolete equipment and execution risk management


(₴)Eskom

5. Effective inspections, condition assessment & defect risk analysis and defects management

Ageing assets and potential declining plant health may impact future system performance. An active replacement strategy is utilised to manage performance and to avoid an extensive end of life asset replacement and plant failures.

Asset Condition Assessment – Main asset classes






Asset Condition Assessment

National View

Asset Condition Assessment and Plan


Eskom

Plant Age & Condition Profile



Planned for Replacement





Replacement Strategies for high impact and value assets







- The Transformer asset strategy is a combination of:
 - replacement of high risk units,
 - synergies with substation refurbishments
 - risk mitigation covered by sufficient levels of strategic spares and effective contingency plans in place for un-firm stations.
 - Technology improvements
- Replacement of high risk circuit breakers that have become unreliable and/or exhibit poor performance are expedited via equipment specific projects.
- Protection asset replacement criteria is based on equipment failure rate, performance, functional importance and age.
- Incorporate identified assets into substation refurbishment projects
- Life extension interventions and maintenance programs are to be implemented on the balance of assets not catered for on the current refurbishment plan to mitigate the risk of failure.
- The spares holding levels are aligned with prevailing network failure rates and capital constraints impacting on the implementation of the refurbishment plan.

Overhead Lines Refurbishment Strategy


Eskom

Lines Asset Strategy (installed asset base of 32 721km) entails:

- Transmission Overhead Lines are heavily influenced by the environment that they operate in and their performance and condition is susceptible to the elements. Although they are mechanical structures, they are not affected by wear and tear as much as the substation equipment and thus have a much higher longevity than that of substation equipment.
- A rigorous maintenance program is followed. From detailed inspections, periodic maintenance addresses the identified defects, to restore the line to the initial design specification.
- Design parameters have changed to cater for climate and technology changes. Past design and construction practices have resulted in limitations and these are rectified through a refurbishment program. Refurbishment program includes:
 - Replacement of insulators
 - Corroded steel lattice members
 - Bare guy-anchor links
 - Conductor and hardware.




Plant Age & Condition Profile



Capital Allocation within the Refurbishment Plan

Eskom



Grid Refurbishment Plans








Western Cape Province

2020 - 2029 TNRP

Presented by Jimmy Khoza


Western Cape Province: Asset Replacement Profile



150


(Eskom

Major Substation Refurbishment per MTS



Eskom

Eskom



Asset Classes planned for Replacement



Number of Assets Planned for Replacement					
Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total	
CAPACITOR	0	4	0	4	
CIRCUIT BREAKER	25	65	3	93	
CURRENT TRANSFORMER	77	230	4	311	
ISOLATORS	95	223	10	328	
PROTECTION	34	89	12	135	
REACTOR	1	4	0	5	
SURGE ARRESTER	84	111	12	207	
TRANSFORMER	9	2	3	14	
VOLTAGE TRANSFORMER	31	54	5	90	






Northern Cape Province

2020 - 2029 TNRP


Northern Cape Province: Asset Replacement Profile @Eskom



155


Major Substation Refurbishment per MTS





156





Asset Classes planned for Replacement



Number of Assets Planned for Replacement								
Asset CategoryMYPD 4FY23-FY25> 6 YRSTotal								
CAPACITOR	0	4	0	4				
CIRCUIT BREAKER	25	65	3	93				
CURRENT TRANSFORMER	77	230	4	311				
ISOLATORS	95	223	10	328				
PROTECTION	34	89	12	135				
REACTOR	1	4	0	5				
SURGE ARRESTER	84	111	12	207				
TRANSFORMER	9	2	3	14				
VOLTAGE TRANSFORMER	31	54	5	90				



Eastern Cape Province South Grid

2020 - 2029 TNRP

Eastern Cape Province: Asset Replacement Profile

0

10

20

30

40

50

60


Planned Plant Replacement REACTOR 1 ISOLATORS 84 112 CAPACITOR З з PROTECTION 9 63 47 TRANSFORMER 5 19 CIRCUIT BREAKER SURGE ARRESTER 133 CURRENT TRANSFORMER 152 50 VOLTAGE TRANSFORMER 53 17 0% 20% Poor (31-50%) % 40% ■ Very Poor (0-30%) 60% 80% 100% Fair (51-70%) **Selected Assets Replaced** (FY2010 - FY2019) TRANSFORMER REACTOR 7 ISOLATORS 14 PROTECTION VOLTAGE TRANSFORMER 16 CIRCUIT BREAKER 18 SURGE ARRESTER CURRENT TRANSFORMER 51

160


(Eskom

Major Substation Refurbishment per MTS









Asset Classes Planned for Replacement



Number of Assets Planned for Replacement								
Asset CategoryMYPD 4FY23-FY25> 6 YRSTotal								
CAPACITOR	0	4	0	4				
CIRCUIT BREAKER	25	65	3	93				
CURRENT TRANSFORMER	77	230	4	311				
ISOLATORS	95	223	10	328				
PROTECTION	34	89	12	135				
REACTOR	1	4	0	5				
SURGE ARRESTER	84	111	12	207				
TRANSFORMER	9	2	3	14				
VOLTAGE TRANSFORMER	31	54	5	90				






Gauteng Province

2020 – 2029 TNRP

Presented by Mini Palamootil

Gauteng Province: Asset Replacement Profile


Eskom



165


Major Substation Refurbishment MTS East Rand CLN






Major Substation Refurbishment per MTS JHB CLN






Major Substation Refurbishment per MTS Vaal CLN & West Rand CLN









Assets Planned for Replacement per category



Number of Assets Planned for Replacement					
Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total	
CAPACITOR	5	0	8	13	
CIRCUIT BREAKER	34	12	130	176	
CURRENT TRANSFORMER	152	36	582	770	
GIS	0	0	132	132	
ISOLATORS	120	32	490	642	
PROTECTION	52	11	178	241	
REACTOR	0	0	3	3	
SURGE ARRESTER	57	36	437	530	
TRANSFORMER	0	0	5	5	
VOLTAGE TRANSFORMER	77	18	225	320	






North West Province

2020 – 2029 TNRP


North West Province: Asset Replacement Profile

() Eskom



172

NW: Major Substation Refurbishment Projects



Eskom

Install Anti Climb Install Anti Climb Install Anti Climb Devices: Ararat -Devices: Bighorn -Devices: Apollo -Dinaledi 400kV Line Dinaledi 400kV Line Spitskop 1 275kV Line **Install Anti Climb Devices:** Mogwase **Bighorn - Spitskop 400kV** Line Nawedi Ararat lentMarang Brits Bighorn ★ **Install Anti Climb Devices:** Ararat - Trident 1 275 kV Kwagg Nia Line LulamisaE Westgat 0 Paunu Eiger Etna Brenne **Install Anti Climb** Carme Hera 6 Bernina **Devices: Bighorn -**Snowdou Kookfontein Glockher **Trident 275kV Line** OlympusRic Potchef troom Scafelt sdorp Highveld S Vryburg Mookodi Hera-Watershed 275 kV **Line Clearance Violation** Northern Cape Pluto - Thuso 400kV Fre Line Ground clearance violations Leander Everest This map has been compiled (Eskom by ESKOM Grid Planning **Existing Substations Existing Lines** • department to the best of their North West knowledge. However, since Created by: Sonja Ferreira * Towns various data sources have Date: 2019/05/28 88,32,24 20 53 16 been used Grid Planning department cannot accept responsibility for any inaccuracies.

25

50

100

150


200

Eskom



Number of	Assets Planne	d for Rei	olacement

Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total
CAPACITOR	7	0	0	7
CIRCUIT BREAKER	6	10	12	28
CURRENT TRANSFORMER	18	35	36	89
ISOLATORS	15	31	47	93
PROTECTION	6	10	18	34
SURGE ARRESTER	0	36	38	74
VOLTAGE TRANSFORMER	3	12	13	28






Limpopo Province

2020 - 2029 TNRP

Limpopo Province: Asset Replacement Profile


Eskom




177

Major Refurbishment per MTS





2019/11/01



Eskom



Number of	Assets Planned fo	r Replacement

Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total
CAPACITOR	3	2	0	5
CIRCUIT BREAKER	3	14	34	51
CURRENT TRANSFORMER	9	33	141	183
ISOLATORS	8	57	121	186
PROTECTION	3	9	23	35
SURGE ARRESTER	0	65	105	170
VOLTAGE TRANSFORMER	0	27	62	89







KwaZulu- Natal Province

2020 - 2029 TNRP

Presented by Jorge Correia

KwaZulu-Natal Province: Asset Replacement Profile






182


(Eskom

Major Substation Refurbishment per MTS



Eskom







Number of Assets Planned for Replacement					
Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total	
CAPACITOR	0	0	1	1	
CIRCUIT BREAKER	10	15	43	68	
CONTROL	0	3	4	7	
CURRENT TRANSFORMER	96	87	114	297	
DC & STANDBY	0	18	51	69	
GIS	0	6	0	6	
ISOLATORS	55	84	165	304	
METERING	0	4	4	8	
PROTECTION	8	37	91	136	
QUALITY OF SUPPLY	0	1	2	3	
REACTOR	1	3	0	4	
SURGE ARRESTER	90	60	225	375	
TELECOMMUNICATIONS	8	24	31	63	
TRANSFORMER	7	11	12	30	
VOLTAGE TRANSFORMER	12	39	47	98	







Free State Province

2020 – 2029 TNRP

Free State Province: Asset Replacement Profile








187


Major Substation Refurbishment per MTS





Major Line Refurbishment

Eskom



Asset Classes to be replaced



Number of Assets Planned for Replacement					
Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total	
CAPACITOR	0	0	2	2	
CIRCUIT BREAKER	2	11	31	44	
CURRENT TRANSFORMER	165	48	86	299	
DC & STANDBY	0	8	0	8	
ISOLATORS	9	89	128	226	
METERING	0	0	8	8	
PROTECTION	5	42	53	100	
REACTOR	0	0	1	1	
SURGE ARRESTER	15	66	137	218	
TELECOMMUNICATIONS	4	11	14	29	
TRANSFORMER	2	0	2	4	
VOLTAGE TRANSFORMER	6	76	25	107	






Mpumalanga Province

2020 – 2029 TNRP

Presented by Calvin Govindasamy


Mpumalanga Province: Asset Replacement Profile




Planned Plant Replacement

(Eskom

Selected Assets Replaced (FY2010 - FY2019)




MP: Major Substation Refurbishment Projects



Eskom

MP: Major Line Refurbishment Projects



Eskom

Mpumalanga: Number of Assets Planned for Replacement per category



Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total
CAPACITOR	0	0	2	2
CIRCUIT BREAKER	59	26	81	166
CURRENT TRANSFORMER	236	90	425	751
ISOLATORS	202	111	345	658
PROTECTION	66	39	128	233
SURGE ARRESTER	140	137	297	574
TELECOMMUNICATIONS	33	0	3	36
TRANSFORMER	2	2	2	6
VOLTAGE TRANSFORMER	93	51	158	302





Apollo HVDC Converter Station


2020 - 2029 TNRP

Apollo HVDC: Assets Planned for Replacement

Kwagga ISOLATORS Pretoria AndersonLomond CAPACITOR Njala PROTECTION nuso TRANSFORMER Minerva Apollo Lulamisa **CIRCUIT BREAKER** SURGE ARRESTER Esseien Lepino 0% Craighall Benburg Croydon stgate Princess Johannesburg Jupiter unus Brenner Eiger CIRCUIT BREAKER Piete Etna TRANSFORMER REACTOR Snowdon 0


Planned Plant Replacement by Tx

Eskom



Gauteng Province (Apollo HVDC)





Apollo HVDC: Assets Planned for Replacement



Number of Assets Planned for Replacement					
Asset Category	MYPD 4	FY23-FY25	> 6 YRS	Total	
CAPACITOR	2	2	0	4	
CIRCUIT BREAKER	44	0	0	44	
CURRENT TRANSFORMER	0	0	0	0	
DC & STANDBY	4	0	0	4	
HIGH VOLTAGE DC	2	0	0	2	
ISOLATORS	0	115	0	115	
PROTECTION	0	4	0	4	
SURGE ARRESTER	0	8	0	8	
TRANSFORMER	3	3	3	9	

Conclusion

Eskom

- Transmission has a robust planning process to determine asset replacement requirements, which is aligned to Asset Management principles.
- The current 10 year Transmission refurbishment plan is a good reflection of the needs of the network since it is based on asset condition assessments, asset criticality and network risks.
- The prioritisation process that was employed in developing the portfolio of projects for the 10 year refurbishment plan, embodies the requirements and stipulations of the Grid Code. The plan is flexible enough to accommodate emerging operational risks and current requirements in addition to the planned asset replacement program.
- The plan supports two key strategic imperatives of Eskom Holdings:
 - "Ensure the reliability and availability of power capacity to support South Africa's economic growth ambitions."
 - Continue capturing efficiencies in operating and capital costs to achieve a sustainable tariff path for the economy."
- Opportunities are pursued to enhance the current plan and secure resources to expedite the Refurbishment Plan.





Transformer Refurbishment Strategy

Asset Replacement

- The end of life of transformers and reactors (or estimation) are defined by certain condition criteria which are calibrated into an asset health appraisal.
- The criteria used for the assessment evaluated the transformer/reactor:
 - insulation condition,
 - electrical condition,
 - auxiliary components and
 - the dissolved gas analysis of the insulating oil.
- This condition information (asset health appraisal) forms the basis for the equipment operation, maintenance and refurbishment strategies.

Condition Assessment

Maintenance

 Maintenance is based on the Manufacturer manuals, asset health appraisal, as well as Transmission procedures defined by Transmission Engineering Assets are replaced when they have reached the economic end of life or technical end of life, whichever comes first. Economic end of life brings risk to the customers into the decision which is the least economic criterion in the Grid Code.


- The least economic criterion warrants the replacement of assets when customer interruption costs, CIC (R/kwh) > costs to Eskom
- Optimising the capital budget involves prioritising and considering the best combination of refurbishment projects to reduce overall risk to customers and the network, given the financial constraints.

CIC > <u>Annualised Capex costs + Life cycle costs of new asset – Maintenance costs of old asset</u> probability of failure x load lost x duration


• the probability of failure is a function of the condition of the asset

Transmission Network Refurbishment Plan Development Process

Eskom










Transmission Development Plan 2020 – 2029

Summary and Capex Analysis

By: Makoanyane Theku Manager: Infrastructure Planning Support

A REAL PROPERTY AND INCOME.


Recap: Transmission demand forecast and comparisons



(Eskom

Recap: Assumed Generation Pattern for the TDP 2019








2019 TDP Plan

Transmission Assets:	New Assets expected in	New Assets expected in	Total New Assets			
National View	2020 - 2024	2024 - 2029	Total New Assets			
Power lines (km)						
765 kV	178	190	368			
400 kV	1389	2793	4182			
≤275 kV	172	122	294			
Total length (km)	1739	3105	4844			
Transformers						
Number of units	29	58	87			
Total capacity (MVA)	11050	24280	35330			

Transmission expansion plan: Transmission lines



(Eskom


Transmission expansion plan: Transformer capacity



(Eskom

Major Projects planned in the TDP period

Eskom



Transmission Capital Expenditure Drivers



1. Capacity Expansion and Network Strengthening:


- Connection of new and anticipated customer loads and generation
- N-1 reliability investments
- Mitigation of fault-level exceedances (existing and anticipated)
- Resolution of quality of supply excursions
- Securing of servitudes and environmental authorisations
- Compliance (Regulatory, OHSAct, Environmental etc.)
- 2. **Refurbishment** (i.e. Extension of life of existing assets):
 - Refurbishment of aging equipment (CTs, VTs, Surge Arresters, HV Circuit Breakers and Power Transformers)
 - Replacement of substation batteries and electronic components for protection and control systems, corroded conductors etc. (these not repairable)
 - Targeted asset performance improvements (lines and substation equipment)
 - Physical security improvements and surveillance and monitoring at our key assets and sites
 - Strategic and operational spares holding (to reduce SML<1 and MI risk)
 - Compliance (Regulatory, OHSAct, NKP Act, Environmental etc.)

3. Asset Purchases:


• Specialised equipment for: live-line work; fault location systems, and online condition monitoring, etc.

Transmission 10-year CAPEX Plan: FY2020 - 2029

Summary of Transmission Capex Plan (R Million) FY 2020 - 2029



~R21bn of Capex is for projects in execution



(Eskom



The total Transmission Capital Plan amounts to R98.6 billion over the TDP period 2020 – 2029 of which:

- R79 billion is required for reliability (N-1) projects, integration of committed generation (Medupi, Kusile, IPPs) and connection of new loads and generation onto the system
- R20 billion is required for EIA and servitudes, refurbishment and production equipment



- Decision on Eskom's future MYPD applications may impact execution of the Transmission Development Plan
- The liquidity position of Eskom may impact the execution of the Transmission Development Plan
- The location of future IPPs may also impact the roll-out of new network reinforcements
- The time taken to acquire servitudes remains a challenge to the TDP roll out

Conclusions



- The demand forecast in the TDP assumptions compares favourably with all the forecasts (IRP and Eskom) and is therefore prudent
- The generation forecast assumptions will be sufficient to allow the 2019 TDP to meet the requirements of the IRP (Draft), and where necessary, sensitivity studies will be done to meet extreme conditions or stress test various scenarios
- We are confident that projects currently in construction will be completed in time
- We will continue engaging with our stakeholders to enable network access in anticipation of the Country's future demand and generation needs
- Investments in the Transmission infrastructure is a crucial enabler for economic growth and development



Questions?



Impacts of the IRP 2019

Presented by: Ronald Marais Senior Manager: Strategic Grid Planning



Generation Connection Capacity Assessment 2022

Round 5 - Interest




beyond $4B \rightarrow BW5$ interest (expedited round)

Impact of the New IRP 2019 vs IRP 2018 Draft (referred to as IRP2018)

Eskom

GCCA shows there is Capacity in FS, LP, MP and NW, but little interest for Round 5





Available Capacity BW5 Interest

Available Capacity vs BW5 Interest


- · Interest in RE generation is inverse to network availability
- Capacity will have to be increased in deficit areas or generation must follow capacity

(Eskom






IRP 2019 Impact		2029			() Eskom
		IRP2019	IRP2018	Change	
Hydro	Hydro	0	0		
CSP		300	300		
PV	* Solar	5814	5484	330	
Wind) Wind	14162	7862	6300	4118
Storage	$\langle \langle \rangle$	2088	0	2088	
Gas & Diesel		3000	8100	5100	
Nuclear	Nuclear plant	0	0		4118MW Increase in capacity within
Coal	Coal-fired plant	7232	6732	500	the TDP period






Additional 9.793 GW to be installed by 2025



Developing new Tx capacity in this time frame will be challenging. Most likely existing Tx capacity to be exploited first and local substation strengthening.


Additional Corridor Requirements & Strategic Servitudes required





- Previous strategic studies indicated a need to supplement the corridors
- Gas corridor (SEA) studies will supplement electricity corridors and the request has been included in the study









4118 MW new capacity included in the TDP window

Rephasing of capacity into the period 2022 – 2025

9793 MW increase of capacity between 2022 – 2025


New capacity and rephasing will require acceleration of existing TDP projects, development of new corridors and substation strengthening.

Developing new Tx capacity in this time will be challenging from a servitude, EIA and capital perspective.

Most likely existing Tx capacity will need to be capitalized first.

Co-ordination of wind and solar locations will be important not to sterilize technology capacity integration

Streamlining the process and co-operation/partnership from RE association, DOE, IPP Office etc will be key to the success of the implementation of the IRP 2019 229





Thank you



