

Eskom Presentation to the Joint Portfolio Committee on Public Enterprises & Mineral Resources and Energy

System Status and Outlook

System Operator


31 August 2022



Summary of system status

Summary of Load shedding and curtailment


Power System Outlook



Summary of system status



Financial year-to-date energy sent out from dispatchable plant is 1.4% lower than for the same period last year. (0.67% lower for dispatchable and renewable)



IPP OCGT load factor is 9.9%, Eskom OCGT load factor is 16.4% (Financial year to date)



There were 24 wind generation curtailment events in the financial year.



There were 77 days of load shedding in the financial year.




The highest residual demand (demand supplied by dispatchable generation) for 2022 was 33 136 MW




The highest contracted peak demand (demand supplied by dispatchable and renewable generation contracted to SBO) for 2022 was 34 666 MW

Loadshedding and load curtailment summary



- For FY2022, there have been a total of 65 days of loadshedding, with 22 days of load curtailment at Stage 1&2
- Since 01 January 2022, there have been 91* days of loadshedding, with 18 days of load curtailment at Stage 1&2 and 2 days at Stage 3



In general, some of the following conditions led to the above load reductions:

- Shortage of generation;
- Increased unplanned unavailability;
- Limited fuel availability at peaking stations;
- The need to conserve and replenish depleted emergency resources;
- Poor coal and compromised emissions performance.

Load curtailment is the load reduction obtained from customers who are able to reduce demand on instruction and satisfy the requirements of NRS048-9 for load curtailment


* As at 29 Aug 2022

Power System Outlook

(Summer Plan 2022/23)



Planning process



All reliability maintenance outages are catered for in the 12 month planning period



The maintenance outage optimization is done in the **Capacity Plan** using an unplanned unavailability provision of 10 000 MW. Anything higher than this does not make sense because there would be no room to schedule maintenance. The difference between the **Capacity Plan** and the **System Outlook (Summer Plan)** is that the Capacity Plan contains risks in the assumptions while the System Outlook Plan shows the consequences should those risks materialize.

Components of the Plan

- Four critical components make up the Plan and determine the need for OCGT generation usage and load shedding.
- Due to the 4 000MW uncertainty in unplanned unavailability, scenario planning is necessary to determine the likely outlook.



Installed generation capacity: This includes new build non-commercial generators and dispatchable IPP OCGTs but excludes self-dispatch renewable generation.



Demand forecast: The residual demand forecast (total demand less demand supplied by renewable generation) is used.




PCLF: Planned generation outages for maintenance.




UCLF + OCLF (Unplanned unavailability): Unplanned generation outages.

Cumulative Monthly Unplanned Outage Levels



Unplanned Outage Performance: Winter 2022


Winter UCLF+OCLF Frequency (01-Apr-2022 to 31-Aug-2022)



42.5% of the time we operated above the maximum assumption for the Winter Plan

The **average** UCLF+OCLF over evening peaks was 14 864 MW over the winter period

Total view unplanned outages during Winter



Summary of the Plan



All reliability maintenance required in the 12-month planning period has been accommodated in the plan. This has resulted in a “full” plan with little room to move, extend or add outages.



This outage plan was stress tested with 3 scenarios by the System Operator to estimate the OCGT usage and level of load shedding. For summer 2022/23, 13 000 MW, 14 500 MW & 16 000 MW of UCLF + OCLF provision was used.



For the most part the System Operator will need to source operating reserves from Demand Response (DR) products as well as from emergency reserve sources such as Interruptible Load Shedding (ILS) and OCGTs.



The Plan requires OCGT usage over weekdays, and low diesel usage on some weekends. The failure of Medupi 4 has increased the dependency on diesel generation to manage the power system.



The plan is “tight” and any significant outage slips will have a knock-on effect that will influence the plan from that point forward.



The plan does not cater for difficulties that could arise at power stations due to industrial action or other employee protests.



There is a $\pm 2\,000$ MW variance in UCLF (4 000 MW). This is often the variance in one week (168 hours). This cannot be predicted and makes planning uncertain.



This is equivalent to four stages of load shedding. In practical term it mostly means we operate in the range of having 2 000 MW of reserve to needing Stage 2 load shedding to create sufficient reserves.



Demand response was added to the plan in anticipation of signing up new customers. The demand forecast was reduced by 150MW for September 2022 – February 2023 and 400MW for the rest of the planning period.



The uncertainty of the Plan must be clearly communicated and understood by all stakeholders including government and the public.

Critical success factors



All resources and funding must be made available as needed to execute this plan. Any changes to this will have a knock-on effect that will influence the plan from that point forward.



The success of the plan relies on sufficient diesel to support the power system during periods of high UCLF. Without sufficient diesel to power the 3 000 MW of OCGT, 3 additional stages of load shedding *could* be added to the scenarios shown below.




Prolonged diesel usage may result in delays in getting fuel to the OCGT stations (approval of funds, procurement of product & logistics to move fuel). Failure to supply sufficient diesel will lead to further load shedding.



Outage 126 (SGR and refuelling) at Koeberg will significantly increase the risk of load shedding for 240 days.

System Operator Capacity Outlook for the next 12 Months (Base Case)



Monthly System Status Outlook to March 2023

System Status Including 2200MW Operating Reserves			Base Case				Base Case + 1500 MW Risk				Base Case + 3000 MW Risk			
Month	Peak Residual Forecast	Unplanned Provision	Load Reduction Days	Max Load Reduction Stage	Estimated Monthly Gas Generation	Estimated Gas Generation Cost (Rm)	Load Reduction Days	Max Load Reduction Stage	Estimated Monthly Gas Generation	Estimated Gas Generation Cost (Rm)	Load Reduction Days	Max Load Reduction Stage	Estimated Monthly Gas Generation	Estimated Gas Generation Cost (Rm)
September 2022	30,109	13,000	0		119,468	R665.43	19	②	354,136	R1,972.54	27	③	831,408	R4,630.94
October 2022	29,325	13,000	0		92,986	R517.93	10	②	293,245	R1,633.37	22	③	716,259	R3,989.56
November 2022	28,959	13,000	4	①	139,976	R779.66	17	②	524,211	R2,919.85	26	③	1,047,261	R5,833.24
December 2022	28,687	13,000	3	①	369,908	R2,060.39	19	②	992,008	R5,525.48	30	③	1,606,074	R8,945.83
January 2023	28,311	13,000	2	①	386,768	R2,154.30	20	②	960,217	R5,348.41	28	③	1,438,280	R8,011.22
February 2023	29,058	13,000	13	①	309,414	R1,723.44	20	③	799,608	R4,453.82	28	④	1,144,764	R6,376.34
March 2023	29,185	13,000	0		217,311	R1,210.42	18	②	737,022	R4,105.21	28	③	1,323,497	R7,371.88
April 2023	31,621	13,000	0		95,376	R531.24	13	②	310,969	R1,732.10	23	③	711,408	R3,962.54
May 2023	34,267	13,000	2	①	135,735	R756.04	19	②	313,830	R1,748.03	30	③	617,546	R3,439.73
June 2023	33,710	13,000	0		103,916	R578.81	16	②	258,355	R1,439.04	28	③	544,987	R3,035.57
July 2023	33,397	13,000	0		107,663	R599.68	17	②	272,627	R1,518.53	29	③	577,283	R3,215.47
August 2023	32,111	13,000	0		95,656	R532.80	15	②	273,460	R1,523.17	27	③	599,437	R3,338.86




Note: The base case unplanned unavailability provision (UCLF+OCLF) has been increased to 13 000 MW for summer based on the performance over the past year. The scenarios stress tested are at 1 500 MW intervals above the base case.



History has shown that it is not possible to use more than about R 2.4bn of diesel in a month due to the physical limitations of moving the diesel to the OCGT stations. Where the Plan shows a diesel usage greater than this, additional stages of load shedding should be expected

Interventions to contribute to the National Energy Crisis Committee

Overview of estimated additional capacity over 36 months (MW)



Notes

- Plant performance is based on Generation recovery plan to address load losses and includes Kusile units currently in operation
- New build includes commissioning of units 5 and 6 at Kusile, and recovery of unit 4 at Medupi (Aug 2024)
- Procurement of new Generation capacity consists of:
 - Standard offer, emergency procurement, imports from the region ~ 2300 MW in the next 12 months.
 - Land leasing initiative and Section 34 procurement** (RMIPPPP, battery storage and bid window 5,6 included in the latter part of the plan), **24 months onwards**
- Additional ~1450MW of demand management interventions over 3 years

- Successful implementation of all the initiatives will greatly reduce the risk of load shedding
- Timing of new generation capacity is dependent on the market response and regulatory processes



Thank you