



Western Region

Parc du Cap, Building 5, cor. Mispel Str & Willie van Schoor Avenue, Bellville, 7530
Private Bag X19, Bellville, South Africa, 7530
Tel +27 (0) 21 957 4600 Fax +27 (0) 21 946 1630

Head Office Tel +27 (0) 12 426 6000 Fax +27 (0) 12 342 1320 / 1322

Offices in Menlyn - Pretoria, Pietermaritzburg, Port Elizabeth

Reference: Nc11/1/4-12/5

Date: 14 March 2007

Email: runkelc@nra.co.za

Fax Number: +27 (0) 21 946 1630

Direct Line: +27 (0) 21 957 4600

Website: www.nra.co.za

Ms B Shinga
Acer Africa Environmental
Management Consultants
P O Box 503
MTUNZINI
3867

*Creating
wealth through
infrastructure*

Dear Ms Shinga

NATIONAL ROUTE 12 SECTION 6: EIA COMMENT: DRAFT SCOPING REPORT: GAMMA SUBSTATION

Thank you for the CD and telephone call.

The South African National Roads Agency Limited (SANRAL) has the following comments with regard to the proposed Gamma Substation.

SANRAL has a statutory building line of 60m measured from the road reserve fence, adjacent to the national road as well as a 500m radius building restriction measured from the centre point of an intersection on a national road. SANRAL will not allow any servitudes inside the building restriction. Application needs to be submitted to SANRAL for a wayleave in terms of Act 7 of 1998 for the construction of the substation if it is to be situated within the 500m radius building restriction or if a road crossing is anticipated.

SANRAL will impose conditions in terms of Act 7 of 1998 upon approval of a wayleave.

Yours sincerely

MJ RUNKEL
STATUTORY CONTROL

✓
BS

DOC # 259502